

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月01日

報表日期: 114年10月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.99	13.14	61.70	2.21	16.17	11.69	1.27	78284.00
1	14.40	11.98	53.65	2.87	16.17	11.04	1.28	83468.76
2	12.22	11.63	54.76	2.74	16.02	11.29	1.26	81893.50
3	7.89	11.75	55.12	2.48	16.08	11.02	1.25	84395.67
4	7.57	11.25	56.61	2.55	16.09	11.03	1.27	83837.55
5	15.90	13.00	51.13	2.12	15.48	11.55	1.25	80300.33
6	8.42	13.30	48.58	1.61	15.58	11.58	1.25	80017.72
7	9.72	12.97	52.35	1.73	15.39	11.52	1.25	80716.06
8	3.73	13.83	66.17	1.26	15.11	12.12	1.25	73632.08
9	9.55	13.00	49.29	1.68	15.91	10.81	1.25	83743.42
10	6.47	13.19	58.38	1.93	13.40	11.89	1.25	75775.09
11	7.41	13.32	52.55	1.39	15.17	11.73	1.25	77463.63
12	9.17	12.65	59.94	1.49	15.50	11.31	1.25	80101.65
13	11.70	12.98	51.05	1.39	16.49	11.40	1.25	78517.59
14	7.72	15.09	62.40	1.12	16.16	11.25	1.25	79413.50
15	7.47	16.07	46.60	1.50	14.88	11.59	1.25	76518.19
16	12.97	16.90	47.86	1.32	17.07	10.82	1.25	80858.97
17	17.10	15.08	56.83	1.87	16.83	10.68	1.25	83865.90
18	6.01	16.68	53.67	0.97	16.51	11.27	1.25	78098.24
19	7.02	13.96	57.18	1.55	14.54	11.48	1.24	77875.17
20	7.24	13.89	42.53	1.74	14.01	11.69	1.23	76477.55
21	10.00	13.58	46.74	1.46	15.26	11.58	1.25	77086.51
22	9.32	13.02	56.29	1.85	14.30	11.49	1.25	79156.76
23	8.12	14.05	53.77	2.26	13.57	12.04	1.25	74316.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.38	13.60	53.96	1.80	15.49	11.41	1.25	79408.93
最 大 值	17.10	16.90	66.17	2.87	17.07	12.12	1.29	84395.67
發生時間	17	16	8	1	16	8		3
最 小 值	3.73	11.25	42.53	0.97	13.40	10.68	1.23	73632.08
發生時間	8	4	20	18	10	17		8
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	0.00 %		0.06		0.00 %
全幅偏移(率)	0.10 %	0.49 %	-0.30 %	-0.47 %		0.23		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月01日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.37	12.57	56.09	1.86	17.43	10.06	1.36	79064.85
1	8.50	12.65	48.38	2.87	19.91	9.10	1.39	73043.64
2	12.15	12.13	56.76	3.23	18.24	9.35	1.41	82895.59
3	9.96	13.24	59.66	2.46	16.31	10.02	1.41	81118.17
4	7.79	11.00	55.47	2.49	16.65	9.95	1.41	83331.93
5	9.54	11.77	63.16	3.39	14.90	10.64	1.38	80526.17
6	8.41	11.95	60.09	2.77	15.76	10.50	1.38	83440.01
7	8.86	11.95	49.26	0.67	17.58	10.11	1.43	80858.30
8	7.61	12.27	54.65	0.89	16.21	10.76	1.39	78422.26
9	7.16	12.38	54.88	0.89	16.24	10.72	1.41	76342.83
10	8.77	12.34	53.15	0.90	16.04	10.61	1.38	77108.07
11	8.98	12.15	58.44	0.80	16.69	10.73	1.42	78819.45
12	9.06	12.33	55.90	0.99	16.61	10.85	1.37	78755.84
13	12.71	12.34	58.72	0.84	17.39	10.73	1.37	80719.50
14	8.58	14.45	51.40	0.70	17.52	10.19	1.36	78687.88
15	9.38	13.26	45.53	1.31	17.04	9.92	1.40	78161.39
16	17.66	13.43	52.70	2.85	17.24	9.96	1.41	80620.42
17	6.40	12.95	47.93	0.48	19.02	9.36	1.37	83932.71
18	6.29	13.14	47.46	0.68	17.29	9.82	1.36	80131.71
19	4.36	13.47	49.84	0.80	16.90	10.06	1.41	79476.21
20	6.86	12.98	46.37	0.79	17.20	9.71	1.38	79945.98
21	10.64	14.47	54.02	1.53	16.27	10.60	1.38	78268.85
22	5.36	13.09	37.00	0.08	17.60	9.49	1.36	75779.84
23	8.78	12.93	46.08	0.10	18.09	9.40	1.36	78155.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.88	12.72	52.62	1.43	17.09	10.11	1.39	79483.63
最 大 值	17.66	14.47	63.16	3.39	19.91	10.85	1.43	83932.71
發生時間	16	21	5	5	1	12		17
最 小 值	4.36	11.00	37.00	0.08	14.90	9.10	1.34	73043.64
發生時間	19	4	22	22	5	1		1
零點偏移(率)	-0.09 %	-0.01 %	0.00 %	-0.01 %		-0.02		0.00 %
全幅偏移(率)	-0.28 %	0.52 %	-0.17 %	0.81 %		0.40		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								