

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.47	13.71	36.71	1.70	17.44	11.28	1.10	81560.80
1	9.02	13.46	56.74	1.54	17.57	12.07	1.12	75761.96
2	11.25	11.85	45.53	2.57	16.69	10.88	1.13	85787.33
3	10.99	13.19	43.49	2.38	16.07	11.42	1.13	81964.93
4	9.89	12.63	45.39	2.20	16.60	11.17	1.12	83692.49
5	8.71	11.92	49.05	1.86	15.99	11.54	1.17	83150.39
6	9.79	11.76	50.63	2.05	16.15	11.43	1.15	81611.05
7	8.54	12.51	54.57	1.70	16.19	12.01	1.16	77109.70
8	9.69	12.53	50.94	1.32	17.14	11.47	1.18	80423.78
9	9.71	11.83	45.26	1.76	17.10	10.84	1.18	85376.78
10	10.25	15.43	49.15	3.37	14.69	11.46	1.14	82194.11
11	17.32	14.43	50.18	6.56	13.24	12.08	1.18	77598.28
12	10.61	12.10	44.96	1.59	14.43	11.94	1.18	78515.14
13	8.85	12.34	47.36	1.28	15.09	11.90	1.17	77609.20
14	12.76	12.60	33.76	1.53	14.50	11.76	1.18	77562.72
15	9.56	12.86	40.83	1.32	14.50	12.23	1.17	75074.59
16	11.05	12.19	49.10	1.70	14.84	11.63	1.16	81087.20
17	9.95	14.13	34.09	2.46	13.89	11.91	1.18	77709.63
18	9.33	12.37	45.39	1.50	14.54	12.04	1.18	77891.99
19	11.45	12.62	39.88	1.69	15.24	11.71	1.18	79924.70
20	8.72	12.53	48.42	1.42	14.90	11.98	1.18	78080.91
21	9.90	12.62	47.15	1.09	15.76	11.57	1.17	80553.00
22	9.25	11.69	45.86	1.53	14.92	11.49	1.15	82064.65
23	9.11	12.76	53.63	1.69	15.25	12.28	1.13	74930.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.26	12.75	46.17	1.99	15.53	11.67	1.16	79884.81
最大值	17.32	15.43	56.74	6.56	17.57	12.28	1.20	85787.33
發生時間	11	10	1	11	1	23		2
最小值	8.54	11.69	33.76	1.09	13.24	10.84	1.10	74930.21
發生時間	7	22	14	21	11	9		23
零點偏移(率)	-0.01 %	0.01 %	-0.01 %	0.00 %		-0.19	-0.01	0.30 %
全幅偏移(率)	-0.55 %	1.00 %	1.29 %	0.06 %		0.06	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.82	11.98	49.44	0.95	18.34	10.39	1.06	78221.47
1	5.77	11.90	44.96	1.61	17.91	10.36	1.06	78806.53
2	8.38	11.93	48.58	1.56	17.20	10.52	1.06	78243.59
3	13.42	12.10	50.66	2.50	15.61	10.81	1.06	78461.16
4	14.30	12.17	58.85	2.40	16.13	10.89	1.06	78212.26
5	11.27	11.92	49.05	2.00	16.46	10.71	1.05	79042.64
6	12.72	11.44	57.89	2.34	17.28	10.13	1.02	77570.44
7	11.81	11.72	49.53	2.21	17.47	10.43	1.02	79382.22
8	4.70	11.69	43.93	1.77	17.15	10.44	1.02	80062.18
9	2.33	11.90	43.09	1.56	17.37	10.28	1.05	79139.96
10	1.31	11.45	42.57	1.49	17.23	10.17	1.02	77935.51
11	3.77	11.79	42.59	1.89	16.31	10.29	1.03	78075.27
12	2.21	11.61	42.99	1.99	15.53	10.48	1.02	75710.30
13	2.65	11.54	42.11	1.90	16.29	10.28	1.03	76646.42
14	3.20	13.02	44.42	2.15	15.20	10.21	1.02	75449.41
15	3.66	11.96	37.15	1.51	16.22	10.08	1.02	75269.34
16	6.85	11.66	50.76	1.80	15.25	10.32	1.02	76857.42
17	9.42	13.33	48.40	2.08	15.62	10.13	1.01	76184.43
18	7.33	11.33	45.70	1.31	15.99	9.96	1.02	75654.88
19	7.65	12.05	62.07	2.17	14.61	10.22	1.02	76817.30
20	11.94	12.04	62.14	2.63	14.19	10.55	1.02	76488.48
21	12.21	11.42	37.16	2.09	15.63	10.17	1.01	77759.05
22	11.79	12.45	48.68	2.25	15.71	10.25	1.02	78663.93
23	7.28	11.39	54.87	1.42	16.10	10.38	1.02	78195.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.62	11.91	48.23	1.90	16.28	10.35	1.03	77618.76
最大值	14.30	13.33	62.14	2.63	18.34	10.89	1.06	80062.18
發生時間	4	17	20	20	0	4		8
最小值	1.31	11.33	37.15	0.95	14.19	9.96	1.00	75269.34
發生時間	10	18	15	0	20	18		15
零點偏移(率)	-0.08 %	0.01 %	-0.04 %	-0.01 %		-0.08	-0.01	0.00 %
全幅偏移(率)	-1.92 %	1.81 %	0.61 %	-0.38 %		-0.10	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.21	11.79	49.09	2.30	18.67	9.31	1.47	74077.86
1	9.65	12.12	45.62	2.43	18.50	9.30	1.48	73680.68
2	9.56	13.12	40.38	2.08	16.37	9.27	1.46	72680.22
3	9.46	11.20	40.12	2.05	17.22	9.20	1.47	74741.70
4	9.44	11.01	38.52	2.64	17.50	9.01	1.46	74027.61
5	9.59	10.88	38.02	2.57	17.02	9.09	1.47	73175.83
6	9.59	10.66	38.14	2.48	18.07	8.90	1.48	74634.74
7	6.83	11.37	38.19	1.74	20.09	8.68	1.46	76491.06
8	9.71	11.17	38.53	1.99	18.30	9.08	1.47	74614.80
9	9.58	11.84	34.54	1.94	18.78	8.91	1.47	75071.52
10	9.30	14.11	25.19	2.58	18.53	8.66	1.46	74980.98
11	10.97	12.06	38.68	3.60	16.63	9.30	1.46	72522.49
12	9.48	11.88	38.07	1.50	15.61	9.82	1.43	66728.23
13	9.46	12.82	37.37	1.97	17.04	9.01	1.45	70825.18
14	9.40	12.56	35.26	1.55	16.90	8.89	1.44	69655.89
15	7.59	12.06	24.76	2.65	16.50	8.38	1.42	69682.48
16	8.74	11.54	39.16	1.69	15.95	9.17	1.42	71055.72
17	9.26	10.90	39.31	2.63	16.53	9.32	1.43	72334.70
18	9.50	11.61	45.08	2.46	16.21	9.41	1.44	71266.02
19	9.49	11.42	45.87	2.15	16.39	9.17	1.43	72313.35
20	9.62	13.06	42.71	2.44	15.44	8.98	1.43	72026.10
21	9.70	12.03	41.93	1.23	16.13	8.96	1.43	72612.03
22	9.06	11.70	40.36	1.17	17.18	9.00	1.43	73621.50
23	9.89	11.06	38.27	1.65	17.72	8.87	1.45	74689.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.34	11.83	38.88	2.15	17.22	9.07	1.45	72812.92
最大值	10.97	14.11	49.09	3.60	20.09	9.82	1.48	76491.06
發生時間	11	10	0	11	7	12		7
最小值	6.83	10.66	24.76	1.17	15.44	8.38	1.41	66728.23
發生時間	7	6	15	22	20	15		12
零點偏移(率)	-0.01 %	-0.02 %	-0.01 %	0.01 %		-0.07	-0.01	0.10 %
全幅偏移(率)	-1.60 %	-0.22 %	0.03 %	-0.02 %		0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								