

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.37	12.98	59.07	0.50	19.58	11.10	1.04	75617.91
1	4.43	7.70	59.31	1.12	20.44	10.46	1.02	83465.46
2	4.14	8.30	43.28	2.79	16.46	11.80	1.02	75833.58
3	6.06	10.59	56.83	1.73	18.07	11.54	1.02	77922.04
4	9.09	9.33	52.43	2.36	16.81	11.66	1.02	77650.03
5	8.17	7.60	51.69	2.46	18.02	11.26	1.05	76477.12
6	5.18	12.52	51.49	2.43	17.23	11.62	1.06	76945.45
7	6.36	12.86	61.13	1.93	18.73	11.41	1.04	78018.34
8	6.41	8.49	53.41	2.26	17.69	11.56	1.03	76649.21
9	6.92	7.83	64.11	1.77	19.48	11.33	1.05	77832.49
10	6.36	8.34	54.27	1.70	19.31	11.43	1.04	77494.39
11	7.06	8.40	57.78	1.50	19.19	11.21	1.03	79010.12
12	6.70	12.66	53.28	1.42	19.94	10.64	1.03	81752.31
13	8.26	6.11	52.40	2.59	16.89	11.59	1.03	74344.83
14	8.12	9.58	55.97	2.58	18.67	11.42	1.03	76711.41
15	8.62	8.40	50.95	2.38	17.93	11.48	1.03	76999.35
16	9.31	8.34	62.83	1.90	18.30	11.69	1.05	76220.15
17	7.98	8.01	62.42	1.73	19.31	11.15	1.05	79871.64
18	9.50	11.55	58.77	2.16	18.34	11.09	1.05	81626.16
19	9.22	11.64	60.12	1.77	18.93	11.11	1.05	80462.40
20	8.11	12.45	51.80	2.04	17.49	11.46	1.04	78105.67
21	10.35	11.98	49.23	2.81	17.03	11.70	1.02	77251.87
22	8.10	13.24	55.19	2.19	17.61	11.87	1.02	75608.27
23	7.07	12.13	64.24	1.51	18.10	12.05	1.01	73909.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.20	10.04	55.92	1.98	18.31	11.40	1.03	77740.84
最大值	10.35	13.24	64.24	2.81	20.44	12.05	1.06	83465.46
發生時間	21	22	23	21	1	23		1
最小值	1.37	6.11	43.28	0.50	16.46	10.46	1.00	73909.97
發生時間	0	13	2	0	2	1		23
零點偏移(率)	-0.04 %	0.00 %	-0.03 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.00 %	-0.45 %	-0.85 %	0.09 %		0.31		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.52	10.07	42.76	1.22	18.86	10.05	1.03	86640.58
1	0.29	4.58	48.08	1.54	19.43	10.21	1.03	84215.35
2	2.46	6.21	67.86	1.57	17.41	10.74	1.03	82511.04
3	9.14	8.56	48.64	2.49	17.71	10.41	1.03	84930.09
4	4.20	8.29	51.88	1.69	18.14	10.29	1.05	85158.32
5	1.42	8.01	56.48	1.87	17.24	10.71	1.05	82550.35
6	2.16	6.69	54.00	2.01	18.13	10.19	1.05	84708.38
7	3.26	9.28	44.89	1.58	17.68	10.34	1.03	82545.64
8	7.61	3.48	50.60	1.79	18.83	9.90	1.02	87174.72
9	8.48	3.55	52.42	2.27	17.97	10.35	1.02	84716.30
10	8.76	12.56	44.79	1.62	19.96	9.75	1.02	87609.34
11	7.61	5.47	47.91	2.16	18.11	10.28	1.02	85019.27
12	8.82	14.05	46.99	2.22	17.42	10.23	1.02	85997.87
13	9.68	4.03	47.02	2.83	17.64	10.46	1.02	83899.69
14	8.45	2.08	54.24	2.02	18.88	10.20	1.01	85327.19
15	9.81	6.66	53.64	1.68	18.71	10.23	1.02	84500.28
16	9.32	7.41	46.80	2.29	18.03	10.21	1.02	86557.51
17	9.08	8.05	50.39	1.80	18.24	10.12	1.04	86919.87
18	7.15	8.18	55.61	1.84	17.89	10.56	1.02	83227.67
19	5.39	8.41	46.68	1.96	17.71	10.18	1.00	85164.24
20	9.41	5.62	51.18	2.16	16.84	10.34	0.99	83835.76
21	9.09	8.02	42.79	1.99	17.36	10.47	0.99	84431.91
22	8.44	6.75	50.19	1.48	19.15	10.07	1.01	86182.47
23	2.46	8.44	63.98	1.25	18.47	11.32	1.02	76797.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.42	7.27	50.83	1.89	18.16	10.32	1.02	84609.24
最大值	9.81	14.05	67.86	2.83	19.96	11.32	1.07	87609.34
發生時間	15	12	2	13	10	23		10
最小值	0.29	2.08	42.76	1.22	16.84	9.75	0.99	76797.95
發生時間	1	14	0	0	20	10		23
零點偏移(率)	-0.05 %	-0.12 %	-0.28 %	-0.01 %		0.00		-0.20 %
全幅偏移(率)	0.04 %	-0.63 %	-0.45 %	-0.29 %		-0.29		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.59	6.06	45.99	1.09	17.07	10.50	0.99	82616.58
1	0.19	5.20	53.52	0.94	18.36	10.67	0.99	81036.23
2	0.30	10.53	51.92	1.86	14.50	11.33	0.99	74257.40
3	0.24	4.93	58.18	1.25	16.40	11.29	0.99	74699.02
4	0.05	9.51	49.93	1.03	17.24	10.72	0.99	80606.29
5	0.00	5.97	48.15	1.00	17.59	10.65	1.02	83606.20
6	0.01	7.21	52.75	1.07	17.06	10.91	1.03	79571.77
7	0.03	5.96	49.10	1.11	17.22	10.69	1.00	79858.46
8	0.09	11.65	51.03	1.35	16.80	10.78	1.02	80998.94
9	3.71	7.11	53.75	1.57	16.47	11.24	1.05	79624.99
10	3.02	5.26	60.71	1.37	17.48	10.99	1.00	81347.03
11	1.90	5.73	52.91	1.45	16.40	11.05	1.01	81443.48
12	0.52	5.59	51.89	1.11	18.24	10.44	1.04	82518.50
13	2.80	5.57	47.67	1.58	16.08	10.75	1.02	79509.55
14	6.76	6.35	53.02	2.25	16.77	10.44	0.98	80255.12
15	6.22	9.75	42.18	1.74	16.26	10.49	0.97	75681.09
16	5.46	2.16	52.95	1.58	16.78	10.63	1.00	79830.71
17	6.90	3.73	52.99	1.58	16.40	10.80	1.03	80339.23
18	5.94	8.51	57.93	1.52	16.37	11.04	1.01	80758.88
19	4.96	11.02	60.70	1.71	15.70	11.16	0.99	80888.07
20	8.44	6.25	53.52	1.93	15.29	10.95	0.99	76520.26
21	7.37	6.69	56.49	2.10	15.13	11.23	0.97	74660.26
22	9.74	6.21	54.67	2.02	17.74	10.27	0.97	80808.62
23	8.81	6.48	57.46	1.68	16.88	10.92	0.97	75812.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.54	6.81	52.89	1.50	16.68	10.83	1.00	79468.71
最大值	9.74	11.65	60.71	2.25	18.36	11.33	1.07	83606.20
發生時間	22	8	10	14	1	2		5
最小值	0.00	2.16	42.18	0.94	14.50	10.27	0.97	74257.40
發生時間	5	16	15	1	2	22		2
零點偏移(率)	-0.07 %	0.00 %	-0.02 %	-0.01 %		-0.02		0.00 %
全幅偏移(率)	-2.23 %	0.05 %	-0.85 %	0.01 %		0.15		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								