

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.77	9.09	63.81	1.34	19.54	10.75	1.07	78573.07
1	9.54	9.69	56.39	2.66	17.13	11.61	1.07	74168.30
2	9.01	7.13	63.11	2.09	16.84	11.72	1.07	74380.07
3	9.28	7.12	56.85	2.24	17.00	11.46	1.05	76115.54
4	10.09	7.97	61.94	2.63	16.05	11.77	1.05	74119.45
5	10.14	10.76	58.59	2.22	16.93	11.43	1.07	74296.49
6	8.86	7.46	57.60	1.85	17.64	11.37	1.07	75463.81
7	9.91	7.71	59.80	2.46	16.43	11.61	1.07	74479.50
8	9.66	7.73	52.72	2.78	15.72	11.70	1.06	74685.37
9	11.22	7.99	59.90	2.47	15.79	11.78	1.05	74513.77
10	10.32	7.95	53.07	2.76	15.34	11.66	1.05	75753.63
11	8.27	8.12	56.58	2.58	15.26	11.91	1.05	73883.40
12	9.87	6.96	54.66	2.71	15.28	11.85	1.07	74054.05
13	8.96	8.25	55.72	2.22	16.02	11.72	1.07	74112.32
14	9.66	9.91	62.82	2.55	15.43	12.21	1.07	70557.90
15	9.38	9.18	52.29	2.90	14.89	11.98	1.07	72570.95
16	8.07	7.32	62.55	1.59	16.89	11.65	1.06	74298.93
17	9.47	8.39	51.48	1.87	16.50	11.39	1.05	76711.57
18	4.54	8.16	65.56	1.36	16.67	11.94	1.07	72430.10
19	5.40	7.61	51.54	1.41	18.47	10.68	1.07	80752.24
20	6.90	8.58	52.75	1.13	19.53	10.59	1.06	79954.12
21	9.63	8.44	58.24	1.53	18.79	11.04	1.06	77429.23
22	9.64	8.08	54.05	2.00	17.84	11.18	1.05	76606.57
23	9.83	7.70	58.49	1.66	18.53	10.96	1.05	77779.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.06	8.22	57.52	2.13	16.85	11.50	1.06	75320.40
最大值	11.22	10.76	65.56	2.90	19.54	12.21	1.12	80752.24
發生時間	9	5	18	15	0	14		19
最小值	4.54	6.96	51.48	1.13	14.89	10.59	1.05	70557.90
發生時間	18	12	17	20	15	20		14
零點偏移(率)	-0.01 %	-0.01 %	-0.18 %	-0.06 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.63 %	0.25 %	0.28 %		0.27		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.76	5.90	50.52	1.65	17.82	9.92	0.99	86725.84
1	10.32	4.88	52.43	2.26	17.83	9.80	0.99	87908.86
2	8.64	5.53	51.27	2.23	16.61	9.92	0.99	88520.03
3	10.43	4.86	55.25	2.00	17.03	9.92	0.99	87544.33
4	9.23	10.07	55.42	2.07	16.72	9.99	0.99	87185.34
5	7.98	6.47	48.12	2.28	16.32	10.06	0.99	87550.24
6	9.70	7.67	58.17	2.92	15.56	10.36	0.99	83511.25
7	9.89	7.16	52.73	3.07	15.05	10.35	0.99	86128.00
8	9.54	3.76	53.42	2.75	15.30	10.53	0.99	84997.83
9	10.25	3.69	56.58	3.09	15.53	10.19	0.99	86539.85
10	7.86	5.28	55.59	3.19	14.59	10.92	1.00	81686.57
11	2.73	7.49	58.15	1.93	16.14	11.86	1.03	73029.24
12	5.13	3.86	46.81	1.78	16.69	10.96	1.04	79829.71
13	9.87	4.58	36.81	2.47	15.01	10.22	1.03	87129.57
14	9.53	7.49	36.32	2.92	14.88	10.42	1.02	85958.87
15	8.73	5.00	38.35	2.60	15.50	10.29	1.02	86435.72
16	8.63	7.06	37.76	2.37	15.79	10.35	1.02	85120.81
17	9.71	3.00	36.00	1.87	17.76	9.68	0.99	89192.27
18	8.94	3.76	32.57	2.11	17.19	10.12	0.99	85752.86
19	8.70	4.63	33.28	1.64	18.17	10.08	1.00	85050.28
20	9.94	4.47	42.09	1.91	16.61	10.20	1.00	85129.00
21	8.53	5.61	40.63	2.35	15.14	10.67	1.00	83661.36
22	9.35	5.71	38.52	1.80	17.49	10.13	0.99	85424.27
23	9.73	5.13	33.87	1.76	18.06	9.58	0.99	88633.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.84	5.54	45.86	2.29	16.37	10.27	1.00	85360.25
最大值	10.43	10.07	58.17	3.19	18.17	11.86	1.10	89192.27
發生時間	3	4	6	10	19	11		17
最小值	2.73	3.00	32.57	1.64	14.59	9.58	0.99	73029.24
發生時間	11	17	18	19	10	23		11
零點偏移(率)	-0.06 %	-0.02 %	-0.01 %	-0.02 %		0.05		-0.20 %
全幅偏移(率)	0.02 %	-0.10 %	0.28 %	0.03 %		0.03		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.19	6.76	60.53	2.46	14.13	11.54	0.94	78565.80
1	8.17	5.66	57.36	1.69	16.00	11.09	0.94	80453.50
2	9.33	5.15	54.39	1.98	15.18	11.00	0.94	80738.63
3	11.67	5.11	61.81	2.25	14.85	11.15	0.94	81935.15
4	10.23	6.93	60.01	2.53	14.15	11.28	0.94	79817.94
5	9.59	6.30	55.48	2.09	15.14	10.96	0.94	81286.42
6	8.58	7.31	56.34	2.97	14.18	11.12	0.94	78065.18
7	4.01	9.52	50.48	2.15	14.25	11.01	0.94	70917.78
8	9.36	6.74	51.91	2.22	14.39	10.95	0.94	77751.75
9	11.32	7.20	52.60	2.71	14.71	10.77	0.95	78608.49
10	7.78	8.17	56.34	2.20	14.29	11.11	0.94	78051.31
11	8.94	7.00	56.06	3.03	13.17	11.38	0.94	76961.98
12	8.56	7.64	51.76	2.65	13.14	11.25	0.94	76066.36
13	9.92	11.92	52.91	2.77	13.31	11.11	0.94	76123.28
14	5.64	3.80	50.59	3.26	12.24	11.59	0.94	75436.03
15	6.30	9.43	50.14	2.82	13.21	11.17	0.94	75526.81
16	11.68	4.66	65.99	1.71	16.41	10.90	0.96	81653.74
17	5.28	13.53	54.72	2.17	14.51	11.68	0.96	77780.10
18	6.41	5.66	49.93	2.34	15.04	11.39	0.94	75532.97
19	7.81	5.66	49.32	1.20	17.18	10.43	0.94	78698.50
20	9.42	7.48	50.37	1.45	16.65	10.37	0.94	80571.61
21	9.04	8.98	52.27	1.53	16.16	10.59	0.96	81676.38
22	9.54	4.74	63.02	1.35	16.71	10.95	0.97	81323.27
23	9.13	5.72	56.91	1.76	15.38	11.02	0.97	81265.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.66	7.13	55.05	2.22	14.77	11.08	0.95	78533.68
最大值	11.68	13.53	65.99	3.26	17.18	11.68	0.97	81935.15
發生時間	16	17	16	14	19	17		3
最小值	4.01	3.80	49.32	1.20	12.24	10.37	0.92	70917.78
發生時間	7	14	19	19	14	20		7
零點偏移(率)	-0.18 %	-0.01 %	-0.04 %	0.00 %		0.04		0.00 %
全幅偏移(率)	-0.19 %	1.11 %	-0.80 %	0.23 %		0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								