

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.54	7.36	45.41	1.22	18.95	11.31	1.07	73198.99
1	8.45	7.94	50.52	0.93	20.05	11.12	1.07	74765.69
2	9.19	7.38	54.98	1.02	20.13	10.45	1.07	79383.33
3	7.38	7.83	53.60	0.89	19.82	11.01	1.04	75672.73
4	9.51	7.90	48.86	1.02	19.84	10.73	1.03	77881.26
5	13.12	11.43	44.79	1.05	18.89	11.18	1.04	77483.50
6	9.17	9.12	47.91	0.56	19.99	10.86	1.05	75850.30
7	9.44	6.64	43.91	0.74	19.17	11.13	1.05	74493.90
8	9.19	5.88	44.14	0.55	19.90	10.80	1.07	76337.09
9	8.83	11.93	57.58	0.74	19.76	11.24	1.10	72468.90
10	9.11	12.84	44.52	0.61	19.15	11.03	1.09	75154.51
11	8.43	12.10	40.82	0.67	19.49	10.87	1.07	75288.97
12	7.41	12.37	55.08	0.46	18.63	11.68	1.07	70050.01
13	8.76	10.28	43.62	0.53	19.11	10.76	1.10	76806.70
14	9.03	6.18	43.36	1.11	19.08	10.91	1.10	75578.24
15	9.78	6.38	52.62	0.81	19.30	11.12	1.10	74588.76
16	8.58	6.56	50.88	0.75	19.04	11.28	1.08	73029.39
17	4.85	6.68	62.39	0.34	19.36	11.68	1.06	69831.99
18	6.27	6.47	54.51	0.36	20.81	10.82	1.05	75145.28
19	9.05	10.73	41.18	0.42	21.07	9.93	1.07	81528.02
20	10.08	10.74	36.90	0.44	20.59	10.33	1.08	78890.85
21	6.24	2.33	33.74	0.86	18.72	11.02	1.08	73412.50
22	3.90	6.05	48.59	0.31	20.06	11.17	1.07	73390.05
23	1.69	7.50	55.42	0.37	19.00	11.73	1.07	69941.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.17	8.36	48.14	0.70	19.58	11.01	1.07	75007.18
最大值	13.12	12.84	62.39	1.22	21.07	11.73	1.10	81528.02
發生時間	5	10	17	0	19	23		19
最小值	1.69	2.33	33.74	0.31	18.63	9.93	1.02	69831.99
發生時間	23	21	21	22	12	19		17
零點偏移(率)	-0.75 %	-0.01 %	-0.07 %	-0.06 %		-0.19		0.00 %
全幅偏移(率)	0.00 %	3.97 %	1.24 %	1.69 %		0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.82	4.42	48.64	2.28	18.23	10.01	1.05	86868.79
1	4.58	7.69	52.50	2.17	18.33	10.38	1.06	84484.56
2	5.04	9.08	49.50	2.77	17.52	10.25	1.07	85740.32
3	8.47	3.76	58.83	2.81	17.20	10.30	1.07	85800.33
4	8.16	9.78	54.82	2.91	16.93	10.47	1.07	84837.89
5	9.36	5.93	57.63	2.86	17.49	10.14	1.07	86760.26
6	11.29	5.96	51.72	3.43	16.07	10.55	1.06	87006.51
7	8.47	4.28	52.14	2.99	16.88	10.41	1.06	85183.23
8	7.40	5.18	52.94	2.34	18.12	10.01	1.07	87487.71
9	6.03	3.86	49.30	2.34	17.34	10.33	1.05	85598.50
10	4.56	10.16	49.90	2.69	16.13	10.60	1.07	83609.91
11	2.81	7.77	57.96	2.58	15.70	10.82	1.08	82050.01
12	5.10	9.58	56.82	3.02	15.49	11.04	1.07	81379.24
13	3.70	7.87	55.85	2.67	17.02	10.53	1.07	83463.14
14	7.90	5.05	51.52	3.09	15.88	10.62	1.07	83693.98
15	9.54	1.50	56.10	2.49	16.77	10.64	1.05	83163.84
16	6.61	1.63	62.44	2.05	17.15	11.01	1.06	79655.44
17	7.57	4.25	49.57	1.87	18.27	10.22	1.06	84846.95
18	2.06	2.63	50.36	2.00	17.67	10.59	1.07	82728.17
19	0.26	5.34	58.57	2.43	17.21	10.81	1.07	81529.08
20	1.03	4.02	53.69	2.20	17.72	10.17	1.07	85915.69
21	6.13	4.15	51.62	2.21	17.75	10.26	1.07	84837.09
22	7.26	7.00	56.94	1.48	19.14	9.95	1.07	86585.70
23	6.00	8.12	43.43	2.30	18.41	9.98	1.05	86712.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.13	5.79	53.45	2.50	17.27	10.42	1.06	84580.78
最大值	11.29	10.16	62.44	3.43	19.14	11.04	1.09	87487.71
發生時間	6	10	16	6	22	12		8
最小值	0.26	1.50	43.43	1.48	15.49	9.95	1.05	79655.44
發生時間	19	15	23	22	12	22		16
零點偏移(率)	-0.01 %	-0.10 %	-0.03 %	-0.01 %		0.02		-0.20 %
全幅偏移(率)	0.02 %	-0.09 %	-0.02 %	-0.06 %		-0.15		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.00	3.68	42.49	1.16	15.73	10.67	0.94	74442.06
1	6.05	5.23	50.14	1.21	16.43	10.97	0.93	75856.55
2	7.96	4.38	57.32	1.41	16.07	10.98	0.94	77969.83
3	7.86	5.11	47.94	1.23	17.99	9.88	0.94	83245.94
4	8.45	2.76	47.84	1.65	14.77	10.61	0.93	76824.21
5	7.41	6.10	43.46	1.54	15.80	10.45	0.94	77654.45
6	8.81	6.13	44.36	1.40	16.01	10.38	0.94	77356.13
7	6.52	11.32	41.03	1.65	14.60	10.90	0.91	74811.14
8	7.57	5.57	49.11	1.71	14.89	11.39	0.92	78806.49
9	7.55	6.55	50.63	1.62	15.62	11.40	0.93	80382.27
10	6.82	10.34	50.16	1.59	15.43	11.35	0.93	80814.44
11	6.49	12.96	46.54	2.07	14.35	11.51	0.90	79299.98
12	1.48	8.87	61.59	0.67	17.89	10.84	0.95	82639.78
13	1.83	9.07	42.83	1.11	15.22	11.28	0.94	79178.32
14	3.15	2.17	47.22	0.96	16.10	11.24	0.94	82015.93
15	2.47	2.49	50.32	1.55	15.03	11.68	0.95	77640.71
16	1.48	2.20	49.38	1.41	14.96	11.84	0.94	75491.33
17	1.98	4.68	42.56	1.06	15.63	10.91	0.92	75891.09
18	1.07	3.13	46.89	0.76	16.54	10.71	0.89	74661.95
19	3.12	5.65	46.49	0.90	16.88	10.57	0.91	80513.89
20	3.01	3.39	48.95	0.74	17.80	10.43	0.93	79108.30
21	2.33	5.51	44.01	1.19	15.60	10.83	0.90	72711.32
22	2.32	4.97	42.85	0.89	17.33	10.32	0.90	79997.16
23	3.64	3.42	52.32	1.20	16.49	10.95	0.91	77584.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.85	5.65	47.77	1.28	15.97	10.92	0.93	78120.75
最大值	8.81	12.96	61.59	2.07	17.99	11.84	0.97	83245.94
發生時間	6	11	12	11	3	16		3
最小值	1.07	2.17	41.03	0.67	14.35	9.88	0.89	72711.32
發生時間	18	14	7	12	11	3		21
零點偏移(率)	-0.04 %	-0.07 %	-0.01 %	-0.04 %		0.02		0.00 %
全幅偏移(率)	-0.51 %	0.03 %	0.25 %	0.03 %		0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								