

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月09日

報表日期: 114年10月09日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.45	13.74	69.52	3.30	14.53	12.15	1.22	76120.31
1	1.75	15.22	61.31	2.54	16.54	11.74	1.22	70948.25
2	0.38	10.87	60.96	2.52	15.81	11.44	1.20	77886.09
3	3.21	13.41	62.06	3.01	14.77	11.64	1.20	79930.18
4	8.05	15.62	41.88	3.21	16.17	11.65	1.21	79869.73
5	8.91	14.51	56.73	4.23	14.31	11.78	1.21	77632.48
6	8.49	15.10	47.98	2.95	15.30	11.85	1.21	78782.75
7	8.82	13.01	54.65	2.63	15.80	11.68	1.22	78713.32
8	8.77	12.30	65.08	2.68	16.16	11.66	1.21	81166.53
9	10.25	12.18	64.22	4.08	15.87	11.52	1.19	83009.78
10	10.98	13.06	62.99	5.84	15.18	11.80	1.18	79228.03
11	8.07	11.90	65.93	6.12	14.19	11.80	1.18	79677.60
12	9.29	12.67	59.28	5.89	13.77	12.37	1.18	74985.16
13	6.57	13.26	42.92	3.14	15.46	12.19	1.18	75363.45
14	7.59	12.99	44.31	4.09	14.70	12.04	1.18	77036.22
15	7.86	14.22	52.67	3.60	14.60	12.50	1.18	74700.79
16	6.25	12.43	50.79	3.13	14.77	12.12	1.18	79466.37
17	7.09	13.18	50.07	2.78	15.31	12.39	1.18	77000.52
18	8.80	12.49	57.54	2.26	16.16	12.00	1.19	77498.28
19	8.68	11.96	49.85	1.66	17.30	11.26	1.21	81780.76
20	10.19	11.29	51.97	2.28	16.78	10.97	1.23	84076.27
21	11.77	12.11	49.03	3.04	15.82	11.40	1.23	81518.57
22	10.30	13.78	44.47	3.44	15.16	11.62	1.23	79901.05
23	7.62	13.28	49.96	2.01	16.94	11.50	1.24	79732.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.76	13.11	54.84	3.35	15.48	11.79	1.20	78584.38
最 大 值	11.77	15.62	69.52	6.12	17.30	12.50	1.25	84076.27
發生時間	21	4	0	11	19	15		20
最 小 值	0.38	10.87	41.88	1.66	13.77	10.97	1.17	70948.25
發生時間	2	2	4	19	12	20		1
零點偏移(率)	-0.13 %	-0.03 %	-0.08 %	0.00 %		0.02		0.20 %
全幅偏移(率)	-0.08 %	-0.46 %	0.01 %	0.14 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月09日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.84	12.46	54.39	0.60	16.56	10.99	1.02	82160.46
1	2.74	12.12	53.54	0.74	17.80	10.59	1.01	83706.51
2	2.86	12.65	64.78	0.42	17.99	10.43	1.01	84979.94
3	2.22	12.41	53.86	0.95	15.76	11.01	1.01	81525.49
4	2.32	14.39	51.24	0.60	16.43	10.88	1.00	81724.55
5	2.20	14.52	43.87	0.51	16.76	10.76	1.01	82000.44
6	3.73	10.87	56.03	0.53	15.93	10.80	0.99	81657.11
7	2.80	12.81	41.85	0.63	16.31	11.02	0.99	80770.54
8	4.13	16.96	39.82	0.83	16.83	10.44	0.98	84371.22
9	4.16	11.92	40.61	0.60	16.83	10.82	0.98	77374.11
10	3.41	11.85	42.61	0.44	17.22	10.63	0.99	81326.55
11	4.18	12.39	42.37	0.39	16.92	10.83	0.98	78842.76
12	2.89	13.80	56.16	1.12	15.69	12.20	0.99	71282.42
13	2.31	12.66	44.54	0.75	16.13	11.18	0.97	78848.79
14	2.46	12.98	43.51	0.95	15.42	11.14	0.96	78948.21
15	2.81	12.32	43.65	0.70	16.30	11.07	0.97	80563.15
16	2.16	12.19	45.63	0.76	17.13	10.82	0.97	82168.39
17	2.43	12.64	56.67	0.39	18.16	10.32	0.98	85677.65
18	2.55	12.33	49.72	0.68	18.07	10.33	0.97	82200.90
19	2.29	12.20	49.28	0.35	18.38	9.60	0.96	83234.08
20	1.99	12.24	54.64	0.24	17.64	10.04	0.97	80110.14
21	2.33	11.98	53.20	0.22	18.32	9.61	0.97	81183.10
22	2.77	14.64	52.49	0.29	18.10	10.11	0.97	83287.43
23	2.61	13.17	44.36	0.33	18.20	10.29	0.97	82221.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.80	12.85	49.12	0.58	17.04	10.66	0.98	81256.89
最 大 值	4.18	16.96	64.78	1.12	18.38	12.20	1.03	85677.65
發生時間	11	8	2	12	19	12		17
最 小 值	1.99	10.87	39.82	0.22	15.42	9.60	0.95	71282.42
發生時間	20	6	8	21	14	19		12
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.01 %		-0.12		-0.10 %
全幅偏移(率)	0.28 %	0.43 %	0.14 %	-0.25 %		-0.33		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年10月09日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.96	12.26	45.88	0.60	16.42	9.49	1.43	75256.06
1	8.69	12.15	48.67	0.96	19.29	9.04	1.43	77872.89
2	7.85	10.61	55.50	1.03	18.26	9.11	1.43	79120.76
3	9.01	12.61	54.15	0.87	17.28	9.72	1.43	78034.34
4	10.11	13.30	61.03	1.07	16.86	9.98	1.43	78806.88
5	9.33	13.27	51.50	1.06	16.45	9.88	1.42	79535.14
6	6.30	13.03	57.07	0.84	16.59	9.77	1.44	78713.85
7	12.42	12.50	52.52	1.58	16.21	9.76	1.46	79383.68
8	9.99	11.59	57.56	1.38	16.57	9.66	1.46	79804.31
9	10.08	11.44	54.90	0.97	16.65	9.76	1.43	79337.88
10	13.31	14.37	53.82	2.06	15.80	9.73	1.45	82813.05
11	6.99	12.81	60.92	1.13	16.12	10.51	1.45	78603.12
12	5.20	11.93	56.35	0.79	15.94	10.52	1.40	78384.80
13	6.87	13.10	58.33	1.37	14.78	10.54	1.41	76044.17
14	7.19	11.66	61.41	0.81	17.09	9.98	1.39	78682.46
15	5.44	11.73	57.23	0.86	15.50	10.44	1.40	76404.76
16	10.57	12.67	57.41	0.99	15.76	10.46	1.44	80133.17
17	14.60	13.67	57.28	0.80	18.04	9.45	1.42	82852.39
18	7.26	12.23	55.04	0.79	18.26	9.12	1.40	78863.15
19	8.85	12.23	54.51	0.89	19.32	8.59	1.44	81257.17
20	8.04	13.90	52.76	1.01	18.38	8.61	1.43	79972.44
21	6.15	11.63	54.92	0.73	18.01	8.78	1.43	75068.23
22	9.79	12.66	63.48	0.98	17.23	9.41	1.43	79545.40
23	8.09	12.00	63.54	0.75	18.96	9.61	1.44	82599.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.63	12.47	56.07	1.01	17.07	9.66	1.43	79045.42
最 大 值	14.60	14.37	63.54	2.06	19.32	10.54	1.49	82852.39
發生時間	17	10	23	10	19	13		17
最 小 值	4.96	10.61	45.88	0.60	14.78	8.59	1.37	75068.23
發生時間	0	2	0	0	13	19		21
零點偏移(率)	-0.03 %	-0.01 %	-0.04 %	-0.01 %		-0.03		0.10 %
全幅偏移(率)	0.34 %	0.91 %	0.27 %	0.19 %		0.30		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								