

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.41	13.71	46.03	1.78	15.35	11.33	1.27	83949.68
1	9.03	12.34	46.81	2.09	15.40	11.25	1.27	84300.24
2	7.81	12.62	55.58	1.72	16.74	11.31	1.27	82786.97
3	9.65	12.35	56.33	2.43	14.85	11.32	1.28	84224.36
4	9.82	12.67	50.58	1.57	16.21	11.38	1.29	82310.07
5	5.84	12.69	39.24	1.49	15.03	11.21	1.29	84219.60
6	8.69	12.64	47.43	1.45	15.76	11.35	1.31	83354.60
7	10.05	12.62	54.43	2.55	15.25	11.29	1.32	84493.81
8	9.02	13.72	51.13	3.04	13.58	12.40	1.33	76810.46
9	9.50	13.33	51.01	2.51	14.23	11.71	1.34	81023.72
10	8.41	13.03	56.12	3.68	13.13	11.97	1.31	80696.49
11	6.36	13.49	41.02	3.26	12.94	12.27	1.29	75763.96
12	7.92	13.43	43.90	2.97	13.60	11.99	1.30	75860.70
13	10.83	15.14	39.34	3.09	14.22	11.59	1.33	78097.30
14	5.38	12.05	43.81	2.96	13.52	11.61	1.34	77012.56
15	7.43	11.96	41.80	3.45	13.19	11.83	1.34	76610.98
16	9.88	11.89	47.70	3.34	14.01	11.70	1.34	78477.30
17	9.76	12.21	48.39	3.55	13.04	11.80	1.33	80222.15
18	8.82	14.37	43.80	3.80	12.67	12.48	1.33	75288.67
19	5.84	13.93	45.41	3.09	13.05	12.92	1.34	71964.21
20	10.86	11.99	43.12	2.73	13.79	11.79	1.34	81311.39
21	8.99	12.27	41.41	2.39	13.82	12.10	1.34	78575.39
22	10.38	13.79	57.48	3.19	12.99	12.84	1.34	72431.49
23	9.73	12.88	52.74	3.54	12.20	12.74	1.34	74179.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.73	12.96	47.69	2.74	14.11	11.84	1.32	79331.92
最大值	10.86	15.14	57.48	3.80	16.74	12.92	1.35	84493.81
發生時間	20	13	22	18	2	19		7
最小值	5.38	11.89	39.24	1.45	12.20	11.21	1.26	71964.21
發生時間	14	16	5	6	23	5		19
零點偏移(率)	0.00 %	-0.01 %	-0.02 %	-0.04 %		-0.26	-0.01	0.20 %
全幅偏移(率)	2.07 %	0.37 %	1.26 %	0.29 %		0.27	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.56	11.91	47.65	1.78	15.40	10.62	0.99	77479.55
1	1.76	11.80	47.40	1.17	17.08	10.49	0.99	79014.98
2	1.61	11.68	45.36	1.57	15.66	10.55	0.99	78332.28
3	1.81	11.83	49.21	1.09	16.06	10.63	1.00	77811.39
4	1.54	12.18	51.24	1.38	15.02	10.66	1.02	77397.88
5	2.08	11.90	52.60	1.34	15.42	10.69	1.02	77529.93
6	2.70	11.30	50.35	1.18	15.36	10.65	1.01	78806.78
7	2.12	11.45	56.39	1.45	15.66	10.53	1.01	79895.36
8	2.42	11.51	57.55	1.09	15.37	10.62	1.02	79644.02
9	2.06	11.52	64.03	1.30	15.12	10.65	1.02	81198.15
10	2.25	12.10	47.88	1.00	14.34	11.27	1.02	78202.66
11	2.07	12.13	41.17	1.37	14.07	11.32	0.99	78008.36
12	1.32	11.91	47.93	0.94	15.60	10.90	1.01	75099.58
13	0.91	11.29	63.57	0.93	15.80	10.26	1.00	75511.19
14	1.31	11.09	49.02	1.19	15.64	10.02	1.00	76538.05
15	1.41	11.52	46.36	1.16	15.36	10.26	0.99	75630.50
16	1.35	11.08	52.90	1.11	15.70	10.00	0.99	77576.29
17	1.62	11.46	60.57	1.00	15.41	10.47	0.99	76956.22
18	7.13	11.58	60.06	0.93	16.36	10.44	1.00	78513.21
19	8.10	11.49	50.00	0.78	16.83	10.21	1.01	83202.03
20	5.18	11.77	43.97	1.24	15.15	10.72	1.02	78402.44
21	1.77	12.22	53.43	1.22	15.08	11.11	1.02	77959.10
22	2.45	12.30	53.05	1.20	14.66	11.21	1.02	79491.79
23	2.19	12.22	53.74	0.87	16.28	10.94	1.02	75296.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.45	11.72	51.89	1.18	15.52	10.63	1.01	78062.42
最大值	8.10	12.30	64.03	1.78	17.08	11.32	1.05	83202.03
發生時間	19	22	9	0	1	11		19
最小值	0.91	11.08	41.17	0.78	14.07	10.00	0.97	75099.58
發生時間	13	16	11	19	11	16		12
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	-0.01 %		-0.07	-0.01	0.10 %
全幅偏移(率)	-2.01 %	-0.81 %	0.58 %	-0.48 %		-0.04	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.46	11.87	30.59	1.66	17.20	8.71	1.47	74584.80
1	7.84	13.14	27.80	1.32	17.76	8.77	1.47	73806.23
2	9.09	11.22	26.86	2.15	18.19	8.60	1.46	74374.73
3	8.76	10.39	30.03	1.75	17.30	8.79	1.46	72888.79
4	9.35	11.19	25.99	2.84	17.61	8.19	1.45	74982.58
5	9.02	10.50	30.14	1.88	17.78	8.58	1.46	74020.77
6	9.00	10.32	38.51	1.89	16.94	9.01	1.48	75513.87
7	4.77	10.56	34.95	1.77	17.07	9.14	1.48	78013.51
8	6.94	14.17	26.61	2.57	18.83	8.26	1.47	73106.18
9	2.86	12.57	27.82	4.20	17.35	8.22	1.48	73691.09
10	5.85	11.74	33.01	1.85	16.44	8.46	1.45	71446.15
11	4.82	11.35	33.56	2.04	14.82	9.60	1.44	68016.31
12	7.26	11.27	36.83	1.99	16.98	9.34	1.44	68871.11
13	9.23	11.29	38.68	2.68	16.50	9.02	1.47	76058.47
14	7.40	11.14	36.21	1.98	16.28	9.20	1.46	72989.64
15	7.21	11.32	37.66	1.78	16.93	9.03	1.46	73406.98
16	5.67	10.93	44.55	1.61	17.16	9.38	1.47	73956.12
17	6.40	11.31	43.41	1.61	16.86	9.65	1.48	75532.46
18	6.47	11.27	40.51	1.63	16.13	9.76	1.48	75418.69
19	7.03	11.27	50.95	1.55	16.39	10.11	1.48	75250.11
20	9.20	11.69	44.74	1.78	16.23	10.09	1.48	76508.58
21	8.94	11.01	42.81	1.83	17.02	9.72	1.48	76848.29
22	9.12	11.59	43.51	2.18	15.27	10.34	1.48	75308.00
23	9.01	11.34	53.32	1.84	16.60	10.15	1.48	74812.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.49	11.44	36.63	2.02	16.90	9.17	1.47	74141.92
最大值	9.35	14.17	53.32	4.20	18.83	10.34	1.48	78013.51
發生時間	4	8	23	9	8	22		7
最小值	2.86	10.32	25.99	1.32	14.82	8.19	1.43	68016.31
發生時間	9	6	4	1	11	4		11
零點偏移(率)	-0.07 %	0.01 %	-0.03 %	-0.01 %		-0.05	-0.01	0.30 %
全幅偏移(率)	-1.02 %	-1.14 %	0.61 %	0.02 %		0.21	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								