

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.18	6.35	47.16	1.31	17.44	11.86	1.02	70929.60
1	1.56	6.24	53.44	0.81	19.65	11.27	1.00	73661.82
2	6.48	6.20	43.55	1.53	18.51	11.31	0.99	74645.27
3	8.97	9.56	39.98	2.37	17.53	11.31	0.99	75551.22
4	9.23	5.74	40.73	1.77	18.67	11.03	0.99	76642.08
5	3.93	7.97	43.84	1.26	17.54	11.83	0.99	72506.88
6	0.45	7.19	52.73	0.52	19.53	11.58	1.00	71756.32
7	0.35	6.22	42.12	0.48	19.83	10.72	1.00	77357.27
8	2.81	6.89	40.57	0.96	19.38	11.15	1.03	74905.96
9	4.20	7.70	41.68	1.81	17.49	11.72	1.03	71074.59
10	2.12	6.19	45.90	0.75	19.80	11.30	1.00	73414.38
11	3.09	6.33	42.67	0.77	19.61	11.03	1.02	75647.38
12	4.77	6.03	45.74	1.06	18.54	11.49	1.02	72402.85
13	5.10	6.36	38.38	1.08	19.53	10.80	1.03	76699.51
14	3.68	7.77	40.95	0.95	20.01	10.89	1.03	75432.29
15	6.19	8.38	36.44	1.36	17.94	11.49	1.03	72639.09
16	8.61	8.31	42.11	1.83	17.93	11.47	1.02	73353.61
17	7.78	15.13	40.60	1.57	18.07	11.26	1.00	74379.45
18	5.54	9.20	40.58	1.08	18.31	11.21	1.02	74621.10
19	4.62	6.78	37.97	1.75	16.94	11.59	1.03	73414.00
20	3.99	5.59	52.41	0.71	19.71	11.30	1.02	73836.22
21	4.26	6.33	44.28	1.01	18.39	11.52	1.00	72839.35
22	3.21	6.37	51.32	0.66	19.44	11.61	0.99	71017.40
23	0.47	9.07	53.92	0.51	19.10	11.92	0.99	69480.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.48	7.41	44.13	1.16	18.70	11.36	1.01	73675.33
最大值	9.23	15.13	53.92	2.37	20.01	11.92	1.05	77357.27
發生時間	4	17	23	3	14	23		7
最小值	0.35	5.59	36.44	0.48	16.94	10.72	0.99	69480.37
發生時間	7	20	15	7	19	7		23
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	0.00 %		-0.04		0.00 %
全幅偏移(率)	0.33 %	-0.43 %	-0.23 %	0.07 %		0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.61	6.09	41.19	0.94	19.40	10.01	0.99	85707.41
1	3.68	4.32	36.42	1.34	20.24	9.81	1.00	86455.97
2	4.71	5.77	49.80	1.53	17.63	10.24	1.00	86059.15
3	1.06	6.09	43.67	1.12	18.02	10.18	1.03	86031.83
4	0.09	4.59	50.93	2.16	17.32	10.38	1.02	85318.25
5	0.46	8.19	47.45	1.55	18.44	10.43	1.02	84196.65
6	0.12	5.86	56.94	0.99	19.41	10.78	1.00	83527.89
7	2.38	3.51	39.20	1.11	20.25	9.57	0.99	88208.49
8	3.88	8.07	39.10	1.91	17.97	10.06	0.99	86765.95
9	6.81	10.48	42.34	1.29	19.23	9.67	0.99	89255.94
10	5.63	8.56	44.52	1.75	17.31	10.33	0.99	85854.25
11	8.32	4.01	46.40	1.38	18.29	10.14	0.99	86240.75
12	7.95	10.63	47.38	1.56	17.64	10.35	1.00	84451.03
13	9.31	12.95	50.88	2.36	16.51	10.48	0.99	84993.25
14	9.48	4.39	53.68	1.35	18.37	10.11	0.99	86337.14
15	9.50	9.15	55.48	1.52	18.11	9.98	1.00	87232.53
16	9.39	6.54	51.52	2.16	16.35	10.48	0.99	85366.67
17	9.11	7.25	52.76	1.53	17.38	10.30	0.98	85444.31
18	8.26	7.47	50.67	1.12	18.03	10.17	0.98	86461.86
19	5.54	7.19	47.26	1.12	18.24	10.16	0.97	86002.12
20	4.25	7.17	48.93	0.95	18.08	10.32	0.98	85153.86
21	3.52	5.20	46.94	0.58	19.51	10.11	0.99	85223.52
22	4.33	4.18	56.49	1.07	18.42	10.23	0.99	84747.57
23	3.37	5.85	56.60	0.67	18.97	10.55	0.99	82003.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.28	6.81	48.19	1.38	18.30	10.20	0.99	85710.01
最大值	9.50	12.95	56.94	2.36	20.25	10.78	1.06	89255.94
發生時間	15	13	6	13	7	6		9
最小值	0.09	3.51	36.42	0.58	16.35	9.57	0.97	82003.97
發生時間	4	7	1	21	16	7		23
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	-0.07 %		0.01		-0.20 %
全幅偏移(率)	-0.37 %	0.26 %	-1.06 %	0.17 %		0.04		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.25	4.19	34.61	0.84	17.96	10.37	0.95	81699.58
1	2.35	3.75	34.56	0.59	18.85	10.67	0.94	77555.61
2	1.46	11.12	34.41	0.73	18.42	9.83	0.94	81194.61
3	2.27	8.35	30.53	3.58	15.76	10.24	0.92	76379.26
4	2.86	4.10	37.11	1.16	16.58	10.20	0.92	77474.36
5	4.28	5.50	39.67	1.52	15.72	10.49	0.92	74006.88
6	4.21	3.95	41.61	1.19	18.47	10.26	0.94	77906.46
7	3.78	2.67	42.78	1.22	16.53	10.61	0.97	77512.90
8	5.83	4.96	50.11	1.48	16.33	11.05	1.01	80604.20
9	4.49	3.54	49.99	1.39	15.88	11.32	0.96	78794.93
10	5.48	9.88	49.41	1.57	16.49	10.79	0.98	79935.27
11	5.47	5.86	48.70	1.35	16.07	11.03	0.99	80671.64
12	4.62	5.12	45.82	1.03	17.22	10.55	0.99	83133.95
13	6.32	8.30	45.60	1.29	16.15	10.60	0.99	79325.85
14	8.46	7.77	49.32	1.32	16.40	10.86	0.99	80116.33
15	8.80	6.08	44.99	1.19	16.98	10.82	0.99	81759.36
16	9.75	5.43	53.18	1.56	16.35	10.99	0.99	78902.39
17	8.68	5.82	45.98	1.26	15.77	10.92	0.95	76048.12
18	6.16	5.14	50.85	1.29	15.45	10.92	0.95	75720.09
19	2.84	5.12	46.02	1.30	14.96	10.94	0.97	74959.53
20	1.25	4.87	49.80	1.41	14.57	11.05	0.95	75086.41
21	2.67	4.49	53.14	1.40	15.11	11.15	0.93	74043.65
22	2.90	5.24	53.69	0.98	16.64	10.88	0.94	80201.25
23	1.62	5.85	56.60	0.94	16.02	11.32	0.94	74405.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.74	5.71	45.35	1.32	16.44	10.74	0.96	78226.57
最大值	9.75	11.12	56.60	3.58	18.85	11.32	1.02	83133.95
發生時間	16	2	23	3	1	9		12
最小值	1.25	2.67	30.53	0.59	14.57	9.83	0.91	74006.88
發生時間	20	7	3	1	20	2		5
零點偏移(率)	-0.04 %	-0.00 %	-0.07 %	-0.03 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.01 %	-0.21 %	0.23 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								