

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月31日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.34	10.06	50.57	2.27	14.34	12.10	1.20	68559.13
1	6.39	10.04	57.38	1.83	17.57	11.82	1.20	68515.72
2	8.53	9.78	52.13	2.40	15.40	11.78	1.20	70427.20
3	9.36	10.05	53.89	2.16	15.42	11.79	1.19	70181.03
4	8.80	10.90	50.51	3.03	13.16	12.07	1.19	67879.84
5	2.54	9.57	69.91	2.88	14.25	12.12	1.20	66994.97
6	6.88	9.20	53.34	2.15	15.16	12.01	1.21	69291.86
7	9.79	8.87	57.39	2.62	13.83	12.03	1.21	69106.93
8	8.62	8.63	51.74	2.90	13.68	12.12	1.22	69039.88
9	7.71	9.29	54.03	2.67	14.58	11.83	1.22	69547.01
10	9.42	9.45	55.30	2.88	14.00	12.00	1.20	66716.80
11	8.74	8.52	52.01	2.70	14.06	11.98	1.21	66005.80
12	8.58	8.47	56.22	2.46	14.37	12.09	1.20	65290.40
13	9.18	8.31	57.93	2.27	15.11	11.80	1.22	69121.90
14	9.27	8.54	47.90	2.26	15.18	11.97	1.20	68329.49
15	8.20	11.10	61.70	2.85	13.61	13.03	1.20	63700.61
16	8.13	13.98	60.13	1.75	16.80	11.52	1.20	71469.07
17	9.82	13.71	50.84	2.65	14.18	12.05	1.21	68660.85
18	8.09	14.16	51.81	1.85	15.64	12.00	1.23	68540.81
19	8.86	10.04	56.34	2.02	15.00	12.04	1.23	68478.44
20	6.96	11.23	57.71	2.06	15.85	11.51	1.21	71972.75
21	0.73	12.67	53.87	2.53	13.34	12.00	1.20	69661.14
22	0.12	9.57	57.02	1.92	14.67	12.04	1.20	65829.41
23	4.88	9.08	58.48	1.72	16.75	11.58	1.22	70868.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.33	10.22	55.34	2.37	14.83	11.97	1.21	68507.88
最 大 值	9.82	14.16	69.91	3.03	17.57	13.03	1.25	71972.75
發生時間	17	18	5	4	1	15		20
最 小 值	0.12	8.31	47.90	1.72	13.16	11.51	1.18	63700.61
發生時間	22	13	14	23	4	20		15
零點偏移(率)	-0.23 %	0.00 %	-0.03 %	-0.01 %		-0.02		0.10 %
全幅偏移(率)	0.00 %	-0.06 %	1.00 %	0.54 %		-0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月31日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.42	10.02	62.02	2.07	15.25	10.44	1.34	74578.33
1	6.66	10.19	65.00	2.22	17.98	10.44	1.35	74608.13
2	8.66	9.59	51.73	2.10	17.55	9.34	1.38	82079.98
3	8.70	9.96	57.42	2.02	15.82	10.13	1.40	76534.61
4	7.79	9.85	57.33	2.00	15.55	10.46	1.39	74943.89
5	9.31	10.85	58.84	2.12	15.40	10.26	1.38	76495.11
6	8.58	9.69	55.01	2.07	15.23	10.24	1.39	76429.67
7	9.35	8.30	54.88	4.08	15.52	10.20	1.38	75020.81
8	7.54	8.37	53.96	3.77	15.42	10.16	1.38	77368.16
9	3.56	9.22	52.39	3.41	15.57	10.07	1.35	77419.87
10	3.99	9.19	55.68	3.98	14.56	10.45	1.37	75170.11
11	4.33	8.77	57.78	3.87	15.09	10.47	1.39	76447.13
12	5.34	9.15	60.76	4.12	14.65	10.55	1.38	76211.98
13	5.89	8.88	58.46	3.97	14.84	10.42	1.39	76977.27
14	7.16	10.07	61.98	4.30	14.70	10.62	1.39	74429.82
15	3.41	9.50	61.77	4.18	13.89	11.68	1.36	71269.49
16	7.75	8.42	63.18	2.00	16.20	10.27	1.35	80203.46
17	8.68	8.87	64.29	1.96	15.88	10.50	1.34	79514.93
18	8.71	8.58	63.17	1.89	17.00	10.39	1.33	81190.68
19	8.02	8.87	61.99	1.98	14.91	10.60	1.33	78782.52
20	4.90	10.18	55.74	1.79	15.37	10.21	1.36	79100.35
21	2.51	10.15	54.77	1.87	14.90	10.27	1.39	74988.91
22	2.51	10.38	56.82	1.63	16.53	9.37	1.39	76728.47
23	4.25	9.25	57.20	1.72	16.78	9.81	1.37	76934.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.46	9.43	58.42	2.71	15.61	10.31	1.37	76809.50
最 大 值	9.35	10.85	65.00	4.30	17.98	11.68	1.43	82079.98
發生時間	7	5	1	14	1	15		2
最 小 值	2.51	8.30	51.73	1.63	13.89	9.34	1.33	71269.49
發生時間	21	7	2	22	15	2		15
零點偏移(率)	-0.01 %	0.00 %	-0.04 %	-0.03 %		-0.04		-0.10 %
全幅偏移(率)	0.02 %	-0.00 %	-0.16 %	0.13 %		0.30		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								