

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.13	10.96	60.51	0.98	18.61	11.33	1.07	79520.86
1	4.18	7.21	51.54	1.42	17.53	11.69	1.07	77322.71
2	4.36	7.84	56.27	1.89	17.20	11.96	1.07	75695.23
3	1.65	9.73	61.09	1.64	16.82	12.36	1.07	72973.45
4	0.10	7.33	65.55	0.63	18.65	11.53	1.07	78188.03
5	0.06	6.07	53.71	0.71	18.29	11.39	1.07	79255.20
6	1.53	9.08	55.12	1.40	17.46	11.52	1.07	79117.10
7	1.54	7.51	54.16	2.64	15.38	12.17	1.07	75123.24
8	4.06	15.60	51.95	2.25	16.34	11.99	1.07	76070.75
9	2.76	7.28	55.39	2.07	16.64	11.99	1.07	74744.56
10	9.15	2.12	57.86	2.02	17.90	11.54	1.05	75992.36
11	4.33	6.38	58.77	1.44	17.49	11.85	1.05	76119.02
12	2.29	8.94	57.63	1.04	18.13	11.82	1.05	75440.73
13	1.81	7.64	45.33	1.89	16.79	11.71	1.03	77576.02
14	3.25	5.85	73.78	1.23	18.29	11.95	1.05	74312.86
15	2.37	7.87	51.92	1.94	16.43	12.07	1.05	75412.88
16	2.09	6.81	49.58	2.21	17.16	11.86	1.03	75453.44
17	2.92	10.91	64.32	0.98	17.82	12.01	1.04	74226.43
18	4.76	11.27	53.68	1.26	17.43	11.87	1.04	76410.64
19	6.49	11.16	58.68	1.20	17.78	11.56	1.04	78459.71
20	9.63	12.24	47.02	1.75	17.29	11.41	1.05	79368.41
21	6.81	11.70	58.03	1.51	17.42	11.85	1.04	75953.45
22	8.56	11.81	55.25	1.68	18.53	11.76	1.03	76100.26
23	7.00	11.54	63.80	1.40	17.99	12.09	1.03	73597.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.08	8.95	56.71	1.55	17.47	11.80	1.05	76351.45
最大值	9.63	15.60	73.78	2.64	18.65	12.36	1.08	79520.86
發生時間	20	8	14	7	4	3		0
最小值	0.06	2.12	45.33	0.63	15.38	11.33	1.02	72973.45
發生時間	5	10	13	4	7	0		3
零點偏移(率)	-0.01 %	-0.02 %	-0.02 %	-0.01 %		-0.03		0.00 %
全幅偏移(率)	0.04 %	-0.21 %	-0.44 %	-0.09 %		-0.20		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.22	10.04	56.90	1.52	15.97	10.42	1.02	82247.73
1	0.46	10.95	48.63	2.09	17.50	10.67	1.00	80914.29
2	0.17	7.04	50.72	1.81	17.91	10.40	0.99	85048.70
3	2.52	10.13	53.99	2.40	16.69	10.42	1.00	84036.38
4	1.70	10.31	46.52	2.05	17.15	10.57	1.00	79647.27
5	1.16	9.08	52.52	1.98	17.01	10.51	0.99	83403.26
6	0.87	8.11	60.31	1.61	17.22	10.72	1.00	81411.59
7	1.68	8.44	53.52	1.54	17.56	10.27	1.02	83990.31
8	2.56	10.16	54.20	1.63	17.59	10.05	1.02	83993.74
9	2.81	7.13	57.57	2.42	16.29	10.58	1.03	85193.12
10	1.45	2.12	57.79	2.04	16.99	10.77	1.05	82221.27
11	0.79	8.74	49.93	1.23	18.46	9.94	1.03	84597.55
12	0.55	1.70	43.37	1.43	16.81	10.22	1.02	81171.57
13	0.10	2.07	45.27	1.87	16.04	10.77	1.02	82084.19
14	0.28	3.14	55.35	1.38	17.49	10.58	1.02	83168.98
15	0.53	4.73	54.10	1.87	16.76	10.77	1.02	82887.28
16	3.90	5.50	61.38	1.60	16.78	10.94	1.02	81292.73
17	4.02	5.07	56.73	1.44	17.45	10.69	1.03	81926.94
18	3.99	5.30	54.26	1.42	16.88	11.15	1.02	78648.16
19	3.77	7.06	54.98	0.91	20.17	9.77	1.02	88216.65
20	4.69	9.74	41.74	1.52	17.99	9.72	1.03	88202.21
21	8.45	6.66	49.53	1.43	18.61	9.79	1.03	87231.94
22	4.01	7.04	44.23	1.38	18.16	9.88	1.03	85558.47
23	0.84	7.17	57.07	0.80	19.22	10.13	1.04	85868.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.15	6.98	52.53	1.64	17.45	10.41	1.02	83456.80
最大值	8.45	10.95	61.38	2.42	20.17	11.15	1.05	88216.65
發生時間	21	1	16	9	19	18		19
最小值	0.10	1.70	41.74	0.80	15.97	9.72	0.99	78648.16
發生時間	13	12	20	23	0	20		18
零點偏移(率)	0.00 %	-0.01 %	-0.24 %	-0.07 %		-0.02		-0.20 %
全幅偏移(率)	0.04 %	-0.16 %	-0.08 %	0.09 %		-0.49		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.92	3.72	54.51	1.80	15.76	10.04	0.97	75539.41
1	4.58	2.76	46.00	1.89	16.11	10.03	0.97	74972.10
2	4.81	8.86	33.78	2.11	15.63	10.07	0.97	74879.77
3	9.15	5.82	28.94	2.72	15.70	9.92	0.95	76762.81
4	10.36	5.87	42.66	3.14	14.21	10.94	0.96	72737.98
5	0.16	6.05	56.35	1.22	16.75	11.24	1.00	73594.41
6	0.03	11.34	48.46	1.14	16.60	10.84	0.98	75975.41
7	0.00	6.01	51.68	0.73	18.16	10.92	1.00	76015.47
8	0.34	6.14	48.20	1.04	16.62	10.63	1.02	79430.61
9	8.69	9.76	50.20	2.07	17.00	10.31	1.02	81405.46
10	7.78	7.13	45.62	2.08	16.30	10.58	0.99	76069.61
11	2.56	8.34	49.64	1.28	16.05	10.78	0.99	73572.66
12	0.22	2.30	47.24	0.90	16.33	10.99	0.99	74227.56
13	0.08	2.26	50.98	1.44	15.26	11.30	0.99	74722.36
14	1.55	7.41	50.31	1.05	16.69	10.54	0.99	76729.63
15	3.24	7.32	47.24	0.81	17.08	10.70	0.99	75176.75
16	4.92	6.03	55.69	1.05	16.52	10.86	0.99	77405.45
17	5.18	4.95	50.99	0.83	17.12	10.76	0.99	78047.39
18	4.99	8.80	45.04	1.03	16.17	10.87	0.99	76570.57
19	5.06	9.89	55.89	0.86	17.06	11.25	1.01	77838.18
20	4.99	11.20	53.21	1.04	16.37	11.25	1.02	79476.02
21	5.14	8.54	56.77	1.17	16.66	10.82	1.02	82209.20
22	5.66	9.56	54.39	0.98	17.39	10.81	1.00	79985.93
23	1.22	10.73	56.74	1.12	17.29	10.68	1.01	80235.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.94	7.12	49.19	1.40	16.45	10.71	0.99	76815.86
最大值	10.36	11.34	56.77	3.14	18.16	11.30	1.04	82209.20
發生時間	4	6	21	4	7	13		21
最小值	0.00	2.26	28.94	0.73	14.21	9.92	0.94	72737.98
發生時間	7	13	3	7	4	3		4
零點偏移(率)	-0.07 %	0.00 %	-0.09 %	-0.06 %		-0.02		0.00 %
全幅偏移(率)	0.04 %	0.32 %	-0.71 %	0.15 %		0.00		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								