

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月07日

報表日期: 114年08月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.86	11.64	48.69	2.41	14.61	12.24	1.25	67998.52
1	10.11	10.50	46.01	2.53	16.04	11.86	1.25	69868.00
2	9.96	10.50	44.97	3.11	14.12	11.88	1.25	69083.15
3	7.87	10.06	44.12	2.95	13.57	12.23	1.25	67704.36
4	8.57	10.49	55.04	3.26	14.01	12.33	1.25	67818.18
5	7.79	5.88	64.09	3.36	14.36	12.03	1.22	67669.40
6	6.69	5.56	58.62	2.55	14.35	12.11	1.23	66650.45
7	9.41	6.68	62.40	2.54	14.35	11.79	1.26	70147.12
8	8.67	8.55	51.12	2.67	14.32	11.83	1.25	67922.63
9	9.35	8.46	63.74	2.43	14.50	11.84	1.25	70102.42
10	10.07	8.61	58.41	3.17	13.02	11.94	1.25	68240.73
11	7.25	11.45	56.71	2.69	13.24	12.04	1.24	66705.04
12	7.93	11.50	58.40	2.38	14.04	12.03	1.24	67884.11
13	9.63	11.23	55.92	2.58	14.33	11.95	1.25	68640.46
14	8.11	10.66	54.77	2.51	14.10	12.02	1.25	68280.34
15	5.67	10.51	64.61	2.21	14.36	12.31	1.25	66770.67
16	7.23	10.18	56.15	2.10	14.70	11.91	1.24	69726.17
17	8.99	10.14	57.46	2.38	14.93	11.76	1.25	70744.33
18	7.96	10.86	62.18	2.36	14.63	11.92	1.25	70571.76
19	9.03	10.23	48.37	2.12	15.79	11.70	1.25	70679.48
20	8.49	10.73	48.59	2.15	14.85	11.91	1.25	69177.99
21	4.11	11.62	60.76	1.74	14.94	12.29	1.24	67025.74
22	9.49	10.53	54.13	1.97	15.66	11.59	1.24	71407.29
23	7.12	8.97	56.44	2.86	16.25	11.96	1.25	68935.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.18	9.81	55.49	2.54	14.54	11.98	1.25	68739.73
最 大 值	10.11	11.64	64.61	3.36	16.25	12.33	1.27	71407.29
發生時間	1	0	15	5	23	4		22
最 小 值	4.11	5.56	44.12	1.74	13.02	11.59	1.20	66650.45
發生時間	21	6	3	21	10	22		6
零點偏移(率)	-0.05 %	-0.01 %	-0.27 %	-0.10 %		0.00		0.10 %
全幅偏移(率)	0.00 %	0.61 %	0.23 %	0.28 %		0.13		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月07日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.17	10.56	55.48	1.69	16.09	9.62	1.39	72717.71
1	5.83	10.44	61.59	2.91	18.08	9.57	1.39	73775.40
2	6.91	11.04	58.55	4.09	16.12	9.60	1.38	72667.29
3	3.06	11.13	54.88	1.82	15.74	9.63	1.38	72279.41
4	6.38	11.30	57.66	2.78	16.09	9.50	1.39	73062.64
5	3.00	10.80	55.43	1.78	16.96	9.13	1.41	73789.42
6	1.17	11.01	56.18	1.12	17.58	9.41	1.40	73917.63
7	9.27	5.22	60.28	2.16	18.22	9.42	1.45	79092.54
8	12.00	7.46	55.98	2.15	17.47	9.30	1.44	75120.87
9	9.92	6.46	57.01	3.41	16.82	9.80	1.45	75482.96
10	9.44	9.39	47.48	2.36	17.40	8.97	1.45	76022.23
11	9.66	8.34	51.60	1.83	16.91	9.27	1.41	74724.59
12	7.10	6.52	59.48	1.94	17.53	9.33	1.43	76109.86
13	5.43	6.88	61.71	1.53	17.90	9.67	1.46	74330.13
14	6.20	9.78	56.08	1.72	17.98	9.61	1.44	78708.78
15	3.24	9.46	57.49	1.48	17.13	9.87	1.45	75494.25
16	0.37	12.47	50.12	1.42	18.69	8.55	1.45	73190.30
17	0.00	8.86	48.32	1.23	19.12	8.14	1.43	72668.52
18	0.60	8.84	50.13	1.51	17.85	8.66	1.42	71501.09
19	0.43	13.82	51.02	4.56	17.98	8.87	1.39	76038.43
20	2.09	8.78	54.59	1.69	18.81	8.34	1.40	73133.26
21	5.99	11.60	44.87	3.11	20.31	7.81	1.44	80031.30
22	6.15	9.65	54.94	2.17	18.11	9.33	1.43	79133.35
23	7.79	8.02	63.14	1.14	16.94	10.21	1.41	76491.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.26	9.49	55.17	2.15	17.58	9.23	1.42	74978.46
最 大 值	12.00	13.82	63.14	4.56	20.31	10.21	1.48	80031.30
發生時間	8	19	23	19	21	23		21
最 小 值	0.00	5.22	44.87	1.12	15.74	7.81	1.38	71501.09
發生時間	17	7	21	6	3	21		18
零點偏移(率)	-0.07 %	0.00 %	-0.03 %	-0.01 %		-0.12		-0.10 %
全幅偏移(率)	0.02 %	-0.27 %	0.68 %	0.27 %		0.21		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								