

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.23	2.49	41.65	5.13	14.79	12.46	1.27	66793.78
1	8.62	3.33	57.97	4.42	16.57	12.01	1.28	68711.96
2	8.90	2.58	60.71	4.78	15.84	12.30	1.27	67955.93
3	8.38	3.55	55.15	5.32	14.66	12.51	1.27	67904.69
4	5.24	3.94	63.48	4.43	15.72	12.37	1.28	68073.44
5	10.05	3.74	45.77	5.56	14.43	12.55	1.28	71748.30
6	6.41	4.47	56.74	4.76	15.19	12.43	1.28	67895.44
7	9.78	2.28	60.48	4.44	16.14	12.16	1.28	69076.98
8	10.35	5.62	45.55	5.64	14.90	12.34	1.28	66394.40
9	8.71	4.51	58.91	4.60	15.54	12.41	1.28	67085.31
10	7.32	5.57	52.66	4.32	15.44	12.42	1.30	66607.37
11	8.44	6.65	59.79	5.76	13.61	13.11	1.32	62242.25
12	8.20	3.94	53.87	5.89	13.39	13.05	1.33	63337.07
13	9.46	6.46	56.79	6.43	13.62	12.88	1.33	63624.26
14	9.68	2.33	52.73	5.08	15.17	12.22	1.35	67899.79
15	7.29	1.62	61.31	5.61	15.10	12.61	1.33	65105.49
16	7.06	2.04	48.83	5.05	16.86	11.94	1.33	68922.93
17	6.72	3.90	59.83	4.25	15.38	12.60	1.34	64951.73
18	10.25	9.95	53.09	6.07	14.18	12.52	1.33	66692.17
19	4.68	8.33	57.47	5.36	13.88	12.92	1.33	64276.62
20	5.34	4.15	53.40	3.70	18.31	11.15	1.34	72936.62
21	9.61	2.75	39.92	5.14	15.13	12.23	1.33	65345.77
22	5.19	2.75	56.87	4.32	14.72	12.77	1.33	62652.44
23	3.82	1.64	61.36	3.44	16.99	11.88	1.33	69616.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.86	4.11	54.76	4.98	15.23	12.41	1.31	66910.47
最大值	10.35	9.95	63.48	6.43	18.31	13.11	1.38	72936.62
發生時間	8	18	4	13	20	11		20
最小值	3.82	1.62	39.92	3.44	13.39	11.15	1.26	62242.25
發生時間	23	15	21	23	12	20		11
零點偏移(率)	-0.10 %	-0.03 %	-0.04 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.02 %	0.01 %	0.00 %	0.02 %		0.05	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.38	1.62	63.41	1.34	20.90	9.47	1.45	89064.86
1	8.09	2.24	52.70	1.67	21.09	9.67	1.45	85049.71
2	10.27	2.17	53.00	2.47	19.34	9.55	1.44	88701.67
3	9.32	1.59	65.75	2.34	18.46	10.10	1.44	86602.60
4	8.94	1.90	46.68	2.64	18.34	9.84	1.44	85725.89
5	7.52	1.95	61.15	2.58	17.04	10.24	1.45	82463.52
6	10.36	2.11	46.73	2.96	17.98	9.85	1.44	86460.75
7	9.64	1.91	56.60	2.44	18.97	9.85	1.44	86192.86
8	7.56	2.30	53.38	2.25	17.95	10.02	1.43	84536.86
9	6.17	7.25	50.21	2.41	19.39	9.64	1.43	83139.80
10	11.08	3.66	49.47	7.70	16.24	10.16	1.45	80188.97
11	9.77	2.49	51.67	4.26	17.20	9.99	1.44	81344.37
12	3.62	3.64	54.20	1.68	19.96	9.62	1.43	80545.17
13	9.04	4.51	52.58	3.09	16.92	9.64	1.41	83807.54
14	6.47	4.82	51.13	2.21	19.61	9.37	1.41	82109.50
15	8.37	3.68	42.57	3.02	17.74	9.25	1.40	78779.74
16	10.17	4.17	41.44	2.69	19.50	8.89	1.41	81961.60
17	10.22	5.82	38.98	2.97	18.73	9.00	1.41	81138.51
18	12.39	3.67	53.10	2.32	20.33	9.07	1.42	82447.91
19	10.38	2.10	68.55	1.82	19.99	9.81	1.42	78763.21
20	9.91	2.56	51.46	1.93	20.15	9.21	1.42	88277.98
21	9.51	2.41	50.42	2.17	17.91	10.50	1.41	81533.00
22	7.76	2.12	60.08	1.87	19.23	10.30	1.40	77255.21
23	2.34	2.15	53.93	1.50	19.56	10.63	1.41	77643.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.64	3.04	52.88	2.60	18.86	9.74	1.43	83072.28
最大值	12.39	7.25	68.55	7.70	21.09	10.63	1.45	89064.86
發生時間	18	9	19	10	1	23		0
最小值	2.34	1.59	38.98	1.34	16.24	8.89	1.39	77255.21
發生時間	23	3	17	0	10	16		22
零點偏移(率)	-0.01 %	-0.01 %	-0.08 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	-0.03 %	-0.16 %	-0.03 %	0.04 %		0.09	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.54	2.14	61.00	3.05	16.11	10.76	1.36	83007.46
1	7.76	2.29	68.54	2.77	18.87	10.65	1.37	85252.73
2	9.90	2.65	60.38	2.97	17.10	10.65	1.36	83653.27
3	10.28	4.09	63.99	2.96	17.81	10.39	1.37	88674.75
4	8.93	4.69	61.67	2.89	16.48	10.69	1.38	86244.99
5	8.82	4.32	60.67	3.13	15.35	10.94	1.38	83421.59
6	6.63	3.88	59.73	3.05	15.58	10.88	1.36	80022.25
7	10.53	4.92	55.79	2.73	16.80	10.70	1.34	78856.27
8	10.04	4.12	58.70	2.80	16.04	10.79	1.35	82220.43
9	8.46	4.42	60.37	2.69	16.77	10.53	1.35	81782.42
10	9.16	4.53	56.60	2.73	16.70	10.59	1.36	82047.08
11	4.63	2.39	57.60	2.10	17.12	10.74	1.36	80576.97
12	3.58	2.23	65.05	2.37	16.43	11.03	1.34	77703.78
13	8.50	2.39	54.67	2.85	17.10	10.54	1.36	82639.40
14	10.46	3.20	63.44	3.02	16.16	10.55	1.38	82648.48
15	7.83	2.59	65.97	2.62	17.26	10.63	1.37	81605.25
16	6.98	3.96	55.64	2.50	16.43	10.54	1.36	80222.21
17	7.74	5.87	57.03	2.38	18.66	10.07	1.37	85376.09
18	8.85	3.26	65.82	2.65	18.68	10.17	1.37	84665.18
19	10.21	8.80	55.23	2.56	16.59	10.67	1.36	81551.97
20	10.26	4.31	58.36	2.60	18.32	10.20	1.37	84703.88
21	9.79	5.80	53.99	2.48	17.19	10.62	1.37	83888.76
22	9.59	2.55	69.13	2.76	18.30	10.61	1.36	83403.67
23	9.43	3.01	58.18	2.75	19.89	10.13	1.36	84295.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.66	3.85	60.31	2.73	17.16	10.59	1.36	82852.66
最大值	10.53	8.80	69.13	3.13	19.89	11.03	1.38	88674.75
發生時間	7	19	22	5	23	12		3
最小值	3.58	2.14	53.99	2.10	15.35	10.07	1.33	77703.78
發生時間	12	0	21	11	5	17		12
零點偏移(率)	-0.01 %	0.00 %	-0.15 %	-0.02 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.29 %	0.02 %	-0.10 %	0.21 %		-0.06	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								