

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月10日

報表日期: 113年03月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.40	6.55	54.32	0.77	16.37	11.71	1.02	80293.17
1	4.66	6.48	60.37	1.28	16.81	11.71	1.02	80528.92
2	5.55	6.42	52.75	1.49	16.42	11.49	1.02	82901.18
3	3.52	6.35	62.40	0.91	16.31	11.92	1.02	79156.33
4	2.50	7.35	55.45	2.04	15.13	12.09	1.02	79214.45
5	8.49	6.29	56.28	2.03	16.48	11.30	1.04	83389.38
6	7.63	6.46	53.12	2.38	15.46	11.63	1.04	82494.56
7	8.68	6.25	64.26	1.20	17.12	11.39	1.05	82799.71
8	5.20	7.11	46.43	1.44	16.12	11.34	1.06	83655.00
9	6.60	6.36	55.60	1.28	16.96	11.31	1.06	83764.16
10	6.40	6.59	60.95	1.23	16.23	11.82	1.06	79956.69
11	9.52	6.30	55.56	1.49	16.93	11.37	1.02	83856.91
12	10.03	6.76	51.19	1.00	18.16	10.85	1.02	86876.20
13	8.71	6.80	52.24	1.18	16.90	11.46	1.04	82409.88
14	8.86	6.85	49.35	0.78	18.21	11.08	1.06	84739.78
15	9.86	6.52	47.45	1.35	16.88	11.34	1.06	83927.56
16	8.52	7.06	44.77	1.96	15.73	11.81	1.06	80007.20
17	8.48	8.54	55.68	1.24	17.27	11.31	1.06	82582.84
18	8.10	8.52	52.45	1.12	17.47	11.30	1.04	81344.04
19	7.17	8.59	51.95	0.71	17.91	11.25	1.04	82915.71
20	8.61	8.70	54.20	0.86	18.07	11.49	1.03	81306.49
21	8.88	8.84	45.68	0.89	17.59	11.21	1.04	83269.32
22	7.15	9.43	58.83	0.82	17.68	11.86	1.05	77670.58
23	9.57	9.44	57.49	1.04	18.34	11.14	1.06	83784.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.34	7.27	54.12	1.27	16.94	11.47	1.04	82201.85
最 大 值	10.03	9.44	64.26	2.38	18.34	12.09	1.07	86876.20
發生時間	12	23	7	6	23	4		12
最 小 值	2.50	6.25	44.77	0.71	15.13	10.85	1.02	77670.58
發生時間	4	7	16	19	4	12		22
零點偏移(率)	-0.08 %	-0.04 %	-0.01 %	0.00 %		0.02		0.30 %
全幅偏移(率)	0.00 %	-0.69 %	-0.15 %	-0.13 %		0.27		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月10日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.11	4.36	54.47	2.95	14.85	11.40	1.02	79777.51
1	1.94	4.62	57.62	2.53	16.06	11.75	1.02	76185.55
2	2.59	3.98	55.41	2.15	15.40	11.47	1.02	78113.60
3	3.04	4.17	60.98	2.56	15.45	11.59	1.02	77398.13
4	7.61	3.92	55.65	2.42	15.97	11.29	1.03	80031.53
5	6.35	4.40	63.48	2.49	15.81	11.35	1.04	79498.05
6	5.14	3.96	46.68	2.19	16.49	11.09	1.06	78142.66
7	3.68	4.18	55.80	2.12	15.79	11.35	1.06	79597.24
8	5.90	5.00	54.50	3.70	14.03	11.54	1.06	79690.40
9	8.56	4.68	62.74	2.72	15.05	11.54	1.07	78425.33
10	9.12	4.39	51.03	3.25	15.55	11.25	1.06	79988.27
11	8.69	4.40	60.54	2.52	18.40	10.61	1.04	81963.08
12	7.81	4.24	51.65	2.79	16.98	11.05	1.05	80312.98
13	5.52	4.38	62.49	2.39	17.65	11.02	1.06	79607.49
14	5.87	4.86	39.85	2.15	18.78	10.51	1.07	82704.12
15	6.94	5.07	53.73	2.50	17.51	10.97	1.08	80419.67
16	6.00	4.27	54.05	2.92	16.19	11.28	1.06	79503.81
17	8.70	4.33	48.19	3.21	15.82	11.27	1.06	79549.41
18	9.80	4.55	47.19	3.91	14.24	11.67	1.06	77543.56
19	10.27	4.53	55.05	2.20	16.06	11.36	1.06	78045.39
20	8.83	4.26	47.28	2.27	15.43	11.28	1.06	79967.83
21	8.93	4.07	51.88	2.18	15.75	11.33	1.06	79364.71
22	10.00	4.13	51.51	2.03	15.45	11.33	1.07	79296.23
23	9.56	4.42	50.36	2.96	15.96	11.27	1.08	79457.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.87	4.38	53.84	2.63	16.03	11.27	1.05	79357.69
最 大 值	10.27	5.07	63.48	3.91	18.78	11.75	1.09	82704.12
發生時間	19	15	5	18	14	1		14
最 小 值	1.94	3.92	39.85	2.03	14.03	10.51	1.02	76185.55
發生時間	1	4	14	22	8	14		1
零點偏移(率)	-0.05 %	0.01 %	-0.02 %	-0.02 %		-0.01		0.10 %
全幅偏移(率)	0.24 %	-1.19 %	-0.95 %	0.10 %		-0.09		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月10日

[illegible]