

報表日期: 115年07月11日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	7.44	12.75	59.62	3.31	18.12	10.96	1.25	83246.19
1	8.21	11.71	66.60	2.18	19.89	11.14	1.25	80434.97
2	9.09	11.38	37.45	3.39	17.86	11.04	1.24	83275.82
3	10.24	12.14	50.37	2.35	15.76	11.57	1.25	80591.65
4	13.78	12.00	57.91	1.48	15.62	11.80	1.25	78671.71
5	11.79	12.51	54.44	2.47	14.69	12.15	1.23	74348.58
6	15.53	11.93	49.01	2.39	17.48	11.02	1.23	83413.40
7	6.96	11.81	48.46	2.37	16.87	11.30	1.23	81756.31
8	7.78	11.46	59.32	2.45	17.69	11.05	1.23	83010.23
9	9.82	12.87	62.48	2.77	18.40	11.11	1.24	81834.95
10	9.29	13.85	47.38	2.95	16.63	11.39	1.25	81178.73
11	11.88	13.33	55.73	3.33	16.20	11.74	1.25	78311.17
12	5.19	14.07	64.43	2.49	15.73	12.39	1.25	73809.61
13	9.40	13.70	49.22	2.94	16.82	11.75	1.25	78031.99
14	10.57	13.25	55.69	3.15	17.16	11.68	1.25	78162.52
15	6.57	13.66	56.75	3.24	17.87	10.96	1.25	83658.82
16	8.28	13.89	55.97	3.16	15.42	12.02	1.24	76592.87
17	11.64	13.15	60.73	2.84	16.36	11.68	1.22	78849.92
18	7.73	12.97	57.66	2.11	17.33	11.05	1.20	83524.84
19	8.57	12.68	60.87	2.25	17.18	11.24	1.22	82069.88
20	6.84	13.11	63.39	1.89	16.74	11.63	1.23	79130.90
21	8.44	12.21	59.27	2.18	19.75	10.43	1.23	86226.77
22	9.55	13.31	49.90	2.29	19.86	10.34	1.25	86560.99
23	11.44	12.69	59.40	2.90	18.44	10.76	1.25	84686.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.42	12.77	55.92	2.62	17.24	11.34	1.24	80890.79
最 大 值	15.53	14.07	66.60	3.39	19.89	12.39	1.25	86560.99
發生時間	6	12	1	2	1	12		22
最 小 值	5.19	11.38	37.45	1.48	14.69	10.34	1.20	73809.61
發生時間	12	2	2	4	5	22		12
零點偏移(率)	-0.09 %	0.00 %	-0.03 %	-0.00 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-1.01 %	1.18 %	-1.20 %	-0.08 %		-0.36	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月11日

報表日期: 115年07月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.22	11.80	55.46	1.69	17.00	10.64	1.31	75933.97
1	7.50	11.58	62.52	1.56	19.18	10.14	1.34	74881.00
2	6.75	11.55	55.91	1.60	19.43	10.03	1.35	74873.57
3	9.15	11.54	55.05	1.69	17.45	10.30	1.31	72414.42
4	5.43	12.61	50.51	2.64	17.33	10.13	1.31	73276.64
5	9.31	11.57	50.32	1.71	16.53	10.22	1.35	72747.84
6	8.13	11.31	60.52	1.58	17.25	10.14	1.36	73656.62
7	8.93	11.42	57.72	2.69	17.10	10.11	1.36	73414.35
8	8.49	11.10	57.06	2.94	17.87	9.59	1.36	76496.61
9	12.70	12.23	51.02	3.16	17.83	9.54	1.36	76505.87
10	6.32	12.50	47.98	2.59	18.91	9.20	1.34	79080.88
11	7.95	12.41	46.57	2.57	18.48	9.33	1.35	77380.38
12	6.21	12.45	49.52	2.40	17.72	9.96	1.36	73335.53
13	5.72	12.63	50.27	2.52	17.25	10.02	1.34	71956.54
14	9.50	12.25	47.96	3.02	18.01	9.66	1.31	73636.91
15	6.28	11.85	46.08	2.54	17.96	9.86	1.31	73438.57
16	6.21	11.28	47.59	2.40	18.50	9.68	1.31	74446.76
17	3.06	12.23	49.23	2.28	18.91	9.44	1.32	76845.37
18	9.13	11.32	67.25	3.33	17.55	9.99	1.36	81502.69
19	10.96	11.81	51.58	3.33	17.54	10.05	1.38	84189.17
20	3.94	11.74	68.65	3.43	17.80	10.34	1.39	82516.66
21	4.99	12.13	69.12	2.73	18.17	10.69	1.39	79972.36
22	4.61	11.60	49.97	2.65	19.39	9.99	1.35	82603.69
23	9.34	11.85	55.88	3.12	17.72	10.36	1.38	81573.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.41	11.87	54.32	2.51	17.95	9.98	1.35	76528.34
最 大 值	12.70	12.63	69.12	3.43	19.43	10.69	1.41	84189.17
發生時間	9	13	21	20	2	21		19
最 小 值	3.06	11.10	46.08	1.56	16.53	9.20	1.30	71956.54
發生時間	17	8	15	1	5	10		13
零點偏移(率)	-0.03 %	-0.00 %	-0.01 %	-0.08 %		-0.08	-0.01	-0.20 %
全幅偏移(率)	0.74 %	0.62 %	-0.43 %	-0.84 %		-0.04	0.04	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								