

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.94	12.91	54.55	1.42	17.80	10.88	1.23	86078.22
1	2.87	14.07	65.56	1.84	17.89	11.91	1.23	77464.84
2	2.63	13.94	41.18	1.82	17.56	11.26	1.23	83553.26
3	2.72	13.40	52.15	1.83	16.18	11.74	1.22	80729.62
4	2.78	13.71	42.96	2.61	15.28	11.83	1.20	80576.39
5	0.83	12.84	53.16	2.27	16.59	11.46	1.20	80780.68
6	3.65	13.02	39.41	3.05	15.68	11.43	1.20	83582.72
7	3.11	13.08	39.38	1.98	16.26	11.61	1.20	81384.19
8	6.55	12.23	62.15	1.58	16.96	11.85	1.22	78992.00
9	6.23	11.58	51.27	1.30	17.72	11.01	1.23	85417.66
10	6.35	11.67	48.87	2.16	15.58	11.33	1.23	84625.79
11	7.45	11.50	48.34	2.51	15.71	11.45	1.24	83412.52
12	6.86	11.95	58.54	1.58	16.31	11.78	1.23	80113.90
13	6.21	11.27	53.71	1.42	17.17	11.10	1.22	85370.88
14	6.67	12.04	43.04	2.33	15.12	11.77	1.22	81398.20
15	7.35	12.45	44.74	2.73	14.67	11.88	1.22	80307.97
16	8.68	11.57	43.42	2.80	15.94	11.26	1.23	85047.18
17	8.15	12.36	56.09	1.75	16.48	11.46	1.23	82582.71
18	7.39	12.37	59.39	1.97	16.01	11.47	1.24	82483.34
19	6.92	12.43	53.40	2.48	14.80	11.89	1.25	80055.98
20	7.05	12.47	59.59	2.09	15.67	12.07	1.25	78050.88
21	8.95	11.77	52.46	1.38	17.48	11.29	1.25	82784.23
22	10.64	11.86	42.88	1.59	16.78	11.04	1.25	85797.38
23	9.38	12.18	56.82	1.50	16.95	11.47	1.26	82168.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.89	12.44	50.96	2.00	16.36	11.51	1.23	82198.28
最 大 值	10.64	14.07	65.56	3.05	17.89	12.07	1.26	86078.22
發生時間	22	1	1	6	1	20		0
最 小 值	0.83	11.27	39.38	1.30	14.67	10.88	1.20	77464.84
發生時間	5	13	7	9	15	0		1
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.01 %		-0.05	-0.01	0.40 %
全幅偏移(率)	-0.63 %	0.50 %	-1.34 %	-1.09 %		0.05	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年12月26日

報表日期: 114年12月26日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.20	13.32	48.11	2.28	18.31	9.50	1.29	75895.10
1	12.26	14.27	48.75	1.95	19.14	9.73	1.29	75996.29
2	11.70	15.83	32.12	2.84	18.94	8.95	1.29	73210.98
3	12.46	15.55	33.41	3.11	18.58	8.80	1.27	75343.93
4	11.18	13.96	37.20	2.38	16.53	9.71	1.27	74929.06
5	12.06	13.39	40.89	2.43	16.59	9.76	1.27	74211.26
6	11.90	13.59	46.97	2.50	16.75	9.86	1.28	73671.34
7	6.32	11.39	49.20	1.90	17.64	9.84	1.29	72370.26
8	11.77	11.15	53.87	2.42	18.18	9.86	1.30	76033.03
9	12.31	11.39	45.19	1.91	16.59	10.27	1.31	75121.94
10	11.40	11.47	52.33	2.22	16.02	10.47	1.31	73276.97
11	12.18	11.53	55.99	2.55	15.88	10.56	1.31	74579.93
12	11.07	11.67	51.53	2.38	15.63	10.57	1.30	72213.45
13	11.81	11.55	57.17	2.26	16.25	10.53	1.31	74820.76
14	12.19	11.89	59.99	2.52	15.69	10.80	1.31	73612.81
15	11.66	12.47	62.36	2.34	15.91	11.04	1.31	74219.11
16	12.27	12.24	65.84	2.11	16.32	11.03	1.32	75203.48
17	11.81	12.05	44.62	2.30	15.79	10.50	1.32	76137.23
18	12.12	11.69	41.00	2.33	15.74	10.39	1.32	76196.79
19	12.16	13.00	44.87	3.10	15.23	10.51	1.31	74357.88
20	12.02	11.41	53.15	2.55	16.05	10.26	1.31	76657.92
21	11.44	12.24	52.12	2.62	15.33	10.41	1.31	74672.32
22	11.98	11.60	52.82	2.30	15.88	10.39	1.31	74847.18
23	12.86	11.44	48.13	2.22	16.89	9.91	1.31	77098.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.71	12.50	49.07	2.40	16.66	10.15	1.30	74778.22
最 大 值	12.86	15.83	65.84	3.11	19.14	11.04	1.35	77098.31
發生時間	23	2	16	3	1	15		23
最 小 值	6.32	11.15	32.12	1.90	15.23	8.80	1.27	72213.45
發生時間	7	8	2	7	19	3		12
零點偏移(率)	-0.08 %	0.01 %	-0.03 %	-0.01 %		-0.04	-0.01	0.30 %
全幅偏移(率)	-1.24 %	-0.46 %	0.71 %	-0.67 %		0.10	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								