

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月30日

報表日期: 114年09月30日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.18	12.55	58.79	1.91	15.86	11.85	1.25	78168.70
1	7.29	11.45	58.07	2.36	16.66	11.28	1.23	82313.10
2	9.78	12.21	54.50	2.46	15.89	11.61	1.23	79700.61
3	9.89	11.62	47.33	2.39	15.72	11.35	1.23	82382.85
4	9.36	11.22	53.17	2.49	16.16	11.10	1.25	84155.12
5	8.77	11.98	54.72	2.87	15.33	11.70	1.27	76972.67
6	10.86	11.82	64.19	2.93	15.30	11.61	1.28	80412.98
7	6.23	12.68	59.95	2.87	14.36	12.32	1.28	74833.43
8	6.55	12.51	67.59	2.29	16.05	11.96	1.28	76706.11
9	9.77	12.04	49.72	2.22	17.05	11.40	1.28	80558.23
10	10.98	12.22	49.72	2.66	15.57	11.50	1.26	80717.02
11	10.37	12.04	62.06	2.74	14.95	11.81	1.27	78240.19
12	10.47	11.85	60.37	2.79	14.76	11.70	1.27	79685.35
13	8.90	11.45	64.57	2.54	14.98	11.35	1.26	82307.17
14	12.06	11.71	65.30	2.95	14.00	11.65	1.26	80999.66
15	8.20	14.88	62.22	2.57	14.93	11.52	1.27	81591.78
16	10.23	11.41	56.52	2.55	15.44	11.23	1.27	82821.97
17	5.95	11.19	58.49	1.97	16.80	10.84	1.27	85378.66
18	8.04	11.20	57.32	2.41	15.61	10.94	1.26	84864.57
19	7.57	11.33	55.97	2.35	15.95	11.00	1.27	83708.71
20	9.66	11.32	58.14	2.33	16.68	10.98	1.27	84047.33
21	8.52	12.25	59.20	2.09	17.33	10.60	1.27	86443.15
22	10.66	14.31	51.02	2.96	14.83	10.95	1.26	80927.23
23	6.91	13.04	57.04	2.59	14.37	11.60	1.26	78286.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.88	12.09	57.75	2.51	15.61	11.41	1.26	81092.64
最 大 值	12.06	14.88	67.59	2.96	17.33	12.32	1.29	86443.15
發生時間	14	15	8	22	21	7		21
最 小 值	5.95	11.19	47.33	1.91	14.00	10.60	1.20	74833.43
發生時間	17	17	3	0	14	21		7
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.01 %		0.01		0.10 %
全幅偏移(率)	-0.32 %	0.51 %	-0.69 %	-0.11 %		0.27		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月30日

報表日期: 114年09月30日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.82	13.72	54.49	2.85	18.18	9.84	1.43	80760.56
1	7.68	13.13	51.61	3.18	18.83	9.49	1.43	83710.72
2	9.10	12.20	52.28	3.28	18.23	9.44	1.42	83068.99
3	9.20	12.37	52.79	3.14	17.52	9.82	1.42	80394.96
4	7.10	12.54	44.82	2.93	16.45	9.68	1.39	77215.05
5	11.22	13.22	48.60	3.20	17.35	9.50	1.39	79669.71
6	9.38	12.61	52.93	3.18	16.90	9.83	1.41	81261.82
7	8.90	11.77	53.70	2.70	16.22	10.41	1.41	78322.70
8	6.60	12.81	48.94	2.68	16.69	9.79	1.40	77964.20
9	10.82	11.71	52.93	2.98	16.16	10.17	1.39	80727.13
10	13.06	11.88	58.27	3.21	16.24	10.58	1.40	80350.57
11	7.67	11.88	56.37	2.84	15.61	10.72	1.40	78222.00
12	8.84	12.14	56.35	2.98	15.43	10.60	1.42	80805.87
13	6.52	11.98	54.63	3.14	14.72	10.73	1.35	77534.50
14	8.02	11.68	55.06	2.47	16.24	10.53	1.35	78341.37
15	8.91	13.49	49.66	2.76	15.34	10.53	1.38	77730.55
16	10.97	10.72	50.80	2.65	15.89	10.05	1.41	82456.14
17	10.08	10.12	51.45	2.49	16.80	9.92	1.41	81897.34
18	9.79	10.05	53.68	2.57	17.39	9.81	1.38	82961.74
19	5.93	11.18	47.73	2.23	16.87	9.74	1.36	83581.35
20	9.35	10.88	47.18	2.53	16.22	9.79	1.38	79803.50
21	9.03	10.27	44.31	2.12	16.75	9.61	1.41	78520.61
22	9.34	14.85	42.22	3.14	18.09	8.84	1.36	83440.83
23	9.65	12.89	46.92	0.67	16.48	9.92	1.35	77691.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.92	12.09	51.16	2.75	16.69	9.97	1.39	80268.07
最 大 值	13.06	14.85	58.27	3.28	18.83	10.73	1.44	83710.72
發生時間	10	22	10	2	1	13		1
最 小 值	5.93	10.05	42.22	0.67	14.72	8.84	1.34	77215.05
發生時間	19	18	22	23	13	22		4
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	0.01 %		-0.05		0.10 %
全幅偏移(率)	0.08 %	0.65 %	0.31 %	-0.30 %		0.25		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								