

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月04日

報表日期: 114年04月04日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.39	3.14	63.94	0.62	19.01	10.34	1.29	79382.92
1	4.65	2.65	62.25	0.81	19.77	10.02	1.30	85775.90
2	9.45	2.88	50.81	1.16	18.05	10.52	1.35	83815.94
3	9.42	2.63	54.27	0.63	18.31	10.55	1.32	83171.78
4	10.80	2.60	60.11	1.17	17.60	10.54	1.31	83871.64
5	9.39	5.10	54.22	1.41	17.47	10.68	1.29	88766.04
6	6.37	4.44	54.89	0.86	17.46	10.61	1.29	82943.93
7	8.35	4.62	60.34	0.68	18.48	10.67	1.32	80796.58
8	6.11	4.49	49.68	1.15	17.69	10.44	1.31	81543.60
9	6.12	4.19	59.08	0.79	18.61	10.50	1.30	79760.44
10	9.27	7.32	52.05	1.66	16.80	10.32	1.32	83360.52
11	8.47	4.79	51.82	1.90	16.19	10.76	1.31	81780.79
12	7.51	5.17	53.14	2.20	15.42	10.88	1.30	79510.72
13	7.30	8.09	53.79	2.25	15.58	10.72	1.31	79311.75
14	5.23	7.90	48.98	1.69	16.60	10.54	1.31	79162.04
15	5.15	3.31	48.06	1.14	16.95	10.58	1.29	79855.25
16	5.78	4.70	46.07	1.45	16.22	10.62	1.29	78357.90
17	5.73	7.30	43.68	1.66	16.29	10.47	1.31	78925.27
18	5.82	3.85	49.08	1.11	17.59	10.29	1.30	79170.13
19	4.57	7.20	48.05	1.48	16.37	10.73	1.29	77771.20
20	4.59	2.78	56.53	0.75	18.61	10.25	1.29	81869.12
21	4.34	2.80	54.50	0.74	18.70	10.30	1.28	79813.57
22	5.08	3.19	50.61	0.91	18.20	10.25	1.27	80816.85
23	5.45	3.35	51.43	0.49	18.66	10.24	1.27	80006.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.64	4.52	53.22	1.20	17.53	10.49	1.30	81230.86
最 大 值	10.80	8.09	63.94	2.25	19.77	10.88	1.38	88766.04
發生時間	4	13	0	13	1	12		5
最 小 值	4.34	2.60	43.68	0.49	15.42	10.02	1.27	77771.20
發生時間	21	4	17	23	12	1		19
零點偏移(率)	-0.11 %	-0.04 %	-0.02 %	0.00 %		0.00		0.20 %
全幅偏移(率)	0.00 %	-0.04 %	-0.31 %	0.18 %		0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.50	4.03	56.50	1.19	17.71	10.68	1.10	83459.71
1	9.59	5.07	55.51	2.04	18.66	10.06	1.10	88071.68
2	9.45	2.27	55.34	2.56	16.01	10.57	1.10	87052.97
3	8.54	2.06	60.38	2.28	16.38	10.52	1.10	87188.01
4	9.52	1.86	62.48	2.46	16.04	10.51	1.10	87599.74
5	8.69	2.55	57.46	2.57	15.88	10.55	1.10	86654.64
6	4.43	9.23	49.42	3.57	16.41	10.40	1.13	84922.81
7	6.06	4.17	58.30	2.05	17.16	10.43	1.15	86135.23
8	8.14	1.87	60.17	2.35	15.66	10.84	1.11	84554.13
9	8.70	5.34	57.72	2.40	16.55	10.55	1.12	85924.92
10	8.65	4.16	62.43	3.43	14.22	11.06	1.11	83512.44
11	8.98	1.98	62.43	3.10	14.23	11.02	1.10	83478.21
12	8.53	1.54	64.83	3.34	13.27	11.41	1.11	81523.10
13	8.51	1.40	54.04	2.87	15.44	11.00	1.11	83692.18
14	9.02	1.26	66.08	2.82	15.13	11.02	1.10	82949.38
15	8.91	1.64	58.72	2.82	15.67	10.94	1.11	83316.87
16	8.57	3.24	62.57	2.91	14.57	11.33	1.10	80562.97
17	9.64	3.34	56.63	2.45	16.32	10.86	1.10	82788.25
18	9.20	6.18	62.69	2.77	16.52	10.03	1.11	82306.88
19	9.01	2.38	62.22	2.00	16.76	10.39	1.11	84341.57
20	9.01	2.01	56.12	2.09	17.11	10.21	1.10	85534.80
21	9.26	1.89	53.63	2.35	15.70	10.43	1.10	82538.78
22	8.93	2.15	51.59	2.07	16.42	10.48	1.10	82353.44
23	8.91	3.73	46.73	1.85	17.19	10.15	1.10	82221.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.61	3.14	58.08	2.51	16.04	10.64	1.11	84278.51
最 大 值	9.64	9.23	66.08	3.57	18.66	11.41	1.17	88071.68
發生時間	17	6	14	6	1	12		1
最 小 值	4.43	1.26	46.73	1.19	13.27	10.03	1.10	80562.97
發生時間	6	14	23	0	12	18		16
零點偏移(率)	-0.06 %	-0.05 %	-0.03 %	-0.01 %		0.03		0.10 %
全幅偏移(率)	0.20 %	-0.44 %	0.08 %	0.26 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月04日

報表日期: 114年04月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.68	5.01	52.83	0.45	18.94	9.47	1.60	82099.53
1	0.18	8.73	44.59	3.30	21.11	8.84	1.60	86601.25
2	4.34	3.53	54.89	0.76	18.63	9.21	1.60	83426.62
3	8.26	7.37	45.57	0.99	16.43	9.63	1.60	82325.25
4	12.83	4.88	54.36	1.57	17.05	9.65	1.60	83713.42
5	0.63	4.09	53.73	0.57	15.86	9.92	1.60	80563.12
6	2.29	5.60	50.87	0.48	17.29	9.74	1.60	81479.94
7	4.85	5.91	56.49	0.72	17.88	9.79	1.57	87510.95
8	3.89	2.03	59.23	0.61	16.79	10.09	1.56	84557.93
9	2.62	2.14	62.12	0.51	17.49	10.66	1.56	76887.59
10	3.94	8.78	56.38	1.31	16.27	10.09	1.55	83909.77
11	2.54	1.87	57.95	1.24	15.14	10.40	1.53	81961.39
12	6.28	9.47	54.11	1.88	15.05	10.31	1.52	81841.95
13	5.26	6.49	52.48	0.89	16.55	10.07	1.53	82569.40
14	1.88	7.00	57.76	0.91	15.92	10.27	1.52	80971.66
15	2.90	4.35	53.56	0.76	17.03	10.14	1.52	81887.64
16	5.35	2.32	60.08	1.09	16.33	10.53	1.52	83381.66
17	2.42	4.54	59.90	1.18	15.55	10.47	1.54	82101.36
18	3.97	4.19	55.72	1.10	15.97	10.31	1.55	81259.10
19	3.15	2.94	52.62	0.69	16.88	10.32	1.52	81841.37
20	0.97	2.32	53.62	0.58	17.54	10.05	1.52	81754.38
21	5.88	3.38	51.42	0.91	16.80	10.00	1.53	81779.05
22	2.85	3.01	50.37	0.60	17.40	9.84	1.55	82423.70
23	2.80	6.09	49.23	0.58	17.18	9.88	1.53	82533.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.86	4.84	54.16	0.99	16.96	9.99	1.56	82474.22
最 大 值	12.83	9.47	62.12	3.30	21.11	10.66	1.60	87510.95
發生時間	4	12	9	1	1	9		7
最 小 值	0.18	1.87	44.59	0.45	15.05	8.84	1.52	76887.59
發生時間	1	11	1	0	12	1		9
零點偏移(率)	-0.09 %	-0.01 %	-0.03 %	-0.00 %		0.04		-0.10 %
全幅偏移(率)	-0.05 %	0.84 %	-0.44 %	0.01 %		0.44		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								