

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.12	8.76	46.06	2.84	17.17	11.04	1.07	81609.47
1	8.02	5.09	62.27	2.70	17.36	12.04	1.08	76209.70
2	8.35	4.13	58.37	2.31	18.89	10.99	1.07	84272.29
3	8.35	4.53	67.37	2.23	18.84	11.28	1.08	82261.43
4	9.11	4.02	54.06	2.24	19.34	10.68	1.07	86377.80
5	7.84	5.98	53.03	1.31	22.06	9.82	1.07	90139.67
6	8.94	5.22	54.27	2.79	17.05	11.79	1.07	78795.24
7	7.84	8.15	66.03	1.70	18.81	11.52	1.08	78978.63
8	7.65	7.70	60.85	1.87	18.12	11.32	1.05	81133.40
9	5.60	17.25	62.84	2.04	17.10	11.60	1.06	79802.69
10	9.20	13.96	62.60	1.81	17.86	11.26	1.07	81746.89
11	9.18	15.37	60.93	1.94	17.54	11.46	1.05	80062.33
12	9.38	15.12	56.59	2.36	16.78	11.58	1.07	79975.97
13	12.04	15.68	59.23	3.99	15.16	12.01	1.07	77914.29
14	8.57	7.72	55.83	3.25	16.86	11.83	1.07	74541.97
15	10.30	12.93	54.03	2.12	18.68	11.01	1.07	81999.62
16	10.01	16.60	46.26	2.63	16.57	11.48	1.07	79313.02
17	9.48	11.74	55.74	2.08	17.52	11.49	1.07	80124.04
18	9.63	10.84	56.92	1.78	18.42	11.29	1.06	81288.15
19	9.47	13.79	68.02	1.05	20.32	11.18	1.05	80984.91
20	9.96	12.43	61.25	1.46	19.57	11.05	1.05	82760.85
21	10.08	13.01	53.61	1.36	19.51	10.79	1.05	84323.35
22	9.76	14.17	44.20	2.37	17.26	11.26	1.05	79448.55
23	5.79	11.80	64.72	1.13	19.02	11.82	1.05	76285.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.90	10.67	57.71	2.14	18.16	11.32	1.07	80847.91
最大值	12.04	17.25	68.02	3.99	22.06	12.04	1.11	90139.67
發生時間	13	9	19	13	5	1		5
最小值	5.60	4.02	44.20	1.05	15.16	9.82	1.04	74541.97
發生時間	9	4	22	19	13	5		14
零點偏移(率)	-0.05 %	0.00 %	-0.02 %	0.00 %		0.03		0.00 %
全幅偏移(率)	0.04 %	0.25 %	0.55 %	-0.01 %		0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.81	4.25	56.45	1.87	18.58	10.32	1.19	79633.17
1	3.79	3.28	50.41	1.77	21.17	9.20	1.20	88289.20
2	7.05	3.20	37.63	2.34	19.01	9.87	1.19	84832.92
3	7.54	3.14	49.60	1.93	19.81	9.96	1.19	83629.56
4	3.98	7.14	41.92	1.51	20.66	9.77	1.20	84489.42
5	4.03	4.42	39.74	1.86	19.47	9.82	1.20	84461.38
6	1.60	14.54	36.18	1.40	22.03	8.62	1.20	92298.17
7	7.27	8.67	61.23	2.27	19.78	9.35	1.21	88265.16
8	7.53	9.31	47.07	1.65	20.72	9.43	1.23	86940.36
9	4.37	6.75	46.05	1.72	19.75	9.83	1.22	85070.63
10	8.16	12.88	49.00	1.88	19.66	9.46	1.21	87898.42
11	9.07	5.65	56.94	2.27	18.23	9.88	1.21	86851.56
12	10.37	6.58	55.52	2.62	18.47	9.83	1.23	85402.85
13	10.05	4.76	55.31	2.13	19.61	9.60	1.21	85433.45
14	7.14	9.41	50.99	1.96	18.80	10.38	1.22	80751.35
15	8.86	9.70	54.76	2.32	19.08	9.85	1.23	85779.26
16	8.59	7.46	49.56	1.87	18.60	10.07	1.22	83713.35
17	9.42	10.78	57.34	2.46	17.86	10.19	1.20	81446.36
18	4.47	5.86	56.86	1.68	18.75	10.43	1.19	77674.43
19	10.50	11.07	42.36	1.73	19.90	9.45	1.19	86928.47
20	13.81	9.89	58.78	3.37	16.86	10.48	1.20	82409.10
21	9.52	6.68	58.72	2.17	17.05	10.46	1.20	82000.84
22	8.81	7.91	52.44	1.63	19.43	10.25	1.20	82445.18
23	8.75	8.41	46.07	1.31	19.88	10.28	1.20	80232.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.56	7.57	50.46	1.99	19.30	9.87	1.21	84453.20
最大值	13.81	14.54	61.23	3.37	22.03	10.48	1.24	92298.17
發生時間	20	6	7	20	6	20		6
最小值	1.60	3.14	36.18	1.31	16.86	8.62	1.18	77674.43
發生時間	6	3	6	23	20	6		18
零點偏移(率)	-0.05 %	-0.07 %	-0.01 %	-0.09 %		0.03		-0.10 %
全幅偏移(率)	0.04 %	0.04 %	-0.16 %	-0.07 %		-0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.61	6.33	55.76	1.91	17.56	10.79	1.02	80315.78
1	0.22	4.19	60.78	2.21	17.00	11.39	1.02	75835.02
2	0.47	7.36	49.16	1.96	17.34	10.36	1.02	82217.67
3	0.51	4.86	49.67	2.11	17.21	10.33	1.02	82286.85
4	0.37	3.67	58.29	2.20	16.06	11.12	1.02	77403.71
5	0.37	4.82	51.19	2.22	16.32	10.65	1.01	81175.19
6	0.26	6.07	60.11	2.09	16.94	10.75	1.02	80884.83
7	0.13	3.51	58.94	1.35	16.99	11.55	1.03	81899.08
8	1.21	6.08	54.26	1.51	17.13	10.70	1.01	81991.31
9	0.55	9.44	56.12	1.58	16.30	10.91	1.04	80182.41
10	0.36	12.49	58.22	1.75	15.72	11.07	1.01	78555.18
11	0.86	22.55	55.95	1.51	16.82	10.64	1.04	79331.90
12	0.81	6.69	53.64	1.35	16.82	10.74	0.99	79842.73
13	0.47	11.21	52.20	1.34	17.38	10.80	0.99	77205.19
14	1.37	7.34	50.62	2.10	14.74	11.10	0.99	74786.17
15	1.73	8.90	50.34	1.50	16.84	10.64	1.03	78846.15
16	6.30	14.17	54.13	2.57	15.12	10.86	1.03	77642.30
17	5.71	11.56	50.51	1.97	15.37	10.90	1.00	74773.10
18	3.37	9.62	55.74	1.73	16.40	10.65	1.04	77778.26
19	2.69	13.45	47.56	1.51	17.57	10.21	1.03	81060.29
20	3.70	11.97	53.71	1.90	15.70	11.00	1.00	74801.97
21	4.59	10.74	56.94	1.53	16.77	10.78	0.99	77483.45
22	6.42	11.62	56.90	1.71	17.13	10.61	0.99	78289.49
23	2.38	9.13	53.50	1.35	16.98	10.69	0.99	76428.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	1.89	9.07	54.34	1.79	16.59	10.80	1.01	78792.37
最大值	6.42	22.55	60.78	2.57	17.57	11.55	1.05	82286.85
發生時間	22	11	1	16	19	7		3
最小值	0.13	3.51	47.56	1.34	14.74	10.21	0.97	74773.10
發生時間	7	7	19	13	14	19		17
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.05 %		0.02		0.00 %
全幅偏移(率)	0.50 %	0.06 %	-0.83 %	0.01 %		0.28		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								