

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月31日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 7.26 | 9.26 | 47.44 | 1.94 | 17.23 | 11.49 | 1.01 | 74531.93 |
| 1 | 5.54 | 13.60 | 55.46 | 1.92 | 18.07 | 11.40 | 1.01 | 74989.44 |
| 2 | 9.90 | 11.26 | 43.14 | 2.87 | 16.08 | 11.36 | 0.99 | 74434.72 |
| 3 | 7.52 | 7.81 | 58.48 | 1.71 | 17.94 | 11.19 | 1.00 | 76582.76 |
| 4 | 8.76 | 13.46 | 45.04 | 2.07 | 16.71 | 11.57 | 0.99 | 77100.29 |
| 5 | 6.72 | 8.64 | 55.43 | 1.11 | 18.55 | 11.40 | 1.02 | 76037.55 |
| 6 | 9.39 | 9.59 | 48.61 | 1.44 | 18.38 | 10.98 | 1.02 | 80867.92 |
| 7 | 5.92 | 8.46 | 44.47 | 1.76 | 16.71 | 11.35 | 1.03 | 74733.12 |
| 8 | 4.59 | 4.87 | 51.44 | 1.13 | 18.49 | 11.26 | 1.05 | 75540.36 |
| 9 | 4.20 | 6.24 | 60.08 | 0.92 | 17.88 | 11.25 | 1.03 | 80121.31 |
| 10 | 6.32 | 6.10 | 46.28 | 1.75 | 16.79 | 11.59 | 1.02 | 77810.34 |
| 11 | 8.52 | 7.23 | 47.51 | 1.53 | 18.48 | 10.93 | 1.02 | 80438.08 |
| 12 | 4.76 | 6.60 | 50.34 | 1.67 | 17.21 | 11.78 | 1.03 | 74006.07 |
| 13 | 5.13 | 6.17 | 58.03 | 1.01 | 18.67 | 11.65 | 1.03 | 76851.79 |
| 14 | 6.41 | 5.85 | 53.21 | 1.15 | 18.24 | 11.49 | 1.02 | 78508.52 |
| 15 | 2.96 | 6.08 | 61.01 | 1.10 | 17.69 | 11.84 | 1.03 | 76043.52 |
| 16 | 0.91 | 7.09 | 59.30 | 0.70 | 17.95 | 12.26 | 1.05 | 72301.21 |
| 17 | 2.58 | 7.67 | 42.50 | 1.01 | 16.94 | 11.65 | 1.05 | 77561.57 |
| 18 | 1.91 | 8.39 | 53.03 | 1.20 | 17.27 | 11.88 | 1.05 | 76043.39 |
| 19 | 1.05 | 7.89 | 65.89 | 0.58 | 19.06 | 11.85 | 1.03 | 74811.83 |
| 20 | 3.85 | 8.54 | 44.57 | 0.95 | 18.32 | 11.21 | 1.02 | 80208.01 |
| 21 | 8.36 | 8.17 | 59.79 | 1.37 | 18.87 | 11.37 | 1.02 | 78960.39 |
| 22 | 7.28 | 8.21 | 60.39 | 0.95 | 19.31 | 11.31 | 1.02 | 79229.48 |
| 23 | 7.42 | 9.21 | 52.12 | 1.35 | 18.31 | 11.48 | 1.01 | 78626.99 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 5.72 | 8.18 | 52.65 | 1.38 | 17.88 | 11.48 | 1.02 | 76930.86 |
| 最大值 | 9.90 | 13.60 | 65.89 | 2.87 | 19.31 | 12.26 | 1.06 | 80867.92 |
| 發生時間 | 2 | 1 | 19 | 2 | 22 | 16 | | 6 |
| 最小值 | 0.91 | 4.87 | 42.50 | 0.58 | 16.08 | 10.93 | 0.99 | 72301.21 |
| 發生時間 | 16 | 8 | 17 | 19 | 2 | 11 | | 16 |
| 零點偏移(率) | -0.12 % | -0.01 % | -0.08 % | -0.01 % | | -0.08 | | 0.00 % |
| 全幅偏移(率) | 0.12 % | 0.06 % | -0.01 % | 0.16 % | | -0.01 | | 0.30 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月31日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 7.94 | 7.93 | 58.20 | 2.67 | 16.70 | 10.62 | 1.02 | 82840.99 |
| 1 | 3.36 | 6.53 | 57.13 | 2.07 | 16.93 | 10.32 | 1.00 | 83529.40 |
| 2 | 3.86 | 8.00 | 65.67 | 1.68 | 15.90 | 10.94 | 1.00 | 78593.53 |
| 3 | 3.76 | 7.86 | 53.71 | 1.43 | 16.93 | 10.53 | 1.00 | 82852.42 |
| 4 | 5.45 | 8.28 | 58.69 | 1.63 | 17.43 | 10.46 | 1.01 | 84403.34 |
| 5 | 7.33 | 8.92 | 47.99 | 2.09 | 16.03 | 10.66 | 1.01 | 84125.24 |
| 6 | 8.89 | 5.80 | 58.70 | 2.19 | 15.49 | 11.05 | 0.98 | 79411.25 |
| 7 | 4.94 | 5.83 | 54.85 | 2.06 | 15.81 | 11.06 | 0.98 | 80619.55 |
| 8 | 5.36 | 3.98 | 58.38 | 1.44 | 17.88 | 10.06 | 0.98 | 85314.76 |
| 9 | 7.05 | 4.58 | 52.14 | 1.52 | 18.13 | 9.63 | 0.98 | 83985.13 |
| 10 | 6.44 | 4.39 | 60.51 | 1.94 | 16.54 | 10.04 | 0.99 | 82552.13 |
| 11 | 4.95 | 2.55 | 43.52 | 1.38 | 16.92 | 9.81 | 0.98 | 79867.78 |
| 12 | 7.35 | 4.89 | 51.18 | 1.64 | 16.98 | 9.84 | 0.98 | 80963.46 |
| 13 | 7.57 | 4.31 | 42.80 | 2.17 | 15.94 | 10.64 | 0.99 | 79188.65 |
| 14 | 6.27 | 4.55 | 50.70 | 1.59 | 17.65 | 10.62 | 0.99 | 82134.89 |
| 15 | 5.43 | 3.77 | 66.58 | 1.00 | 18.22 | 10.54 | 0.99 | 83697.50 |
| 16 | 5.96 | 4.92 | 56.59 | 2.30 | 16.16 | 10.91 | 0.98 | 82412.70 |
| 17 | 1.50 | 5.25 | 56.78 | 1.96 | 16.40 | 10.84 | 0.98 | 82893.29 |
| 18 | 5.35 | 4.83 | 59.76 | 2.64 | 16.24 | 10.86 | 0.98 | 83184.99 |
| 19 | 4.57 | 4.67 | 60.27 | 1.67 | 17.17 | 10.85 | 0.97 | 82166.81 |
| 20 | 7.63 | 5.00 | 53.08 | 1.91 | 17.64 | 10.51 | 0.97 | 84115.35 |
| 21 | 6.57 | 5.29 | 58.22 | 1.73 | 17.73 | 10.56 | 0.97 | 83627.15 |
| 22 | 6.16 | 5.88 | 57.19 | 2.15 | 16.95 | 10.81 | 0.97 | 82592.41 |
| 23 | 1.56 | 4.97 | 54.19 | 1.30 | 17.65 | 10.73 | 0.98 | 82722.31 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 5.64 | 5.54 | 55.70 | 1.84 | 16.89 | 10.54 | 0.99 | 82408.13 |
| 最大值 | 8.89 | 8.92 | 66.58 | 2.67 | 18.22 | 11.06 | 1.03 | 85314.76 |
| 發生時間 | 6 | 5 | 15 | 0 | 15 | 7 | | 8 |
| 最小值 | 1.50 | 2.55 | 42.80 | 1.00 | 15.49 | 9.63 | 0.97 | 78593.53 |
| 發生時間 | 17 | 11 | 13 | 15 | 6 | 9 | | 2 |
| 零點偏移(率) | -0.09 % | -0.02 % | -0.14 % | -0.01 % | | 0.00 | | -0.20 % |
| 全幅偏移(率) | 0.04 % | 0.25 % | 0.90 % | 0.08 % | | -0.33 | | -0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月31日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 2.18 | 9.05 | 51.59 | 1.61 | 16.64 | 10.59 | 0.94 | 77068.02 |
| 1 | 4.64 | 12.60 | 46.15 | 1.64 | 17.54 | 10.27 | 0.93 | 78939.73 |
| 2 | 5.25 | 8.37 | 54.23 | 2.70 | 14.37 | 10.68 | 0.94 | 76229.09 |
| 3 | 4.54 | 9.13 | 54.70 | 2.12 | 16.06 | 10.48 | 0.93 | 74076.06 |
| 4 | 6.61 | 7.84 | 66.50 | 2.88 | 16.11 | 9.71 | 0.92 | 77123.25 |
| 5 | 9.41 | 9.80 | 56.37 | 3.58 | 14.58 | 10.52 | 0.93 | 74413.70 |
| 6 | 8.84 | 9.09 | 49.65 | 3.43 | 13.85 | 10.94 | 0.93 | 71050.60 |
| 7 | 8.95 | 4.64 | 56.62 | 3.23 | 14.44 | 11.00 | 1.00 | 68845.56 |
| 8 | 4.24 | 21.49 | 51.28 | 6.45 | 16.36 | 9.97 | 0.97 | 74064.22 |
| 9 | 0.97 | 3.46 | 48.67 | 2.27 | 18.33 | 8.86 | 0.97 | 78470.99 |
| 10 | 5.84 | 1.70 | 61.51 | 2.83 | 16.89 | 9.51 | 0.98 | 74402.20 |
| 11 | 6.41 | 2.90 | 42.59 | 2.80 | 16.24 | 9.76 | 0.98 | 70378.98 |
| 12 | 4.01 | 6.77 | 55.27 | 2.95 | 15.39 | 9.91 | 0.98 | 70668.36 |
| 13 | 0.46 | 7.49 | 51.89 | 1.87 | 14.97 | 10.71 | 0.98 | 67849.28 |
| 14 | 1.82 | 2.81 | 49.36 | 1.31 | 17.35 | 10.08 | 0.96 | 73634.23 |
| 15 | 1.04 | 4.36 | 50.63 | 1.23 | 18.05 | 9.79 | 0.97 | 77061.82 |
| 16 | 2.11 | 2.05 | 54.89 | 1.89 | 15.32 | 10.53 | 0.99 | 75254.15 |
| 17 | 1.23 | 2.98 | 57.81 | 2.44 | 14.03 | 11.50 | 1.02 | 76086.21 |
| 18 | 2.11 | 7.83 | 52.28 | 1.75 | 16.01 | 10.75 | 1.00 | 80883.39 |
| 19 | 1.84 | 6.95 | 51.64 | 1.85 | 15.06 | 11.12 | 0.96 | 77922.40 |
| 20 | 2.07 | 8.09 | 56.48 | 1.58 | 16.22 | 11.12 | 0.97 | 80439.35 |
| 21 | 2.31 | 8.80 | 56.99 | 1.77 | 15.58 | 11.10 | 0.97 | 77000.71 |
| 22 | 2.68 | 6.21 | 49.69 | 1.81 | 15.75 | 11.11 | 0.97 | 78377.84 |
| 23 | 3.82 | 7.17 | 60.17 | 2.12 | 15.22 | 11.33 | 0.97 | 76894.45 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 3.89 | 7.15 | 53.62 | 2.42 | 15.85 | 10.47 | 0.96 | 75297.27 |
| 最大值 | 9.41 | 21.49 | 66.50 | 6.45 | 18.33 | 11.50 | 1.02 | 80883.39 |
| 發生時間 | 5 | 8 | 4 | 8 | 9 | 17 | | 18 |
| 最小值 | 0.46 | 1.70 | 42.59 | 1.23 | 13.85 | 8.86 | 0.91 | 67849.28 |
| 發生時間 | 13 | 10 | 11 | 15 | 6 | 9 | | 13 |
| 零點偏移(率) | -0.02 % | -0.03 % | -0.01 % | -0.05 % | | -0.01 | | 0.00 % |
| 全幅偏移(率) | -0.19 % | 0.17 % | -0.38 % | 0.16 % | | 0.19 | | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |