

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年02月15日

報表日期: 114年02月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.88	3.98	54.82	0.72	18.21	11.39	1.28	80621.06
1	7.40	3.40	59.43	0.55	20.80	10.70	1.29	85850.19
2	6.58	3.41	47.20	1.19	17.19	11.45	1.29	79788.77
3	7.26	2.04	58.99	1.12	17.47	11.83	1.29	79153.01
4	5.48	3.64	57.11	0.49	18.80	11.10	1.29	84555.42
5	7.63	3.29	56.90	1.06	18.68	10.90	1.29	88459.15
6	7.59	2.63	63.64	0.96	18.10	11.06	1.29	85349.49
7	9.32	2.97	55.66	1.36	17.05	11.53	1.29	81956.42
8	6.84	2.81	54.78	1.20	17.19	11.50	1.27	82071.48
9	9.01	3.05	54.23	0.92	18.17	11.09	1.26	83236.63
10	5.52	3.11	59.62	0.72	19.82	11.18	1.28	80989.61
11	5.93	3.34	55.14	0.75	18.84	11.05	1.24	84021.62
12	5.18	3.30	56.14	0.84	18.26	11.54	1.28	80846.69
13	8.37	3.58	49.48	1.50	16.76	11.62	1.29	81621.54
14	7.18	3.41	52.08	1.54	17.04	11.58	1.27	81392.04
15	9.61	3.03	54.63	1.41	16.77	11.70	1.27	80690.61
16	11.68	3.79	49.22	1.42	16.71	11.62	1.27	77970.99
17	9.37	3.04	59.24	0.94	18.02	11.51	1.25	81532.51
18	8.32	2.71	57.40	0.59	18.34	11.23	1.26	83826.53
19	7.36	2.79	52.36	1.30	17.70	11.32	1.25	83080.43
20	6.68	2.88	49.71	1.11	16.65	11.52	1.25	81193.70
21	7.04	4.13	61.92	0.82	18.01	11.75	1.24	79546.58
22	8.49	2.75	58.04	0.42	18.85	11.30	1.25	82921.82
23	8.99	3.21	56.32	0.65	19.43	11.07	1.24	83665.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.61	3.18	55.59	0.98	18.04	11.36	1.27	82264.22
最 大 值	11.68	4.13	63.64	1.54	20.80	11.83	1.31	88459.15
發生時間	16	21	6	14	1	3		5
最 小 值	5.18	2.04	47.20	0.42	16.65	10.70	1.23	77970.99
發生時間	12	3	2	22	20	1		16
零點偏移(率)	-0.02 %	-0.03 %	-0.01 %	-0.01 %		-0.14		0.20 %
全幅偏移(率)	0.00 %	0.82 %	-0.93 %	0.45 %		-0.28		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年02月15日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	14.75	3.55	57.90	2.44	15.07	11.56	1.10	80067.22
1	15.04	3.17	48.27	3.19	17.42	10.74	1.12	84388.64
2	12.19	2.28	52.89	3.09	17.68	10.37	1.14	86075.11
3	11.61	1.50	44.19	2.12	16.23	10.85	1.12	84202.11
4	11.06	2.72	48.94	1.82	15.94	11.15	1.11	81941.00
5	7.74	2.70	50.13	1.65	16.48	10.79	1.11	85066.71
6	10.69	2.16	44.93	2.77	15.30	11.36	1.12	81196.11
7	11.26	1.97	51.72	2.00	14.77	11.40	1.12	81145.89
8	10.10	3.16	57.43	2.38	14.03	11.59	1.14	80859.34
9	13.47	6.95	56.12	2.42	16.49	10.89	1.17	84317.07
10	6.09	4.78	54.03	1.69	16.34	10.86	1.16	84521.21
11	16.13	3.80	51.85	3.78	14.65	11.45	1.15	81427.57
12	10.90	5.79	47.15	4.16	15.18	11.46	1.16	79635.99
13	14.16	10.03	49.23	2.73	15.05	11.46	1.13	80720.73
14	15.25	4.05	48.28	3.78	13.80	11.60	1.14	80235.89
15	13.57	3.69	52.72	2.55	14.65	11.63	1.15	80284.22
16	14.23	3.70	53.10	2.24	14.34	11.70	1.11	79503.49
17	12.88	2.51	56.95	1.84	15.56	11.53	1.11	80148.00
18	12.98	2.64	54.34	2.63	15.52	11.19	1.15	83085.63
19	12.52	2.57	54.98	2.33	14.47	11.54	1.14	80809.55
20	13.85	3.57	52.27	1.88	14.98	11.32	1.13	81464.04
21	15.07	4.01	48.55	1.96	15.71	11.22	1.14	81430.31
22	14.47	2.83	50.97	2.65	15.94	11.27	1.15	80937.68
23	13.49	3.97	55.06	2.77	16.56	11.02	1.15	83130.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.65	3.67	51.75	2.54	15.51	11.25	1.13	81941.40
最 大 值	16.13	10.03	57.90	4.16	17.68	11.70	1.18	86075.11
發生時間	11	13	0	12	2	16		2
最 小 值	6.09	1.50	44.19	1.65	13.80	10.37	1.10	79503.49
發生時間	10	3	3	5	14	2		16
零點偏移(率)	-0.12 %	-0.11 %	-0.05 %	-0.02 %		-0.11		0.10 %
全幅偏移(率)	1.03 %	1.18 %	-1.01 %	0.22 %		-0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

