

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月04日

報表日期: 114年08月04日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.69	9.77	28.95	2.52	17.75	10.51	0.98	82604.44
1	0.95	9.27	42.44	1.99	17.66	10.82	0.98	80734.99
2	2.92	10.50	41.81	1.73	17.35	10.50	0.97	80694.85
3	15.56	8.87	50.64	3.67	16.43	10.81	0.97	82720.83
4	2.55	7.84	54.84	2.26	17.76	10.96	0.97	80103.25
5	2.72	7.43	57.70	2.22	18.15	10.53	0.97	85148.11
6	13.74	5.45	60.40	3.62	17.03	11.02	0.94	83244.11
7	5.64	5.59	57.75	3.21	16.57	11.46	0.96	81831.45
8	7.81	5.58	46.77	4.10	15.05	11.54	0.97	82316.09
9	7.95	5.45	46.51	3.76	15.74	11.27	0.97	83174.59
10	7.09	6.17	54.99	3.85	16.03	11.21	0.96	82946.83
11	4.68	5.26	59.65	2.20	16.91	10.94	0.97	79481.43
12	3.09	9.71	52.12	2.62	16.24	10.74	0.97	77030.36
13	1.82	10.30	53.00	1.81	17.04	10.97	0.94	74914.09
14	0.22	9.63	50.22	1.42	18.81	9.98	0.96	79263.12
15	0.58	10.42	40.46	1.50	18.26	10.21	0.94	78030.97
16	1.77	10.34	42.99	2.05	17.24	9.99	0.96	78921.56
17	4.14	9.66	49.54	1.51	17.57	10.17	0.97	79903.13
18	5.70	9.87	48.06	1.75	17.04	9.99	0.97	80749.35
19	1.51	8.39	46.43	1.19	18.24	9.60	0.94	79027.87
20	2.32	10.42	47.34	2.09	16.51	10.05	0.96	77763.22
21	7.65	8.36	48.09	1.92	17.71	9.86	0.97	79742.50
22	8.55	8.90	49.96	1.94	17.75	10.00	0.96	81017.97
23	6.34	8.61	59.46	1.40	18.18	10.37	0.97	79219.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.96	8.41	49.59	2.35	17.21	10.56	0.96	80441.03
最 大 值	15.56	10.50	60.40	4.10	18.81	11.54	0.99	85148.11
發生時間	3	2	6	8	14	8		5
最 小 值	0.22	5.26	28.95	1.19	15.05	9.60	0.93	74914.09
發生時間	14	11	0	19	8	19		13
零點偏移(率)	-0.06 %	-0.01 %	-0.04 %	-0.03 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	0.28 %	-0.46 %	0.17 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.10	10.63	59.25	2.31	18.59	8.70	1.43	77093.65
1	0.42	10.57	48.98	1.53	18.55	8.82	1.44	75795.30
2	0.59	7.51	56.22	1.66	18.72	8.83	1.48	76604.51
3	0.77	8.17	54.87	1.53	16.86	9.04	1.48	75963.49
4	2.42	8.14	57.41	1.49	17.60	9.11	1.48	74069.52
5	3.84	9.30	53.32	1.51	18.19	8.75	1.48	79322.57
6	3.38	7.38	54.96	1.45	17.48	9.14	1.49	78105.51
7	6.17	5.18	67.70	1.65	18.93	9.78	1.48	74534.66
8	0.03	5.62	64.93	1.67	17.57	10.46	1.45	82721.78
9	6.62	5.37	60.80	2.35	16.05	11.02	1.46	80809.15
10	5.43	5.76	62.55	2.20	17.08	10.65	1.44	79972.81
11	1.36	7.04	54.45	1.76	16.51	10.53	1.47	77073.66
12	3.56	5.27	58.99	2.08	16.41	10.82	1.48	80213.25
13	6.57	5.39	60.63	2.09	16.36	10.90	1.47	78942.73
14	5.62	8.16	62.92	2.20	16.70	10.97	1.46	78755.74
15	5.94	10.28	61.81	2.14	16.35	10.92	1.43	77540.85
16	3.64	9.91	56.48	1.81	16.88	10.44	1.42	80580.48
17	4.67	9.68	58.10	1.81	16.86	10.29	1.42	79567.27
18	4.98	10.30	52.11	1.69	17.22	10.01	1.43	80642.02
19	1.67	8.14	52.26	1.53	18.78	8.72	1.45	74804.53
20	2.10	7.78	55.75	1.63	20.03	8.46	1.46	76751.63
21	2.58	9.08	52.91	1.54	18.87	8.42	1.43	75448.97
22	3.28	8.57	60.82	1.69	17.84	8.67	1.43	75055.22
23	3.21	8.90	62.45	1.83	18.41	9.55	1.43	72888.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.41	8.01	57.94	1.80	17.62	9.71	1.45	77635.75
最 大 值	6.62	10.63	67.70	2.35	20.03	11.02	1.51	82721.78
發生時間	9	0	7	9	20	9		8
最 小 值	0.03	5.18	48.98	1.45	16.05	8.42	1.41	72888.75
發生時間	8	7	1	6	9	21		23
零點偏移(率)	-0.08 %	-0.02 %	-0.03 %	0.00 %		-0.17		-0.10 %
全幅偏移(率)	0.02 %	0.34 %	0.39 %	0.21 %		0.15		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								