

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.43	4.31	48.90	2.04	14.70	11.87	1.05	79418.15
1	6.54	5.32	65.36	1.68	16.03	12.84	1.08	71448.62
2	4.00	5.60	41.04	1.43	16.14	11.84	1.07	80775.21
3	7.45	6.66	49.14	3.04	14.03	11.90	1.04	80958.00
4	8.16	6.21	61.69	1.70	16.02	11.44	1.05	81483.40
5	8.21	9.87	54.52	1.62	17.24	11.19	1.05	78581.46
6	8.50	6.75	67.78	0.99	18.26	10.92	1.04	84211.51
7	10.33	8.24	48.71	2.34	15.99	11.21	1.04	82918.07
8	10.36	3.02	44.61	1.99	16.87	11.36	1.04	79644.91
9	9.58	3.19	57.67	1.04	17.29	11.63	1.06	78616.85
10	9.96	3.49	48.00	1.58	16.48	11.53	1.09	82408.76
11	10.01	2.73	47.07	1.27	17.15	11.29	1.07	84098.04
12	9.87	2.89	42.28	2.23	15.19	11.63	1.04	81137.25
13	7.32	2.66	49.21	1.93	15.31	11.78	1.05	79660.47
14	6.21	5.35	60.02	1.35	17.24	11.72	1.06	80239.05
15	9.22	7.65	53.07	2.15	15.84	11.53	1.08	81208.97
16	9.97	9.78	58.77	1.81	16.50	11.50	1.05	82228.36
17	10.41	4.38	56.69	1.60	16.44	11.37	1.04	83479.08
18	12.13	4.55	60.75	1.75	16.41	11.29	1.04	83457.48
19	11.90	4.64	51.50	2.15	15.84	11.39	1.04	81599.38
20	10.89	4.44	56.38	1.85	16.45	11.21	1.04	81804.98
21	9.76	5.23	59.53	1.16	16.66	12.03	1.04	75766.67
22	9.24	7.52	52.47	1.45	16.29	12.28	1.07	76077.27
23	6.40	8.49	57.13	0.98	16.29	12.74	1.09	71196.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.99	5.54	53.85	1.71	16.28	11.65	1.06	80100.77
最 大 值	12.13	9.87	67.78	3.04	18.26	12.84	1.15	84211.51
發生時間	18	5	6	3	6	1		6
最 小 值	4.00	2.66	41.04	0.98	14.03	10.92	1.03	71196.54
發生時間	2	13	2	23	3	6		23
零點偏移(率)	-0.07 %	-0.15 %	-0.01 %	-0.03 %		0.00		0.10 %
全幅偏移(率)	0.00 %	-0.25 %	-0.02 %	0.01 %		0.10		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月15日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	4.75	6.36	42.81	1.77	16.75	11.12	1.02	80116.31
1	5.67	5.82	52.38	2.46	15.78	11.46	1.02	77681.25
2	7.35	7.07	52.36	3.19	14.82	11.63	1.03	78132.51
3	4.17	5.59	51.60	2.41	16.22	11.21	1.06	79678.80
4	7.21	6.02	49.09	3.27	15.51	10.96	1.06	82309.93
5	5.86	8.27	56.78	3.12	16.15	10.81	1.04	83241.59
6	8.48	6.40	46.50	2.84	16.20	10.81	1.06	82321.23
7	9.20	7.76	56.25	3.30	14.66	11.28	1.06	79722.69
8	9.81	3.74	52.07	2.56	15.59	11.20	1.06	80842.00
9	7.93	5.41	48.44	2.99	14.46	11.52	1.06	78854.34
10	5.58	6.94	50.88	2.74	13.84	11.75	1.04	76769.35
11	5.44	2.65	49.99	2.76	14.38	11.58	1.02	77784.78
12	4.27	2.48	54.09	3.22	14.04	11.51	1.03	78846.36
13	4.92	3.26	58.14	3.43	13.54	11.96	1.05	75804.58
14	9.28	4.86	53.88	3.22	14.01	11.88	1.03	76072.02
15	10.32	2.85	54.62	2.50	14.34	11.69	1.03	76941.60
16	5.09	2.83	55.05	3.13	13.92	11.78	1.04	76291.63
17	1.81	4.54	58.75	2.53	14.81	11.61	1.05	77833.23
18	2.63	3.06	54.76	2.66	14.67	11.57	1.04	78213.63
19	5.44	3.93	52.40	3.48	13.07	11.82	1.04	76339.58
20	11.83	5.54	48.85	3.57	13.11	11.64	1.04	75714.14
21	8.84	2.25	47.85	2.80	14.96	11.66	1.03	77094.91
22	8.17	2.60	55.29	1.97	16.06	11.39	1.02	77797.14
23	2.55	2.90	55.58	1.72	15.90	11.63	1.04	76017.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.53	4.71	52.43	2.82	14.87	11.48	1.04	78350.87
最 大 值	11.83	8.27	58.75	3.57	16.75	11.96	1.06	83241.59
發生時間	20	5	17	20	0	13		5
最 小 值	1.81	2.25	42.81	1.72	13.07	10.81	1.02	75714.14
發生時間	17	21	0	23	19	5		20
零點偏移(率)	-0.08 %	-0.06 %	-0.03 %	-0.01 %		-0.02		-0.20 %
全幅偏移(率)	-0.77 %	0.29 %	-0.51 %	0.13 %		-0.26		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月15日

[illegible]