

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.30	12.68	53.59	1.25	16.08	11.13	1.28	84303.47
1	9.39	12.57	50.08	2.22	14.92	11.32	1.29	82906.68
2	10.39	12.87	44.70	1.55	15.61	11.52	1.27	80769.87
3	9.07	12.62	45.98	1.70	14.98	11.45	1.25	82860.35
4	9.88	13.13	46.71	1.84	14.37	11.93	1.27	79236.40
5	8.84	12.87	47.27	2.02	13.23	11.90	1.28	82226.78
6	9.20	12.94	44.19	1.52	13.96	11.91	1.29	79561.11
7	9.56	12.44	53.12	1.15	15.07	11.41	1.29	82736.76
8	10.48	12.67	53.16	1.58	13.61	11.77	1.29	80825.22
9	9.90	13.21	49.29	1.30	14.37	12.01	1.29	78406.63
10	12.01	12.64	51.83	1.55	14.55	11.43	1.28	83418.38
11	8.88	13.24	51.86	1.14	14.19	12.05	1.26	78060.60
12	9.16	12.86	45.16	0.92	14.90	11.74	1.28	80604.32
13	9.58	12.65	39.40	1.21	14.29	11.67	1.29	81166.73
14	8.46	13.46	44.00	1.34	14.19	12.17	1.29	76634.61
15	9.49	13.13	48.43	1.60	13.58	12.08	1.29	78141.54
16	9.58	12.35	47.55	2.42	13.92	11.84	1.29	80530.47
17	9.33	11.68	56.94	2.39	14.61	11.60	1.29	82144.84
18	8.78	11.85	55.98	2.66	13.93	11.85	1.28	80929.78
19	9.54	11.88	41.06	2.68	14.23	11.83	1.27	80670.13
20	9.06	12.84	44.05	3.00	13.94	12.06	1.26	79146.87
21	3.92	13.17	51.41	2.98	13.08	12.66	1.25	74030.08
22	8.42	13.39	41.54	3.13	13.93	12.04	1.25	78882.72
23	8.91	14.96	50.07	2.42	14.38	12.52	1.25	74207.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.21	12.84	48.22	1.90	14.33	11.83	1.28	80100.08
最大值	12.01	14.96	56.94	3.13	16.08	12.66	1.30	84303.47
發生時間	10	23	17	22	0	21		0
最小值	3.92	11.68	39.40	0.92	13.08	11.13	1.24	74030.08
發生時間	21	17	13	12	21	0		21
零點偏移(率)	-0.06 %	-0.01 %	-0.12 %	0.01 %		-0.21	-0.01	0.30 %
全幅偏移(率)	1.97 %	0.24 %	0.96 %	0.47 %		0.08	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.18	12.28	52.31	1.79	15.15	11.28	1.05	76345.82
1	2.99	12.31	55.07	1.79	16.27	11.19	1.06	77011.61
2	7.27	12.18	54.68	2.53	15.89	11.12	1.05	77929.92
3	4.44	11.87	50.97	2.24	15.68	10.89	1.02	77590.70
4	2.34	12.14	55.71	1.48	15.55	11.13	1.02	77381.90
5	2.20	12.05	52.59	2.10	14.64	11.10	1.02	76169.30
6	1.92	12.15	46.43	2.73	13.80	11.63	1.02	82123.88
7	2.75	12.19	62.98	2.66	14.72	11.21	1.03	79273.93
8	2.30	12.04	58.04	1.99	15.10	11.11	1.02	79087.43
9	2.05	11.65	37.33	1.93	14.91	10.74	1.02	75805.88
10	4.24	11.93	56.49	1.69	16.10	10.86	1.02	77677.51
11	2.79	11.89	52.04	1.78	15.18	10.86	1.02	76504.03
12	3.20	11.93	51.32	2.11	14.54	11.04	1.02	77073.09
13	1.63	11.43	39.62	1.77	15.31	10.39	1.04	75752.33
14	2.01	11.48	39.75	1.54	15.16	10.50	1.04	75431.32
15	2.78	11.34	42.35	1.73	16.09	10.31	1.04	77463.13
16	2.86	11.84	51.67	1.83	15.45	10.74	1.05	77639.67
17	6.78	12.13	50.93	1.89	14.47	10.97	1.05	75753.84
18	3.12	11.93	48.84	1.58	15.24	10.78	1.04	75856.96
19	2.71	13.50	49.30	1.61	15.84	10.38	1.04	78757.47
20	3.82	11.91	50.77	1.62	15.37	10.84	1.03	76672.08
21	3.01	11.98	51.44	1.67	15.39	10.92	1.02	77244.39
22	2.98	11.89	55.33	1.89	14.68	10.88	1.02	76778.26
23	4.06	12.22	47.63	1.37	16.15	10.91	1.02	74820.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.14	12.01	50.57	1.89	15.28	10.91	1.03	77172.70
最大值	7.27	13.50	62.98	2.73	16.27	11.63	1.06	82123.88
發生時間	2	19	7	6	1	6		6
最小值	1.18	11.34	37.33	1.37	13.80	10.31	0.99	74820.24
發生時間	0	15	9	23	6	15		23
零點偏移(率)	-0.07 %	-0.01 %	-0.02 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-1.15 %	0.62 %	0.83 %	-0.47 %		-0.16	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.70	11.12	47.47	1.79	17.64	9.81	1.43	74088.85
1	9.07	11.28	51.42	1.95	17.18	10.02	1.43	73486.62
2	14.01	11.45	49.51	3.44	16.90	9.59	1.43	72373.71
3	12.64	11.62	45.38	3.35	15.93	9.55	1.43	71037.54
4	9.28	11.08	38.75	2.62	16.61	9.39	1.43	73271.66
5	9.32	11.01	45.87	2.83	15.87	9.63	1.43	72087.49
6	10.23	10.92	44.77	2.36	16.12	9.62	1.42	72090.74
7	7.11	11.35	43.12	2.37	15.34	9.81	1.42	72333.24
8	9.25	10.94	43.78	2.33	16.10	9.46	1.43	73049.97
9	9.37	11.18	41.31	2.44	15.40	9.59	1.42	72199.81
10	9.73	11.01	42.35	2.42	15.52	9.69	1.43	71673.42
11	9.48	10.91	43.94	2.36	16.34	9.50	1.43	72947.62
12	9.53	10.84	43.49	2.35	15.37	9.64	1.43	72405.69
13	7.74	12.06	44.93	2.65	15.11	10.15	1.43	67805.61
14	9.91	11.86	35.78	2.68	16.78	9.19	1.43	71288.59
15	8.93	11.87	36.71	2.68	16.22	9.22	1.43	70830.87
16	9.53	12.26	34.49	1.21	16.30	9.30	1.43	73551.36
17	9.33	10.87	37.51	1.71	16.14	9.37	1.40	72082.26
18	9.65	11.23	36.95	2.49	16.38	9.24	1.41	71643.59
19	9.32	11.97	32.86	1.47	17.53	8.99	1.41	71699.75
20	9.86	11.50	32.22	2.25	16.87	9.33	1.41	70472.21
21	9.24	10.77	33.86	1.99	18.23	9.02	1.41	73983.03
22	9.51	10.98	33.20	2.15	16.23	9.04	1.41	73428.76
23	9.76	10.93	36.28	2.14	17.69	8.95	1.41	73602.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.65	11.29	40.66	2.33	16.41	9.46	1.42	72226.47
最大值	14.01	12.26	51.42	3.44	18.23	10.15	1.44	74088.85
發生時間	2	16	1	2	21	13		0
最小值	7.11	10.77	32.22	1.21	15.11	8.95	1.39	67805.61
發生時間	7	21	20	16	13	23		13
零點偏移(率)	-0.07 %	-0.01 %	-0.04 %	-0.02 %		-0.06	-0.01	0.20 %
全幅偏移(率)	-0.56 %	-1.74 %	0.51 %	0.14 %		0.02	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								