

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.03	7.84	58.51	1.43	18.37	11.51	1.08	79842.37
1	8.88	5.77	53.19	1.65	18.19	11.32	1.06	82787.64
2	10.01	8.31	54.33	1.99	17.39	11.51	1.10	82050.00
3	9.37	14.98	48.75	2.98	15.49	11.95	1.10	79727.39
4	8.82	7.32	54.90	1.95	16.44	11.88	1.10	79084.03
5	7.22	13.14	54.09	2.37	16.43	11.63	1.07	77820.69
6	8.56	12.20	56.87	2.47	16.28	11.87	1.06	79658.00
7	8.63	10.62	61.37	2.03	17.24	11.66	1.05	80461.97
8	9.58	11.43	52.45	2.94	15.58	12.00	1.05	78625.98
9	8.08	9.73	59.56	1.79	17.07	11.62	1.06	80850.47
10	7.84	12.06	51.04	2.05	16.98	11.64	1.05	80529.94
11	9.38	13.14	51.12	2.38	16.04	11.93	1.05	79221.83
12	7.13	11.96	51.49	2.05	16.38	12.03	1.06	77633.00
13	5.97	11.92	57.32	1.47	17.83	11.31	1.07	81208.43
14	7.44	16.70	46.12	3.20	15.02	11.97	1.08	77131.75
15	9.11	12.84	53.00	3.35	14.97	12.04	1.08	76563.90
16	8.80	15.12	53.32	3.30	15.21	11.86	1.08	77060.51
17	9.70	16.81	49.25	3.17	14.88	11.71	1.08	77223.27
18	10.88	14.52	49.02	3.21	15.06	11.67	1.07	78146.03
19	8.45	10.40	55.29	1.72	17.73	11.24	1.08	82182.30
20	9.53	15.76	51.39	2.36	15.87	11.70	1.08	79173.37
21	7.75	15.98	55.15	2.29	16.74	11.84	1.07	78377.72
22	7.71	12.49	58.73	1.50	17.76	11.49	1.06	81835.42
23	9.46	13.72	43.80	2.59	15.29	12.10	1.05	77310.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.43	12.28	53.34	2.34	16.43	11.73	1.07	79354.45
最大值	10.88	16.81	61.37	3.35	18.37	12.10	1.19	82787.64
發生時間	18	17	7	15	0	23		1
最小值	4.03	5.77	43.80	1.43	14.88	11.24	1.05	76563.90
發生時間	0	1	23	0	17	19		15
零點偏移(率)	-0.05 %	-0.07 %	-0.04 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-1.65 %	-0.01 %	-0.60 %		-0.10		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.84	2.51	63.47	1.00	18.58	10.62	1.18	77589.94
1	7.57	3.54	50.50	1.33	20.29	9.61	1.19	86500.01
2	9.54	16.80	52.03	3.05	16.85	10.35	1.18	82348.07
3	8.43	8.99	44.27	1.45	19.57	9.73	1.18	85142.36
4	8.95	9.01	45.13	1.87	18.71	9.71	1.19	82620.53
5	8.98	13.20	51.23	1.75	18.63	9.69	1.20	83042.91
6	10.48	6.90	52.92	1.37	19.09	9.54	1.20	79345.25
7	9.89	7.46	47.43	2.34	17.61	10.00	1.20	83244.31
8	8.48	5.20	61.83	1.40	19.53	9.67	1.20	83950.40
9	9.05	8.76	52.63	1.53	18.51	9.17	1.18	82855.65
10	7.09	6.84	62.91	1.49	18.56	9.48	1.19	81379.83
11	5.53	6.73	41.84	1.80	17.36	9.40	1.20	80353.12
12	9.58	10.59	38.51	2.25	17.20	9.50	1.18	78944.47
13	9.56	11.44	54.65	2.06	17.04	9.37	1.19	78026.90
14	9.39	11.71	46.84	2.33	16.07	9.36	1.18	75604.39
15	9.68	8.45	50.95	2.05	16.54	9.00	1.18	76825.44
16	9.37	13.20	46.31	2.25	15.28	9.15	1.20	79595.77
17	10.49	6.16	65.33	2.11	16.10	9.65	1.19	80727.04
18	8.43	12.66	45.33	1.83	17.04	9.34	1.18	80497.72
19	6.61	4.89	47.16	1.67	18.18	10.25	1.20	78525.33
20	4.24	10.40	52.51	1.47	18.25	10.67	1.21	76307.94
21	7.93	7.21	53.41	1.73	18.31	10.34	1.20	82389.90
22	7.30	6.93	49.58	1.32	18.23	9.93	1.20	83253.63
23	10.22	10.53	53.00	1.55	18.30	9.42	1.20	85525.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.36	8.75	51.24	1.79	17.91	9.71	1.19	81024.85
最大值	10.49	16.80	65.33	3.05	20.29	10.67	1.22	86500.01
發生時間	17	2	17	2	1	20		1
最小值	3.84	2.51	38.51	1.00	15.28	9.00	1.18	75604.39
發生時間	0	0	12	0	16	15		14
零點偏移(率)	-0.60 %	-0.01 %	-0.02 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	-2.15 %	-2.33 %	-1.74 %	-0.74 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.58	5.08	48.10	0.67	17.91	10.36	0.98	80562.39
1	1.29	6.69	49.34	0.69	17.70	10.82	0.99	81655.16
2	0.69	7.52	53.63	1.18	16.35	11.20	1.01	77893.15
3	0.81	6.89	56.23	0.75	17.83	10.67	1.02	82178.23
4	2.50	13.55	37.78	0.84	17.52	10.66	1.01	78753.50
5	6.84	9.70	37.03	0.89	18.05	10.29	0.99	80235.94
6	6.31	5.24	47.85	1.06	17.00	10.69	0.99	80936.45
7	7.58	10.28	50.17	1.73	14.85	11.42	0.99	71446.18
8	6.69	7.10	56.31	1.62	15.79	11.29	0.99	78439.08
9	2.19	7.33	54.21	1.04	17.91	10.56	0.98	78652.75
10	3.01	12.95	47.40	1.34	16.62	10.33	0.97	79601.51
11	9.65	11.59	41.40	2.19	14.74	10.72	0.98	75947.96
12	9.17	5.30	58.96	1.65	16.46	10.75	0.99	76603.90
13	2.94	8.39	50.09	1.26	16.37	10.76	0.99	78304.55
14	3.51	11.15	47.46	1.67	15.47	10.91	0.99	77065.96
15	13.80	13.12	45.66	2.16	15.28	10.88	1.00	74475.30
16	9.28	7.53	50.25	2.16	15.19	10.73	1.00	75348.31
17	10.39	17.10	46.27	2.49	14.47	10.62	0.98	75793.84
18	4.19	12.33	46.32	1.33	16.06	10.36	0.97	74288.82
19	4.81	11.49	55.88	1.44	15.74	10.60	0.99	75623.51
20	8.20	6.54	57.19	1.58	15.79	10.93	1.02	75690.37
21	2.74	14.91	56.35	1.03	16.74	10.72	1.03	82188.91
22	6.75	10.40	62.18	1.29	16.43	11.30	1.02	80215.31
23	10.83	12.02	56.40	1.73	16.19	10.46	1.00	86076.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.66	9.76	50.52	1.41	16.35	10.75	0.99	78249.06
最大值	13.80	17.10	62.18	2.49	18.05	11.42	1.05	86076.37
發生時間	15	17	22	17	5	7		23
最小值	0.69	5.08	37.03	0.67	14.47	10.29	0.97	71446.18
發生時間	2	0	5	0	17	5		7
零點偏移(率)	-0.06 %	-0.01 %	-0.02 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-2.48 %	-1.28 %	-1.14 %		0.15		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								