

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.82	7.34	61.96	4.95	14.24	12.65	1.38	62535.79
1	3.76	2.68	57.98	4.43	15.43	12.08	1.38	65543.10
2	8.36	1.96	46.11	4.13	17.91	10.95	1.38	71966.51
3	7.94	1.92	37.52	4.78	17.98	10.48	1.36	73224.24
4	9.84	1.83	54.59	5.30	17.63	10.63	1.35	73099.97
5	6.06	13.62	54.20	4.54	16.03	12.39	1.37	71804.17
6	6.52	2.09	59.76	3.56	17.75	11.82	1.37	67388.06
7	5.72	2.03	46.07	3.69	18.44	10.95	1.36	72431.17
8	8.31	1.91	54.50	4.13	16.82	11.35	1.36	70147.26
9	8.93	2.63	60.18	4.05	16.69	11.28	1.39	68570.87
10	9.00	1.83	53.51	4.27	15.99	11.26	1.36	69556.73
11	9.78	2.03	60.61	4.34	15.90	11.33	1.34	68240.73
12	6.65	1.63	51.55	3.52	16.45	11.07	1.37	69184.99
13	6.51	1.67	59.32	3.61	16.42	11.19	1.37	69447.65
14	9.55	1.64	59.77	3.92	16.37	11.10	1.36	69648.27
15	6.57	1.93	57.13	3.44	16.77	11.10	1.36	70895.72
16	6.70	2.97	56.02	3.95	15.54	11.32	1.35	68104.51
17	5.79	3.44	62.99	3.17	17.72	10.63	1.35	72160.88
18	7.76	1.25	48.19	4.04	17.04	10.89	1.37	68660.81
19	2.27	18.80	64.98	3.03	20.51	9.43	1.36	73199.38
20	1.25	16.05	31.38	7.96	20.50	8.40	1.31	74225.39
21	2.87	0.68	66.92	3.28	16.39	10.99	1.31	67973.12
22	5.16	1.79	47.94	3.58	16.96	11.36	1.33	68792.83
23	7.50	1.09	57.73	3.27	18.77	10.57	1.35	71973.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.53	3.95	54.62	4.12	17.09	11.05	1.36	69949.00
最大值	9.84	18.80	66.92	7.96	20.51	12.65	1.40	74225.39
發生時間	4	19	21	20	19	0		20
最小值	1.25	0.68	31.38	3.03	14.24	8.40	1.30	62535.79
發生時間	20	21	20	19	0	20		0
零點偏移(率)	0.00 %	0.00 %	-0.00 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	-0.77 %	0.00 %	0.11 %	0.31 %		0.09	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.48	2.69	47.22	2.87	16.13	9.92	1.38	71768.61
1	9.47	2.60	50.86	2.90	16.25	9.88	1.38	75031.55
2	10.67	4.91	46.07	2.79	18.82	8.85	1.38	80435.43
3	9.65	7.46	41.88	3.17	18.48	8.56	1.38	82920.21
4	4.23	3.12	62.43	1.22	20.46	9.19	1.38	78718.68
5	2.13	1.75	59.59	0.98	19.76	10.28	1.38	74955.32
6	0.08	3.02	57.10	1.00	19.17	11.27	1.38	68429.85
7	2.56	2.02	48.00	0.87	20.76	9.07	1.38	87863.97
8	6.15	2.42	48.10	1.86	18.04	9.54	1.40	82974.78
9	9.27	3.06	53.01	2.18	17.61	9.76	1.43	82795.80
10	6.71	1.62	62.51	1.43	19.19	9.68	1.42	80775.19
11	5.09	1.71	51.00	1.36	18.79	9.57	1.40	83989.61
12	3.30	1.84	49.48	1.29	18.04	9.84	1.41	84092.63
13	3.32	3.65	54.11	1.71	17.29	10.22	1.41	81093.44
14	3.96	1.78	56.26	1.36	18.30	10.01	1.41	83141.73
15	5.87	1.71	54.54	1.24	18.71	9.74	1.41	86378.09
16	7.08	1.34	57.01	1.04	19.45	9.70	1.41	87929.39
17	3.25	2.02	52.66	1.05	18.37	9.85	1.42	85340.74
18	0.46	1.43	60.80	0.41	20.96	9.31	1.42	86970.62
19	7.15	1.65	55.16	1.33	18.35	9.93	1.40	86011.30
20	6.68	2.55	58.82	1.31	18.95	9.56	1.40	84826.56
21	2.14	1.50	65.98	0.53	20.68	9.44	1.41	81962.16
22	0.50	1.50	64.95	0.66	19.83	10.24	1.41	82577.11
23	1.33	1.56	55.84	0.76	20.09	10.00	1.42	83868.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.98	2.45	54.72	1.47	18.85	9.73	1.40	81868.79
最大值	10.67	7.46	65.98	3.17	20.96	11.27	1.44	87929.39
發生時間	2	3	21	3	18	6		16
最小值	0.08	1.34	41.88	0.41	16.13	8.56	1.38	68429.85
發生時間	6	16	3	18	0	3		6
零點偏移(率)	-0.01 %	0.00 %	-0.00 %	-0.06 %		0.01	0.00	-0.20 %
全幅偏移(率)	1.45 %	-0.48 %	0.37 %	0.26 %		0.04	-0.03	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.90	1.81	60.45	3.00	15.40	11.16	1.24	72098.52
1	6.75	1.55	52.39	2.81	18.54	10.71	1.27	78289.80
2	10.60	2.35	42.89	3.83	18.19	9.95	1.29	83435.68
3	8.67	3.61	41.73	3.69	15.97	10.35	1.26	80094.28
4	8.87	5.95	41.49	3.27	17.14	9.90	1.25	79932.91
5	7.58	2.43	60.09	3.01	20.05	9.52	1.26	82652.45
6	10.42	2.30	57.73	3.48	19.09	9.75	1.26	84861.94
7	7.05	15.15	57.54	2.80	18.88	9.51	1.30	85924.32
8	10.37	4.38	52.89	3.06	17.15	10.07	1.30	85477.27
9	9.61	5.07	48.63	2.83	18.51	9.53	1.30	85180.26
10	10.23	2.48	60.30	3.30	16.77	10.00	1.32	80738.45
11	9.35	6.72	44.65	2.56	16.10	10.37	1.35	78500.32
12	4.57	1.68	61.40	2.29	18.08	10.11	1.30	81217.78
13	7.51	2.09	54.71	2.61	15.90	10.49	1.29	79941.19
14	5.19	1.94	56.74	2.39	16.20	10.46	1.29	78316.75
15	7.72	2.16	60.77	2.28	16.97	10.11	1.30	81538.21
16	6.69	1.49	64.37	2.21	16.69	10.64	1.31	80708.77
17	5.61	2.10	60.23	2.08	16.81	10.38	1.30	84293.12
18	3.90	2.95	61.46	2.22	16.50	10.45	1.29	83112.59
19	6.01	2.71	60.14	2.18	17.87	10.21	1.31	84194.45
20	3.41	2.28	58.89	2.21	17.82	10.06	1.34	83186.48
21	4.31	3.40	55.06	2.30	16.91	10.06	1.31	80916.21
22	3.98	2.24	64.63	2.26	18.12	10.21	1.30	80358.10
23	1.65	1.83	62.39	2.29	18.85	10.41	1.28	80504.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.87	3.36	55.90	2.71	17.44	10.18	1.29	81478.09
最大值	10.60	15.15	64.63	3.83	20.05	11.16	1.36	85924.32
發生時間	2	7	22	2	5	0		7
最小值	1.65	1.49	41.49	2.08	15.40	9.51	1.23	72098.52
發生時間	23	16	4	17	0	7		0
零點偏移(率)	-0.34 %	0.00 %	-0.06 %	-0.13 %		-0.01	0.00	0.00 %
全幅偏移(率)	4.69 %	-0.22 %	-0.48 %	0.26 %		0.37	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								