

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.92	2.58	63.13	0.70	21.68	11.11	1.46	77015.32
1	7.64	1.66	71.38	1.10	20.43	12.12	1.43	71142.12
2	8.69	5.35	66.05	1.48	19.16	13.23	1.49	63364.58
3	11.38	1.02	57.09	1.08	20.69	11.66	1.42	74440.75
4	14.14	1.70	52.89	1.11	21.00	10.90	1.44	79691.65
5	17.86	3.82	51.74	3.50	19.83	11.14	1.49	80512.11
6	10.63	8.10	58.40	2.95	19.93	11.44	1.48	76817.25
7	10.98	1.28	52.19	2.36	19.93	11.13	1.45	79508.01
8	8.45	1.49	55.53	2.22	18.86	11.43	1.44	78001.90
9	13.31	0.91	62.23	1.31	19.21	11.87	1.41	74124.48
10	10.97	1.67	53.50	1.71	18.28	11.45	1.42	77937.41
11	12.92	5.57	55.36	1.70	17.24	11.77	1.45	76220.32
12	8.74	1.14	60.17	1.31	19.09	11.89	1.46	74191.42
13	8.80	4.51	62.63	1.46	18.05	12.33	1.46	71576.16
14	12.46	2.57	55.26	1.47	18.27	11.41	1.46	78377.50
15	13.69	12.93	52.57	1.83	16.70	11.64	1.46	77734.13
16	8.95	4.75	59.83	1.83	17.79	11.81	1.46	75556.33
17	9.80	3.88	66.55	2.23	17.76	12.31	1.44	71453.81
18	10.72	5.20	61.39	1.20	19.27	11.43	1.44	77582.00
19	10.39	10.01	55.90	1.59	18.20	11.67	1.41	76385.75
20	9.60	6.79	52.84	1.52	17.72	11.56	1.41	76632.27
21	9.00	2.07	62.23	1.25	18.82	11.52	1.41	76013.29
22	8.26	2.27	53.30	1.08	18.90	11.19	1.41	78873.67
23	7.00	2.09	62.21	1.04	19.60	11.46	1.41	75650.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.60	3.89	58.52	1.63	19.02	11.64	1.44	75783.47
最大值	17.86	12.93	71.38	3.50	21.68	13.23	1.69	80512.11
發生時間	5	15	1	5	0	2		5
最小值	7.00	0.91	51.74	0.70	16.70	10.90	1.41	63364.58
發生時間	23	9	5	0	15	4		2
零點偏移(率)	0.00 %	0.00 %	-0.10 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	-0.58 %	-0.36 %	0.44 %	-0.05 %		0.19	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.87	3.27	60.05	1.89	16.81	10.95	1.38	63977.78
1	10.69	1.35	63.34	1.35	18.37	10.53	1.42	66257.18
2	10.00	1.47	64.87	1.61	17.52	11.21	1.41	62824.63
3	11.09	1.14	58.41	1.47	19.01	10.30	1.38	67819.87
4	10.99	1.16	58.54	1.29	19.55	10.24	1.38	67772.93
5	10.43	2.60	55.36	1.54	19.12	10.32	1.36	67618.98
6	3.42	4.30	68.46	0.63	20.93	10.39	1.39	67119.47
7	10.28	5.03	64.40	1.04	20.42	10.68	1.43	64801.56
8	11.85	5.34	61.81	1.18	19.60	10.68	1.44	65497.71
9	10.45	4.13	57.06	1.31	19.62	10.39	1.42	67294.70
10	9.92	9.88	56.87	1.41	19.20	10.48	1.39	66761.39
11	8.95	7.08	63.72	1.07	21.07	10.35	1.38	65790.06
12	10.65	5.42	53.14	1.30	20.31	10.09	1.37	68961.53
13	11.45	7.30	57.17	1.83	18.63	10.35	1.36	67685.19
14	12.45	5.55	52.77	1.89	17.71	10.40	1.38	68503.85
15	13.96	6.25	58.04	3.12	17.01	10.52	1.38	68049.12
16	5.81	1.69	62.14	2.36	17.32	10.66	1.38	64582.77
17	9.95	5.01	50.65	3.16	17.77	10.26	1.39	65542.04
18	9.52	5.03	57.91	1.57	18.73	10.06	1.39	69773.60
19	10.48	6.71	65.43	1.68	18.32	10.70	1.41	66441.46
20	7.31	9.28	54.17	1.83	17.67	10.86	1.41	65901.34
21	8.99	7.23	58.66	1.20	19.14	10.61	1.42	66185.83
22	10.62	7.86	53.86	1.49	18.24	10.57	1.42	67030.13
23	7.06	2.68	57.01	1.53	17.62	10.80	1.41	64576.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.88	4.87	58.91	1.61	18.74	10.52	1.40	66532.05
最大值	13.96	9.88	68.46	3.16	21.07	11.21	1.45	69773.60
發生時間	15	10	6	17	11	2		18
最小值	3.42	1.14	50.65	0.63	16.81	10.06	1.36	62824.63
發生時間	6	3	17	6	0	18		2
零點偏移(率)	-0.11 %	0.00 %	-0.02 %	-0.00 %		-0.11	0.00	0.00 %
全幅偏移(率)	-0.26 %	-0.60 %	-0.16 %	0.27 %		0.18	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.02	7.15	54.45	2.87	15.44	10.87	1.33	83727.65
1	8.68	6.16	53.00	2.54	16.95	10.50	1.30	84123.96
2	9.16	1.57	53.06	2.55	15.72	10.90	1.31	82544.68
3	8.65	1.30	54.00	2.37	16.61	10.43	1.33	86742.59
4	10.64	1.43	60.79	2.51	16.93	10.83	1.34	87799.37
5	9.48	2.48	52.05	2.52	17.06	10.22	1.30	86776.34
6	11.68	6.76	52.51	3.08	14.21	11.00	1.27	80006.68
7	12.24	5.30	50.77	3.46	14.73	11.30	1.27	79250.16
8	10.15	2.76	55.48	3.25	16.55	10.48	1.30	88394.12
9	8.46	6.31	58.44	3.09	14.41	11.42	1.30	81167.45
10	11.03	1.12	62.70	1.99	17.86	10.74	1.30	88553.64
11	10.30	1.99	49.86	2.19	16.53	10.82	1.26	88665.01
12	9.69	0.88	54.52	1.91	17.57	10.73	1.28	89534.09
13	10.62	4.14	47.02	2.38	15.48	11.08	1.28	87583.90
14	15.81	12.76	46.23	4.08	14.27	11.02	1.28	87735.52
15	9.13	8.94	50.67	2.88	14.04	11.41	1.29	84027.81
16	9.93	4.34	57.68	2.53	14.67	11.17	1.30	86172.34
17	9.96	2.43	60.32	2.30	15.72	11.09	1.32	86613.26
18	8.29	6.17	57.35	2.27	15.27	11.27	1.30	84187.54
19	8.83	7.97	59.13	2.57	14.99	11.07	1.31	87574.15
20	8.22	3.74	63.92	2.56	14.83	11.25	1.32	86014.78
21	10.42	1.69	61.09	2.00	16.64	10.68	1.32	89491.33
22	9.34	3.79	58.59	2.11	15.18	11.08	1.32	87021.35
23	10.28	3.04	59.84	2.18	15.05	11.11	1.33	86527.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.08	4.34	55.56	2.59	15.70	10.94	1.30	85843.14
最大值	15.81	12.76	63.92	4.08	17.86	11.42	1.37	89534.09
發生時間	14	14	20	14	10	9		12
最小值	8.22	0.88	46.23	1.91	14.04	10.22	1.25	79250.16
發生時間	20	12	14	12	15	5		7
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	-0.04 %	-1.76 %	-0.28 %	-0.33 %		0.54	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								