

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月23日

報表日期: 113年06月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.75	4.44	55.47	1.88	17.47	11.46	0.96	82080.94
1	7.88	5.03	50.48	1.97	18.55	11.53	0.96	80615.68
2	9.32	7.64	38.21	2.90	16.52	11.51	0.96	82600.86
3	9.98	4.40	43.39	2.71	16.55	11.65	0.96	81768.71
4	8.80	3.98	40.72	2.59	16.25	11.65	0.97	82035.25
5	10.45	10.18	57.70	2.56	16.71	11.64	0.96	79238.98
6	8.67	4.52	59.56	1.58	18.35	11.30	0.97	82765.90
7	8.51	6.91	44.76	1.36	20.27	10.55	0.95	85344.41
8	6.57	3.28	39.85	1.64	18.56	11.18	0.94	82056.00
9	8.99	2.98	56.39	1.06	20.26	10.89	0.97	84156.43
10	12.95	3.14	58.68	1.80	19.85	10.92	0.95	84310.61
11	14.07	3.11	58.42	1.92	19.83	10.91	0.93	84071.53
12	8.84	3.24	66.63	1.24	19.67	11.72	0.96	78136.86
13	9.47	3.14	57.49	1.16	20.37	11.25	0.96	81116.60
14	9.32	3.17	54.79	1.12	20.83	10.77	0.95	85211.08
15	7.79	3.32	59.02	1.38	18.61	11.45	0.94	81806.48
16	10.79	3.17	50.83	2.58	18.11	11.25	0.94	83527.69
17	9.60	4.46	49.08	1.67	19.19	10.85	0.93	85761.24
18	10.46	3.71	44.02	2.39	17.99	11.28	0.92	83155.99
19	10.31	7.43	45.99	1.43	19.32	11.05	0.93	83671.78
20	11.42	5.79	50.35	1.87	19.32	10.82	0.94	85628.98
21	9.77	4.37	59.11	1.20	19.93	10.82	0.95	85047.43
22	10.48	6.49	42.20	2.12	17.78	11.32	0.97	83134.87
23	11.25	4.63	48.50	2.11	18.68	11.01	0.96	84818.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.77	4.69	51.32	1.84	18.71	11.20	0.95	83002.61
最 大 值	14.07	10.18	66.63	2.90	20.83	11.72	0.97	85761.24
發生時間	11	5	12	2	14	12		17
最 小 值	6.57	2.98	38.21	1.06	16.25	10.55	0.92	78136.86
發生時間	8	9	2	9	4	7		12
零點偏移(率)	-0.02 %	-0.07 %	-0.02 %	0.00 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	-0.20 %	-0.22 %	0.24 %		0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

