

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.72	9.22	64.30	0.89	19.23	11.60	1.02	76238.90
1	4.99	4.75	52.27	1.04	19.95	10.69	1.00	82941.34
2	3.72	8.02	52.09	1.35	17.72	11.70	1.00	77207.74
3	0.82	6.84	67.17	0.43	19.97	10.85	1.01	80666.14
4	0.93	7.21	57.70	0.79	18.44	11.19	1.02	80060.34
5	1.15	7.45	43.69	1.32	17.55	11.55	1.00	79924.93
6	3.04	10.38	48.70	1.37	18.33	10.92	0.99	80572.01
7	2.43	5.88	52.78	1.36	17.25	11.60	1.00	75557.31
8	3.55	3.89	56.52	1.33	18.32	11.44	1.04	77291.56
9	6.07	5.87	50.93	1.42	18.33	11.36	1.04	78460.93
10	5.21	6.08	63.94	1.04	18.33	11.80	1.01	75479.72
11	6.85	6.81	51.87	1.41	17.48	11.53	1.02	78402.25
12	10.14	6.41	54.50	2.35	16.86	11.56	1.03	78681.22
13	9.29	5.73	52.58	2.06	17.27	11.35	1.02	79794.90
14	7.68	4.82	51.64	1.42	18.49	11.04	1.02	79671.00
15	4.67	5.77	58.63	1.13	17.71	11.77	1.03	75848.88
16	7.00	8.52	52.49	1.47	17.19	11.82	1.02	76364.47
17	7.02	7.50	56.58	1.66	17.32	11.70	1.01	77472.26
18	7.88	7.47	63.11	1.54	16.98	11.93	1.03	75935.36
19	2.91	9.02	68.91	0.84	18.17	12.13	1.01	73246.76
20	9.03	9.85	53.29	1.40	17.55	11.69	0.99	77403.95
21	9.93	11.30	60.17	1.79	16.93	11.73	0.99	77802.50
22	9.19	9.66	56.00	1.87	16.23	11.96	0.99	76578.22
23	9.18	10.87	60.97	1.64	17.38	11.76	0.99	77230.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.73	7.47	56.28	1.37	17.87	11.53	1.01	77868.07
最大值	10.14	11.30	68.91	2.35	19.97	12.13	1.07	82941.34
發生時間	12	21	19	12	3	19		1
最小值	0.82	3.89	43.69	0.43	16.23	10.69	0.99	73246.76
發生時間	3	8	5	3	22	1		19
零點偏移(率)	-0.04 %	-0.01 %	-0.02 %	-0.01 %		-0.05		0.00 %
全幅偏移(率)	0.02 %	0.03 %	0.01 %	-0.20 %		-0.07		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.60	5.76	50.40	1.67	17.03	10.58	0.98	84232.23
1	0.94	4.79	50.57	1.58	18.62	10.43	0.99	83191.49
2	1.12	4.31	55.58	1.51	17.86	10.26	0.99	85307.13
3	0.09	5.19	57.11	1.49	18.62	10.37	1.00	84105.31
4	0.09	6.17	58.45	2.09	17.26	10.32	0.99	85889.83
5	0.14	8.29	51.20	1.53	17.84	10.36	0.99	85240.92
6	0.08	5.45	62.93	1.67	16.62	10.77	0.99	87832.40
7	0.58	5.86	45.05	1.69	17.74	10.26	0.99	83624.55
8	4.59	2.50	55.18	2.51	16.30	10.58	0.99	83366.41
9	6.41	3.47	57.82	1.83	18.40	10.51	0.99	83354.15
10	5.27	7.96	55.18	1.48	18.45	10.42	0.99	83946.33
11	2.74	3.47	60.95	1.05	18.89	10.40	1.01	83839.08
12	8.13	7.58	39.78	2.37	17.35	9.82	0.99	83625.57
13	8.41	6.45	48.29	3.02	15.17	10.50	0.99	82258.67
14	8.55	3.67	43.26	2.75	15.34	10.72	0.99	82597.37
15	6.22	3.19	58.11	1.80	16.98	10.27	0.99	85424.50
16	7.82	4.77	53.51	2.40	14.97	10.81	0.99	82471.75
17	9.60	4.60	55.36	2.51	15.29	10.75	0.98	81926.07
18	8.02	3.64	54.15	1.98	16.44	10.61	0.97	82174.60
19	8.68	4.51	57.03	1.88	17.65	10.52	0.99	84188.53
20	8.30	4.75	59.68	1.52	18.03	10.42	0.99	84625.49
21	8.12	5.85	50.91	3.01	16.12	10.80	0.99	83903.61
22	9.05	9.98	59.33	2.46	16.48	10.83	0.99	82987.32
23	6.02	6.24	62.45	1.26	18.15	10.36	0.99	84715.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.02	5.35	54.26	1.96	17.15	10.49	0.99	83951.21
最大值	9.60	9.98	62.93	3.02	18.89	10.83	1.03	87832.40
發生時間	17	22	6	13	11	22		6
最小值	0.08	2.50	39.78	1.05	14.97	9.82	0.97	81926.07
發生時間	6	8	12	11	16	12		17
零點偏移(率)	-0.07 %	0.00 %	-0.02 %	-0.01 %		0.00		-0.10 %
全幅偏移(率)	0.00 %	0.55 %	-1.22 %	-0.01 %		-0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.93	6.26	53.79	1.89	15.57	11.20	0.97	76760.54
1	0.84	6.25	54.31	1.41	18.36	10.79	0.97	81262.59
2	1.91	8.45	53.11	1.66	16.85	10.58	0.98	81569.14
3	1.35	6.25	49.76	1.55	16.51	10.41	0.97	78121.10
4	1.15	8.44	58.17	1.68	16.16	10.83	0.98	78219.40
5	2.24	7.20	51.83	2.31	15.02	10.95	0.99	79242.00
6	2.69	9.39	56.29	2.14	15.44	10.96	0.99	78769.19
7	1.12	8.13	53.95	1.18	17.59	10.46	1.00	73829.77
8	3.09	8.11	40.39	1.61	16.84	10.19	0.99	79831.03
9	3.99	5.38	47.59	1.95	15.42	10.62	0.95	75986.20
10	3.74	3.27	55.44	1.56	16.28	11.12	0.97	77222.88
11	5.27	6.68	41.72	1.69	16.73	10.35	0.99	76969.18
12	1.46	4.58	52.60	1.18	17.91	10.47	0.99	77168.31
13	1.81	10.27	51.09	1.50	16.26	10.61	0.97	77625.35
14	2.51	4.01	48.36	1.42	17.04	10.17	0.95	78931.23
15	4.60	5.16	45.92	1.55	16.30	10.61	0.97	75841.71
16	5.00	4.61	51.22	1.60	16.01	10.65	0.98	77795.28
17	6.97	7.94	52.30	2.15	14.69	11.01	0.95	77529.89
18	7.98	11.14	57.53	2.57	13.90	11.29	0.97	74863.24
19	5.98	4.69	60.78	1.75	16.07	10.91	0.95	78001.10
20	7.10	10.76	52.16	1.76	16.66	10.61	0.96	80879.35
21	8.98	7.91	51.46	2.15	15.38	10.90	0.97	77964.94
22	8.42	9.40	54.80	2.27	14.82	11.09	0.96	76900.75
23	3.99	11.46	60.14	1.64	15.83	11.28	0.95	74626.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.05	7.32	52.28	1.76	16.15	10.75	0.97	77746.27
最大值	8.98	11.46	60.78	2.57	18.36	11.29	1.03	81569.14
發生時間	21	23	19	18	1	18		2
最小值	0.84	3.27	40.39	1.18	13.90	10.17	0.94	73829.77
發生時間	1	10	8	7	18	14		7
零點偏移(率)	-0.02 %	-0.04 %	-0.08 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.12 %	1.32 %	-0.78 %	0.23 %		0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								