

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.28	6.20	51.27	1.03	18.67	11.48	1.06	77675.09
1	4.62	5.84	46.53	1.30	19.46	11.04	1.06	80695.89
2	8.77	8.04	40.57	2.37	16.65	11.91	1.05	75442.35
3	4.21	8.56	42.00	4.90	20.80	9.83	1.05	83804.31
4	0.11	2.54	62.81	1.64	16.54	11.68	1.05	75708.67
5	0.12	13.22	61.30	1.15	17.83	11.88	1.03	80148.37
6	0.12	12.16	54.75	1.31	17.31	11.67	1.02	77343.83
7	1.91	7.56	62.02	1.45	18.03	11.53	1.03	77852.28
8	4.85	7.49	48.88	1.52	18.73	11.47	1.04	77263.52
9	4.64	7.78	52.27	1.58	18.96	11.40	1.04	78183.91
10	7.72	8.27	50.55	2.19	17.51	11.62	1.05	77672.11
11	10.50	7.96	58.51	1.88	18.84	11.40	1.04	78436.58
12	8.83	7.88	56.79	1.57	18.50	11.24	1.02	79502.64
13	7.23	8.62	47.67	2.07	17.34	11.60	1.04	77531.03
14	8.31	8.12	54.28	2.41	17.56	11.68	1.03	76774.56
15	7.83	7.84	60.77	1.57	18.70	11.57	1.02	77497.54
16	9.37	8.53	51.40	1.98	18.69	11.18	1.04	80377.66
17	9.15	11.83	58.39	2.81	18.17	11.68	1.05	76900.34
18	9.30	7.54	59.00	2.11	18.55	11.14	1.05	81203.85
19	9.07	8.25	58.07	2.04	17.75	11.36	1.04	80837.45
20	8.58	11.00	61.00	1.49	17.87	11.35	1.04	80304.58
21	8.85	13.51	55.98	1.55	17.71	11.46	1.02	79300.19
22	9.07	12.65	63.00	1.04	18.31	11.60	1.03	77823.87
23	8.59	12.39	66.78	1.34	18.42	11.68	1.02	76646.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.42	8.91	55.19	1.85	18.20	11.44	1.04	78538.62
最大值	10.50	13.51	66.78	4.90	20.80	11.91	1.08	83804.31
發生時間	11	21	23	3	3	2		3
最小值	0.11	2.54	40.57	1.03	16.54	9.83	1.00	75442.35
發生時間	4	4	2	0	4	3		2
零點偏移(率)	-0.01 %	-0.01 %	-0.00 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.11 %	-0.02 %	-0.02 %		0.07		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.07	5.00	50.26	1.16	19.02	11.22	1.01	76824.41
1	0.07	2.29	38.95	1.98	20.26	10.54	0.99	82057.71
2	1.23	1.60	45.32	1.93	20.64	9.48	0.99	89568.13
3	3.28	2.78	38.01	1.98	19.78	9.81	0.99	87358.57
4	1.67	2.26	54.48	1.63	20.02	10.32	0.99	84393.25
5	6.78	2.46	35.86	2.51	19.95	9.65	0.99	88506.51
6	12.26	13.06	46.69	6.54	18.88	9.74	0.97	90033.95
7	1.33	5.12	46.92	1.78	19.12	10.15	0.97	85425.44
8	1.74	4.72	50.68	2.07	18.81	10.03	0.97	87391.73
9	4.04	2.17	46.59	1.92	18.41	10.19	0.97	86103.90
10	0.99	2.22	51.41	2.36	17.10	10.50	0.97	84623.23
11	0.62	6.77	51.30	2.32	17.05	10.43	0.97	85199.56
12	1.39	3.29	55.38	2.53	16.06	10.88	0.95	83390.81
13	1.45	2.79	49.04	2.24	17.23	10.43	0.94	85745.24
14	8.53	2.17	54.73	2.67	16.58	10.53	0.94	84856.24
15	8.59	2.55	56.74	2.92	16.10	10.74	0.97	84394.20
16	7.98	1.98	53.31	2.28	17.49	10.45	0.98	85432.11
17	7.71	2.37	51.23	2.37	17.36	10.23	0.97	86856.42
18	5.01	2.29	55.11	2.63	17.19	10.56	0.97	83775.40
19	0.91	2.60	56.15	1.75	18.01	10.55	0.97	83593.74
20	4.65	7.03	49.41	2.08	17.71	10.29	0.97	86439.66
21	9.47	8.59	49.91	3.54	15.52	10.70	0.97	84340.20
22	9.34	3.39	64.44	1.73	17.46	10.59	0.97	83654.81
23	8.52	4.91	45.37	1.56	18.07	10.40	0.97	84966.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.48	3.93	49.89	2.35	18.08	10.35	0.97	85205.49
最大值	12.26	13.06	64.44	6.54	20.64	11.22	1.12	90033.95
發生時間	6	6	22	6	2	0		6
最小值	0.07	1.60	35.86	1.16	15.52	9.48	0.94	76824.41
發生時間	0	2	5	0	21	2		0
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.01 %		0.00		-0.20 %
全幅偏移(率)	0.04 %	-0.52 %	-0.23 %	0.11 %		-0.23		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.89	8.01	51.34	1.36	16.89	10.77	1.02	81559.02
1	1.72	5.78	54.95	1.36	16.86	11.25	1.02	76298.00
2	2.09	6.05	54.34	1.30	16.83	11.17	1.02	77161.54
3	7.72	8.65	54.83	2.04	15.57	11.04	1.02	77267.70
4	6.45	5.26	44.45	1.68	16.38	10.64	1.01	76174.91
5	3.83	5.49	50.02	1.20	17.29	10.82	1.01	74469.98
6	4.59	6.93	45.82	1.37	17.05	10.51	1.02	79650.21
7	3.36	5.21	50.19	1.63	16.29	10.78	1.02	76173.65
8	7.09	3.15	51.74	1.43	17.05	10.93	1.03	78402.29
9	5.14	3.43	44.71	1.19	17.79	10.52	1.03	80166.35
10	3.11	3.28	46.90	1.07	17.72	10.49	1.03	79946.26
11	2.97	3.23	47.38	1.21	16.76	10.73	1.02	79952.38
12	2.44	3.38	50.87	1.63	15.26	11.15	0.99	77405.33
13	3.48	3.42	50.18	1.64	15.59	11.10	1.00	76663.05
14	9.08	4.04	47.44	1.87	16.08	10.71	1.01	79004.11
15	6.52	6.50	45.36	2.17	14.95	11.09	1.02	76661.68
16	5.30	3.18	52.30	1.25	16.92	10.81	1.03	80854.55
17	6.00	3.55	53.80	1.51	15.82	11.12	1.05	80522.25
18	4.64	4.07	56.62	1.92	14.68	11.29	1.02	77864.32
19	5.18	3.79	57.40	1.87	14.99	11.21	1.02	79261.63
20	5.93	10.53	58.07	1.48	16.01	11.32	1.02	78195.68
21	8.14	9.24	54.50	2.06	15.09	11.29	1.00	77200.65
22	7.05	6.47	52.96	2.07	14.88	11.36	1.00	76420.44
23	6.06	6.73	54.98	1.44	16.46	11.12	1.02	79773.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.20	5.39	51.30	1.57	16.22	10.97	1.02	78210.41
最大值	9.08	10.53	58.07	2.17	17.79	11.36	1.05	81559.02
發生時間	14	20	20	15	9	22		0
最小值	1.72	3.15	44.45	1.07	14.68	10.49	0.99	74469.98
發生時間	1	8	4	10	18	10		5
零點偏移(率)	-0.01 %	-0.04 %	-0.03 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.00 %	0.25 %	-0.38 %	0.11 %		0.23		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								