

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.96	5.43	34.00	1.56	19.65	8.98	1.33	87391.97
1	3.36	6.13	35.90	1.59	18.91	9.52	1.31	84559.45
2	6.54	1.66	55.66	2.21	17.79	9.97	1.33	84141.95
3	9.67	1.99	50.43	2.11	18.87	9.64	1.36	91674.89
4	5.45	2.24	56.34	1.90	18.24	10.15	1.34	87286.77
5	8.93	2.80	56.86	1.99	19.10	9.97	1.33	87515.77
6	9.13	3.41	43.73	2.18	19.54	9.62	1.35	85330.57
7	6.68	2.50	49.86	1.40	19.90	9.65	1.35	89580.27
8	2.64	2.51	53.09	0.91	20.34	9.51	1.38	87757.74
9	2.25	3.77	40.10	1.19	18.96	9.79	1.37	86480.76
10	8.68	4.00	53.98	2.28	16.64	10.08	1.36	85098.00
11	6.26	6.31	60.72	3.94	17.03	10.49	1.36	83093.74
12	5.60	1.90	49.77	1.74	18.81	10.15	1.36	83535.42
13	5.44	2.74	47.84	1.91	18.52	9.96	1.38	86567.52
14	10.18	2.70	56.90	2.21	18.55	9.92	1.37	88475.46
15	5.87	4.68	59.86	1.51	18.92	10.01	1.37	87326.64
16	9.77	3.46	51.21	2.26	18.84	9.70	1.36	88913.13
17	10.21	1.54	58.98	2.34	17.31	10.12	1.37	87341.66
18	10.05	2.36	53.00	2.04	19.83	9.47	1.38	88838.34
19	9.25	3.07	50.42	1.91	19.47	9.47	1.38	91500.79
20	9.18	1.73	56.44	1.59	19.68	9.77	1.38	88313.02
21	8.76	1.78	57.48	2.15	17.71	10.55	1.39	84580.38
22	10.06	3.01	48.87	1.67	19.86	9.68	1.38	89163.11
23	8.85	3.51	48.02	2.00	18.06	10.08	1.38	87407.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.41	3.13	51.23	1.94	18.77	9.84	1.36	87161.46
最大值	10.21	6.31	60.72	3.94	20.34	10.55	1.39	91674.89
發生時間	17	11	11	11	8	21		3
最小值	2.25	1.54	34.00	0.91	16.64	8.98	1.30	83093.74
發生時間	9	17	0	8	10	0		11
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.09 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.37 %	-0.01 %	-0.75 %	0.27 %		-0.07	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.17	3.95	53.81	2.82	18.26	9.87	1.37	84402.57
1	6.94	9.16	48.85	2.84	19.04	9.60	1.38	84037.30
2	8.83	6.04	42.67	2.74	16.58	10.10	1.37	81617.21
3	6.12	2.32	57.22	2.99	17.59	10.09	1.38	83207.56
4	8.71	2.72	58.24	3.34	15.69	10.58	1.38	81510.70
5	7.71	1.99	59.51	3.27	17.21	10.05	1.38	83856.61
6	5.78	3.38	55.65	2.87	17.39	10.32	1.38	81437.01
7	8.82	5.03	53.20	3.32	17.69	9.64	1.38	94618.95
8	6.67	3.74	56.38	2.83	17.10	10.33	1.38	84954.81
9	4.71	3.07	61.69	2.86	16.59	10.56	1.38	84636.80
10	9.63	3.28	63.25	3.21	16.98	10.35	1.38	89338.95
11	9.03	2.83	61.03	3.42	16.25	10.58	1.38	86946.91
12	7.45	3.53	54.58	3.44	17.01	10.17	1.40	88152.08
13	7.30	3.84	60.38	3.28	15.71	10.61	1.40	85789.08
14	8.84	3.00	64.82	3.32	16.70	10.49	1.39	85955.80
15	9.31	2.87	58.68	3.27	17.21	10.48	1.39	86310.62
16	7.87	2.47	65.63	3.03	16.66	10.81	1.38	80525.03
17	9.89	4.69	49.94	3.27	16.67	10.08	1.37	85212.43
18	10.88	3.09	61.93	3.37	16.62	10.36	1.38	85171.82
19	9.27	3.20	53.05	3.09	17.04	10.55	1.38	86700.20
20	9.04	2.74	50.14	3.06	17.98	10.25	1.38	86065.45
21	8.29	7.44	46.48	2.98	16.97	10.26	1.38	87101.30
22	8.36	2.97	57.88	3.08	17.35	10.30	1.38	86889.60
23	10.23	4.24	67.27	3.33	16.59	10.42	1.38	87532.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.16	3.82	56.76	3.13	17.04	10.29	1.38	85498.80
最大值	10.88	9.16	67.27	3.44	19.04	10.81	1.41	94618.95
發生時間	18	1	23	12	1	16		7
最小值	4.71	1.99	42.67	2.74	15.69	9.60	1.36	80525.03
發生時間	9	5	2	2	4	1		16
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.09 %		0.00	0.00	0.00 %
全幅偏移(率)	0.94 %	0.53 %	-1.00 %	0.28 %		0.03	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								