

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月23日

報表日期: 114年04月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.43	4.27	49.84	0.75	18.03	10.73	1.33	79463.18
1	3.15	3.21	66.15	0.41	20.12	10.76	1.31	77636.85
2	5.40	6.54	62.08	0.51	20.12	9.87	1.30	84053.51
3	8.17	2.58	48.56	0.82	18.88	10.20	1.32	81767.00
4	8.73	1.19	47.38	1.11	17.93	10.42	1.34	79312.39
5	11.47	4.42	44.49	0.80	18.50	10.03	1.32	81606.56
6	9.09	4.41	41.80	0.83	18.31	10.37	1.31	79894.05
7	8.92	2.36	44.61	1.16	17.67	10.74	1.31	78943.12
8	8.63	4.63	38.78	1.42	17.05	11.00	1.31	74435.31
9	9.72	1.83	55.42	1.21	17.30	11.36	1.32	75528.33
10	6.31	2.06	50.12	1.20	17.10	11.05	1.33	77028.05
11	9.78	6.58	41.13	2.13	15.30	10.46	1.32	78207.53
12	12.67	5.09	38.34	2.16	15.85	10.54	1.34	76893.92
13	8.13	5.96	38.22	2.29	15.42	10.80	1.34	75399.86
14	9.90	7.10	37.32	1.92	15.65	10.81	1.31	76943.78
15	9.26	3.97	37.17	1.34	17.17	10.64	1.29	78663.22
16	8.26	5.46	44.08	1.30	16.71	10.48	1.32	80607.57
17	9.48	9.27	37.13	1.83	16.05	10.60	1.34	80000.59
18	7.09	6.67	38.35	1.14	16.87	10.57	1.34	79528.69
19	6.97	4.55	46.00	0.59	18.22	10.53	1.34	78650.55
20	8.53	8.64	43.99	0.84	19.07	9.90	1.34	81206.74
21	7.59	3.33	40.80	0.79	18.27	10.09	1.33	79716.84
22	10.54	3.54	37.84	1.05	17.66	10.51	1.32	81145.73
23	9.32	3.79	46.81	0.60	18.31	10.70	1.34	80556.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.52	4.64	44.85	1.18	17.57	10.55	1.32	79049.57
最 大 值	12.67	9.27	66.15	2.29	20.12	11.36	1.35	84053.51
發生時間	12	17	1	13	1	9		2
最 小 值	3.15	1.19	37.13	0.41	15.30	9.87	1.29	74435.31
發生時間	1	4	17	1	11	2		8
零點偏移(率)	-0.09 %	0.01 %	-0.01 %	0.00 %		-0.06		0.20 %
全幅偏移(率)	0.00 %	1.07 %	-0.45 %	1.10 %		0.00		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月23日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.88	2.01	66.30	2.42	15.94	10.77	1.04	83318.02
1	11.42	4.63	66.44	3.40	15.71	11.02	1.04	82082.65
2	6.77	4.65	64.06	1.64	18.46	10.10	1.05	81071.29
3	6.01	5.24	63.81	1.14	18.83	9.68	1.06	80074.71
4	9.75	7.31	65.81	2.27	17.24	10.50	1.06	84933.58
5	7.08	3.41	61.21	1.93	16.66	10.33	1.06	82631.01
6	10.43	2.45	60.77	1.58	16.63	10.26	1.04	83811.12
7	12.82	3.23	58.33	3.45	14.83	11.13	1.03	74991.70
8	10.61	1.24	50.55	2.64	16.30	10.31	1.04	82538.11
9	11.14	4.28	54.39	4.97	15.43	10.64	1.02	74915.57
10	6.60	2.37	47.41	3.21	16.24	10.11	1.03	77292.89
11	8.75	3.03	50.67	2.60	15.22	10.41	1.05	81229.05
12	7.60	3.14	52.60	2.98	14.58	10.61	1.06	78902.19
13	9.71	1.96	56.54	2.40	15.89	10.90	1.05	80105.30
14	8.27	4.69	51.12	3.36	14.63	10.67	1.04	82182.07
15	9.77	2.89	51.52	4.35	14.77	10.30	1.04	82157.03
16	9.11	2.70	58.86	3.27	15.05	10.62	1.05	84246.75
17	10.03	1.89	69.25	2.32	16.67	10.42	1.06	87528.14
18	9.56	4.56	53.99	1.89	17.74	10.11	1.05	88036.04
19	10.16	5.57	54.14	2.13	17.74	10.10	1.05	87968.29
20	9.34	4.21	53.51	2.42	17.27	10.06	1.05	89488.68
21	11.97	2.70	55.05	2.77	16.38	10.34	1.05	88361.61
22	9.41	2.56	53.53	2.94	15.80	10.92	1.05	82089.52
23	10.56	3.73	51.22	2.76	15.27	10.64	1.04	82077.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.53	3.52	57.13	2.70	16.22	10.46	1.05	82584.68
最 大 值	12.82	7.31	69.25	4.97	18.83	11.13	1.07	89488.68
發生時間	7	4	17	9	3	7		20
最 小 值	6.01	1.24	47.41	1.14	14.58	9.68	1.02	74915.57
發生時間	3	8	10	3	12	3		9
零點偏移(率)	-0.08 %	-0.04 %	-0.02 %	0.00 %		-0.03		0.00 %
全幅偏移(率)	0.06 %	0.29 %	-0.10 %	0.49 %		-0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月23日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.70	2.37	57.37	2.13	16.63	9.92	1.57	82633.77
1	7.17	5.68	59.73	1.69	19.25	9.58	1.58	85020.42
2	6.54	7.15	56.52	1.87	18.83	9.59	1.56	87575.76
3	6.25	4.07	56.91	1.66	19.02	9.50	1.52	87922.03
4	7.56	5.61	57.20	1.64	18.96	9.39	1.52	85692.57
5	7.90	8.34	50.25	1.84	17.68	9.40	1.52	81652.49
6	11.21	4.23	52.58	2.20	17.92	9.46	1.53	82891.69
7	1.29	6.86	52.48	2.03	15.68	10.94	1.51	77264.90
8	8.80	8.76	47.92	2.18	16.56	9.63	1.51	81490.16
9	9.87	2.32	55.50	2.43	15.12	10.65	1.48	73455.23
10	8.29	13.07	46.47	2.37	18.56	9.24	1.49	78261.00
11	8.04	5.99	52.12	2.33	16.22	9.76	1.51	78146.01
12	6.30	3.08	51.17	2.55	14.78	10.03	1.49	72878.91
13	7.88	1.21	48.44	1.93	15.55	9.84	1.52	76489.31
14	5.37	1.26	53.21	2.16	15.34	10.00	1.53	75239.22
15	9.79	9.30	45.95	2.77	16.76	9.10	1.52	81086.53
16	10.68	5.98	54.78	3.85	13.80	10.16	1.50	78071.87
17	10.31	3.14	54.35	2.64	15.43	10.07	1.48	78120.48
18	10.63	4.16	57.82	2.79	15.62	9.89	1.51	78162.12
19	10.62	7.17	52.92	2.36	16.29	9.70	1.51	80077.51
20	7.68	2.19	50.86	1.83	17.98	9.03	1.51	81332.21
21	6.82	1.63	59.53	1.70	16.87	9.79	1.51	82270.09
22	5.96	2.09	61.37	1.72	16.73	10.32	1.49	82404.25
23	7.45	2.27	59.69	2.01	16.47	10.34	1.50	84666.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.13	4.91	53.96	2.20	16.75	9.81	1.51	80533.53
最 大 值	12.70	13.07	61.37	3.85	19.25	10.94	1.60	87922.03
發生時間	0	10	22	16	1	7		3
最 小 值	1.29	1.21	45.95	1.64	13.80	9.03	1.48	72878.91
發生時間	7	13	15	4	16	20		12
零點偏移(率)	-0.01 %	-0.03 %	-0.02 %	0.00 %		0.04		-0.10 %
全幅偏移(率)	0.02 %	0.20 %	-0.42 %	0.02 %		0.19		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								