

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年08月05日

報表日期: 113年08月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.89	4.91	55.34	0.35	21.21	10.25	0.98	85656.89
1	6.21	6.83	43.51	1.38	19.55	10.53	0.99	83234.65
2	14.22	6.32	46.48	2.86	18.59	11.45	0.99	78560.39
3	5.73	1.69	48.70	1.23	18.69	11.39	0.99	79235.85
4	4.54	5.44	60.01	1.39	18.50	11.59	0.98	79824.45
5	8.97	4.59	60.71	1.57	18.02	11.39	0.97	77274.45
6	9.61	5.65	50.96	1.55	19.12	11.10	0.97	82914.12
7	9.81	4.98	59.00	1.81	18.34	11.12	0.97	84556.32
8	8.34	4.06	57.98	2.38	15.88	11.47	0.98	82140.22
9	8.74	4.48	50.25	2.60	16.74	11.55	0.97	79488.41
10	3.89	5.00	54.65	1.10	17.65	11.18	0.99	80525.41
11	3.17	4.01	58.01	1.51	16.17	11.35	0.98	77744.80
12	1.49	6.47	37.57	2.32	14.85	11.71	0.97	73822.88
13	1.11	1.87	47.46	0.94	17.66	11.15	0.97	77171.31
14	0.70	1.95	66.51	0.60	18.04	11.23	0.97	80981.95
15	1.45	1.84	46.96	1.31	16.35	12.01	0.97	78104.29
16	1.02	5.70	49.94	1.82	16.41	12.00	0.97	77995.43
17	4.07	1.83	49.62	1.73	17.57	11.41	0.97	81540.37
18	4.26	2.93	47.85	1.34	17.82	10.96	0.97	81633.11
19	5.91	3.05	49.16	1.28	18.02	10.89	0.97	82047.10
20	8.59	3.43	45.48	1.61	18.01	10.99	0.98	82860.80
21	8.07	2.79	56.34	1.15	18.67	10.97	0.97	82305.93
22	9.43	2.90	53.45	1.81	16.83	11.52	0.97	80270.83
23	10.16	4.46	64.64	1.63	17.08	12.27	0.97	73583.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.85	4.05	52.52	1.55	17.74	11.31	0.98	80144.74
最 大 值	14.22	6.83	66.51	2.86	21.21	12.27	1.00	85656.89
發生時間	2	1	14	2	0	23		0
最 小 值	0.70	1.69	37.57	0.35	14.85	10.25	0.94	73583.68
發生時間	14	3	12	0	12	0		23
零點偏移(率)	-0.04 %	-0.00 %	-0.01 %	-0.01 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	-0.03 %	-0.40 %	0.11 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月05日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.87	2.36	45.70	1.60	16.99	10.86	0.97	82657.73
1	7.99	2.83	44.14	1.88	17.07	11.36	0.97	78125.55
2	6.12	2.24	51.32	0.56	20.30	10.39	0.96	83060.68
3	6.26	5.39	41.14	0.56	20.44	10.18	0.94	84766.10
4	8.26	2.40	52.22	1.69	18.24	10.84	0.95	81678.28
5	8.55	2.64	60.45	1.31	17.14	10.90	0.96	82569.72
6	10.41	3.89	44.56	2.46	17.67	10.86	0.95	80553.04
7	8.50	1.76	59.33	1.66	16.92	10.98	0.95	81549.29
8	9.88	2.25	42.18	1.76	16.74	10.93	0.96	83907.86
9	8.69	8.33	60.54	2.64	16.48	11.02	0.98	82977.21
10	7.26	7.63	56.08	3.53	14.04	11.46	1.00	80726.17
11	8.06	6.51	44.19	3.93	14.65	11.41	0.99	79995.87
12	0.19	2.17	54.49	3.23	15.08	12.06	0.99	73990.90
13	3.99	1.26	63.05	1.60	18.05	10.62	0.98	84139.09
14	4.40	1.35	50.00	2.42	16.32	11.03	0.97	81398.04
15	6.71	3.33	53.70	1.99	16.91	10.83	0.97	82237.40
16	9.57	7.11	39.05	3.57	14.82	11.38	0.97	78365.92
17	5.96	2.11	46.20	3.52	14.97	11.54	0.97	78184.60
18	9.93	1.71	44.62	3.00	15.64	10.78	0.99	83168.15
19	9.66	2.23	54.39	2.80	15.41	11.13	0.99	81343.29
20	9.26	2.26	60.50	2.10	17.37	10.41	0.99	85381.89
21	11.50	1.69	51.08	2.62	15.60	10.96	0.97	83033.73
22	8.81	2.27	52.56	2.76	15.43	11.14	0.97	79998.66
23	8.88	1.90	55.51	2.25	15.66	11.20	0.97	79795.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.82	3.23	51.13	2.31	16.58	11.01	0.97	81400.18
最 大 值	11.50	8.33	63.05	3.93	20.44	12.06	1.01	85381.89
發生時間	21	9	13	11	3	12		20
最 小 值	0.19	1.26	39.05	0.56	14.04	10.18	0.93	73990.90
發生時間	12	13	16	2	10	3		12
零點偏移(率)	-2.34 %	-0.20 %	-0.04 %	-0.02 %		-0.04		-0.10 %
全幅偏移(率)	0.07 %	0.13 %	-0.06 %	0.04 %		0.09		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	4.43	4.76	51.48	1.07	17.74	10.62	0.92	79582.79
1	2.10	3.81	53.75	0.86	18.19	10.95	0.92	76991.06
2	4.65	4.15	48.34	1.26	17.77	10.64	0.91	80379.08
3	9.61	3.41	51.68	1.91	17.40	10.34	0.89	79966.65
4	5.53	4.07	44.73	1.23	16.94	10.64	0.88	78280.29
5	6.20	3.49	45.73	1.92	15.64	10.79	0.88	76019.18
6	5.73	3.16	50.78	2.09	14.89	11.20	0.87	72977.54
7	7.05	4.26	56.17	1.74	16.25	10.81	0.88	73957.04
8	9.67	3.38	58.21	2.09	14.96	11.22	0.90	75580.86
9	8.20	3.52	52.06	2.07	14.84	11.12	0.92	74370.70
10	8.21	3.23	50.34	1.93	14.79	11.08	0.90	73722.86
11	4.98	3.81	44.91	1.42	15.62	10.68	0.88	72197.30
12	1.46	4.21	41.66	1.60	14.34	10.89	0.88	69834.06
13	0.55	4.10	46.12	1.42	14.62	10.87	0.88	70394.35
14	0.18	4.97	45.80	1.99	13.76	11.08	0.87	70173.80
15	2.51	4.16	47.12	1.47	15.22	10.71	0.86	72772.30
16	2.50	3.45	51.10	1.17	15.92	10.60	0.88	74102.90
17	2.51	3.37	52.28	1.19	15.70	10.84	0.91	74610.64
18	5.85	3.36	53.01	1.12	16.88	10.44	0.90	79157.85
19	4.84	3.20	53.43	1.16	16.68	10.53	0.88	82135.96
20	9.09	3.24	51.26	1.22	16.49	10.62	0.88	81475.51
21	4.45	3.43	49.88	1.03	16.25	10.72	0.91	79988.58
22	1.05	3.39	55.33	0.89	16.17	11.14	0.92	76038.67
23	4.72	3.75	54.84	0.95	16.49	11.19	0.92	75689.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.84	3.74	50.42	1.45	15.98	10.82	0.89	75849.96
最 大 值	9.67	4.97	58.21	2.09	18.19	11.22	0.95	82135.96
發生時間	8	14	8	6	1	8		19
最 小 值	0.18	3.16	41.66	0.86	13.76	10.34	0.84	69834.06
發生時間	14	6	12	1	14	3		12
零點偏移(率)	-0.05 %	-0.02 %	-0.05 %	-0.02 %		-0.03		-0.10 %
全幅偏移(率)	0.02 %	-0.02 %	-0.28 %	0.21 %		0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								