

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.80	13.94	46.93	1.96	18.74	11.29	1.05	80767.02
1	10.10	14.90	52.39	2.11	18.64	11.58	1.03	78991.37
2	10.36	12.30	53.46	1.90	19.03	11.03	1.02	83721.26
3	9.54	10.42	52.46	1.93	17.12	11.26	1.03	83306.92
4	9.95	7.64	43.34	2.27	17.61	10.73	1.03	85506.94
5	7.82	10.79	69.70	0.80	19.77	11.11	1.06	76891.01
6	10.51	11.69	49.24	1.40	18.80	11.04	1.07	82991.18
7	13.76	13.74	44.61	1.62	19.45	10.40	1.08	86886.25
8	7.87	10.76	43.03	1.90	16.54	11.61	1.06	78853.34
9	5.20	8.27	70.02	0.84	18.37	11.94	1.08	75093.80
10	5.92	8.43	41.00	1.67	17.06	11.38	1.07	80023.96
11	2.62	9.30	55.97	1.19	17.50	12.06	1.06	74072.21
12	6.69	7.74	58.89	0.88	18.22	11.71	1.07	77200.70
13	3.31	8.52	50.85	1.03	17.69	11.73	1.07	77206.92
14	4.54	9.41	48.37	1.56	17.29	11.56	1.07	78543.32
15	8.88	9.48	47.44	1.80	17.12	11.54	1.07	78539.07
16	8.63	8.59	47.68	1.65	17.42	11.50	1.07	78524.18
17	9.75	8.29	48.91	1.74	17.48	11.33	1.07	80819.16
18	9.02	9.29	51.99	1.74	17.81	11.31	1.07	80679.36
19	9.57	11.92	52.19	1.28	18.31	11.30	1.06	80976.38
20	9.98	13.26	46.75	1.66	17.14	11.31	1.08	81377.83
21	8.32	12.81	50.09	1.16	18.13	11.38	1.09	80551.41
22	6.54	13.30	61.45	0.80	18.77	10.85	1.09	85256.85
23	7.50	13.26	49.82	1.17	18.75	11.23	1.08	82100.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.17	10.75	51.52	1.50	18.03	11.34	1.06	80370.02
最大值	13.76	14.90	70.02	2.27	19.77	12.06	1.10	86886.25
發生時間	7	1	9	4	5	11		7
最小值	2.62	7.64	41.00	0.80	16.54	10.40	1.02	74072.21
發生時間	11	4	10	5	8	7		11
零點偏移(率)	-0.32 %	-0.01 %	-0.00 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	0.04 %	0.25 %	0.26 %	0.29 %		0.08		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.24	8.15	49.19	1.86	17.71	10.46	1.23	75568.43
1	10.81	7.45	53.23	1.65	19.47	9.96	1.23	80453.49
2	8.48	6.48	58.90	2.05	18.08	10.00	1.23	84410.60
3	9.73	6.70	49.87	2.18	17.09	9.84	1.23	81739.63
4	10.22	5.45	53.55	2.18	16.83	10.05	1.23	85004.05
5	9.92	11.04	44.87	2.55	16.39	10.22	1.23	79816.35
6	10.46	21.29	46.14	3.15	16.17	9.97	1.20	79334.00
7	9.12	8.42	48.53	1.61	18.20	9.59	1.21	78646.23
8	9.37	5.56	61.89	1.37	18.70	9.50	1.23	83444.59
9	8.98	10.12	60.56	2.29	16.43	10.05	1.22	82451.55
10	6.98	4.45	63.55	1.47	18.03	9.94	1.23	81749.07
11	9.21	7.01	53.82	1.98	16.56	10.29	1.23	80016.31
12	4.16	5.83	56.48	1.12	18.26	10.42	1.23	78317.67
13	3.53	4.46	51.96	1.33	17.76	9.89	1.23	82445.89
14	10.81	6.71	55.88	3.10	15.13	10.61	1.23	81128.74
15	8.91	8.93	56.88	2.35	16.44	10.42	1.23	82212.21
16	7.07	4.14	52.88	1.54	17.15	10.19	1.23	81610.43
17	7.85	5.64	49.82	1.74	16.98	10.29	1.23	82677.15
18	4.23	4.91	56.32	1.50	17.03	10.68	1.23	79041.26
19	0.26	4.86	62.09	1.21	18.30	10.70	1.22	76315.78
20	1.54	7.31	44.30	1.57	18.04	9.80	1.20	84844.06
21	4.72	4.14	57.95	2.17	16.79	10.32	1.21	80557.35
22	7.90	6.77	46.74	1.53	18.61	9.61	1.20	86103.84
23	9.27	7.64	52.85	2.03	17.33	10.11	1.20	83215.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.53	7.23	53.68	1.90	17.40	10.12	1.22	81296.02
最大值	10.81	21.29	63.55	3.15	19.47	10.70	1.24	86103.84
發生時間	1	6	10	6	1	19		22
最小值	0.26	4.14	44.30	1.12	15.13	9.50	1.20	75568.43
發生時間	19	16	20	12	14	8		0
零點偏移(率)	-0.05 %	-0.01 %	-0.26 %	-0.01 %		0.03		0.00 %
全幅偏移(率)	0.16 %	-0.24 %	0.94 %	0.12 %		0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.97	10.40	48.50	1.19	17.07	10.58	1.01	77017.12
1	4.77	10.04	55.32	1.27	17.05	10.93	0.99	75466.93
2	8.32	9.60	58.43	1.95	16.35	10.82	0.99	76037.91
3	5.96	8.32	44.91	1.27	19.28	9.99	0.99	81831.00
4	9.97	7.91	43.04	1.33	18.36	10.25	1.01	83722.98
5	7.96	9.33	44.96	1.25	17.90	10.38	1.00	81741.28
6	4.84	12.09	52.53	1.38	16.94	10.36	1.02	78246.84
7	0.83	9.58	41.56	0.65	16.97	9.55	0.99	70536.55
8	1.15	7.60	48.56	0.82	17.08	9.91	1.00	77059.21
9	1.14	7.38	48.51	0.71	17.49	9.78	1.01	78298.11
10	1.62	8.43	51.95	1.05	15.77	9.77	0.99	79210.24
11	0.95	16.30	56.19	1.55	14.47	10.66	1.04	73320.67
12	0.28	3.27	55.93	1.34	15.03	11.19	1.02	76036.94
13	0.32	3.23	55.43	0.66	17.39	10.59	1.00	81536.04
14	0.59	3.09	49.77	0.93	15.52	10.89	0.99	76235.08
15	0.61	5.98	54.03	1.06	15.62	10.86	1.01	76044.86
16	0.60	6.01	60.14	1.16	15.20	10.87	1.01	75591.97
17	0.58	6.52	52.48	1.11	15.34	10.74	0.99	76640.96
18	0.58	6.57	53.76	1.33	14.67	10.79	1.01	75792.78
19	0.60	8.18	66.64	0.90	16.10	11.08	0.98	76098.54
20	0.56	6.87	46.78	0.69	16.83	10.27	1.01	78994.01
21	0.73	8.39	50.20	0.73	17.51	10.51	1.03	78713.22
22	0.59	8.85	53.04	0.71	17.80	10.54	1.03	81219.58
23	0.62	9.21	52.71	0.74	17.38	10.28	1.02	81732.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.42	8.05	51.89	1.07	16.63	10.48	1.01	77796.87
最大值	9.97	16.30	66.64	1.95	19.28	11.19	1.05	83722.98
發生時間	4	11	19	2	3	12		4
最小值	0.28	3.09	41.56	0.65	14.47	9.55	0.97	70536.55
發生時間	12	14	7	7	11	7		7
零點偏移(率)	-0.01 %	0.00 %	-0.13 %	-0.06 %		-0.01		0.00 %
全幅偏移(率)	-1.38 %	0.00 %	-0.63 %	0.42 %		0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								