

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.90	8.51	57.82	0.73	19.49	11.70	1.04	76506.36
1	7.71	7.94	55.23	0.97	19.85	11.02	1.04	81440.25
2	7.96	9.12	47.42	1.73	16.28	11.85	1.02	76931.02
3	5.39	7.52	61.98	1.07	17.25	11.73	1.02	77922.37
4	6.43	8.29	45.85	1.82	16.36	11.80	1.04	77709.96
5	6.79	10.32	47.01	2.52	15.51	11.63	1.04	81156.01
6	7.38	9.65	62.71	1.72	16.61	12.15	1.03	74635.83
7	8.53	10.26	51.91	2.24	16.26	11.60	1.02	78260.87
8	7.89	8.58	56.56	1.92	16.36	11.77	1.03	76947.39
9	8.36	9.07	51.46	2.46	15.56	11.95	1.05	76412.55
10	7.48	8.91	56.17	2.40	15.75	11.77	1.05	77194.17
11	7.71	8.53	54.52	2.19	16.26	11.80	1.03	77046.64
12	4.93	8.63	68.92	1.19	18.27	11.44	1.05	80054.52
13	9.58	10.61	49.07	2.61	15.63	11.85	1.04	78391.80
14	5.53	9.89	66.13	1.55	16.74	12.11	1.05	76306.52
15	6.03	14.74	55.29	2.59	15.40	12.60	1.03	72640.32
16	5.93	12.71	66.45	1.48	17.35	12.20	1.05	74485.42
17	9.24	11.22	32.13	2.26	16.00	12.04	1.05	76851.04
18	8.00	10.64	62.82	2.20	16.37	12.17	1.06	75066.36
19	6.30	15.21	64.43	1.09	19.03	11.39	1.06	79136.66
20	8.94	17.50	45.34	1.34	18.28	10.88	1.05	83008.23
21	8.57	4.46	55.39	2.14	15.23	12.23	1.05	74882.16
22	8.48	8.78	58.19	2.65	16.19	11.60	1.05	78537.82
23	3.34	2.38	69.73	0.87	17.76	11.87	1.06	76714.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.10	9.73	55.94	1.82	16.82	11.80	1.04	77426.63
最大值	9.58	17.50	69.73	2.65	19.85	12.60	1.10	83008.23
發生時間	13	20	23	22	1	15		20
最小值	3.34	2.38	32.13	0.73	15.23	10.88	1.02	72640.32
發生時間	23	23	17	0	21	20		15
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	-0.32 %	0.03 %	0.00 %	0.03 %		0.00		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.96	8.54	57.06	1.31	18.19	11.66	1.18	71878.61
1	0.83	9.11	52.70	1.36	18.37	11.69	1.18	71401.44
2	1.31	7.15	68.76	1.38	17.86	11.39	1.18	74261.03
3	0.74	8.36	61.30	1.24	17.47	11.51	1.18	74151.86
4	8.08	10.26	48.20	2.02	17.80	10.04	1.18	85445.76
5	8.66	5.98	55.53	2.60	15.63	10.63	1.18	80311.91
6	4.08	16.21	50.90	2.80	16.07	10.37	1.19	79020.36
7	9.81	6.98	57.94	2.48	17.06	10.35	1.19	82586.33
8	9.61	7.33	54.09	2.63	17.64	10.18	1.19	84100.93
9	8.31	14.21	55.75	2.28	17.35	10.14	1.18	84342.62
10	8.05	11.26	54.64	2.57	16.69	10.47	1.19	82141.56
11	8.21	13.64	58.99	2.30	17.28	10.21	1.20	81400.14
12	8.34	4.89	52.21	1.87	17.62	10.16	1.20	81681.33
13	6.68	16.81	47.70	2.51	16.53	10.17	1.19	78149.76
14	6.10	13.65	57.66	1.73	18.32	10.19	1.18	79740.71
15	6.10	3.43	58.96	1.45	18.43	10.34	1.18	78826.94
16	5.67	6.04	47.67	1.74	18.56	10.16	1.18	76939.67
17	5.19	11.05	39.40	1.50	18.92	9.73	1.18	79029.04
18	6.17	5.49	61.07	0.85	20.62	9.87	1.20	81604.30
19	9.73	10.39	50.89	1.36	20.07	9.25	1.20	87373.23
20	8.30	10.07	39.52	2.12	18.78	9.64	1.20	81726.77
21	8.50	6.99	45.11	1.79	18.90	9.82	1.20	83301.13
22	7.79	6.65	51.56	1.64	19.52	9.72	1.20	84548.03
23	10.49	13.08	56.48	2.87	16.81	10.35	1.18	82704.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.65	9.48	53.50	1.93	17.94	10.33	1.19	80277.84
最大值	10.49	16.81	68.76	2.87	20.62	11.69	1.21	87373.23
發生時間	23	13	2	23	18	1		19
最小值	0.74	3.43	39.40	0.85	15.63	9.25	1.18	71401.44
發生時間	3	15	17	18	5	19		1
零點偏移(率)	-0.69 %	-0.05 %	-0.04 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.01 %	-0.14 %	0.63 %		-0.33		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.88	7.41	64.89	0.70	16.91	10.61	0.99	81919.18
1	1.72	8.05	57.17	0.87	17.27	11.22	0.99	79957.03
2	3.24	7.37	58.45	0.85	17.07	10.96	0.99	82433.40
3	3.64	7.68	57.39	0.95	16.66	10.90	0.99	81494.50
4	2.48	9.34	57.64	0.86	16.34	11.01	0.99	76788.64
5	3.17	14.74	48.97	1.32	15.73	10.93	0.99	79949.40
6	3.66	13.56	53.97	1.76	14.65	11.05	0.99	75646.52
7	6.00	9.33	55.54	1.10	16.67	10.35	0.98	75306.91
8	4.96	11.90	52.15	1.36	15.14	10.96	1.03	75682.20
9	8.24	9.87	50.56	1.50	15.23	10.89	1.00	75909.26
10	5.81	8.63	51.90	1.12	16.08	10.66	1.02	77808.07
11	5.15	8.68	52.51	0.94	16.88	10.51	1.05	79170.27
12	4.65	9.77	53.25	1.13	16.00	10.90	1.05	75862.34
13	1.61	16.59	53.88	1.22	14.95	11.07	1.01	73660.47
14	2.92	9.51	58.16	1.01	15.53	11.41	1.00	71586.46
15	0.23	18.54	56.37	1.49	14.33	11.81	0.99	66555.42
16	0.01	20.10	63.34	0.80	16.73	11.05	0.97	69699.24
17	0.58	2.23	56.35	0.67	16.26	11.12	0.98	70772.91
18	4.74	17.89	51.41	1.11	16.78	10.78	0.99	73259.14
19	0.31	2.25	49.73	0.47	19.72	9.70	0.99	79891.72
20	3.93	7.14	58.71	0.85	18.01	9.90	0.99	80244.84
21	4.96	20.05	48.13	0.78	16.89	10.82	1.00	76605.91
22	1.81	4.05	63.48	0.50	17.45	10.89	1.02	78191.72
23	0.07	5.83	61.86	0.51	17.48	10.51	1.02	77583.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.24	10.44	55.66	0.99	16.45	10.83	1.00	76499.11
最大值	8.24	20.10	64.89	1.76	19.72	11.81	1.05	82433.40
發生時間	9	16	0	6	19	15		2
最小值	0.01	2.23	48.13	0.47	14.33	9.70	0.95	66555.42
發生時間	16	17	21	19	15	19		15
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	0.00 %		-0.10		0.00 %
全幅偏移(率)	0.04 %	0.60 %	-0.45 %	1.12 %		0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								