

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.39	11.81	55.72	2.81	16.78	11.43	1.29	72925.74
1	9.84	12.41	56.57	3.17	17.37	11.21	1.29	74208.04
2	4.75	12.34	50.41	2.92	17.81	11.46	1.28	71537.03
3	5.99	12.05	48.10	2.36	17.61	11.45	1.28	72354.47
4	3.46	12.36	45.20	2.28	17.44	11.42	1.29	73161.35
5	2.78	11.93	46.16	3.11	16.49	11.49	1.27	77913.89
6	2.22	11.83	50.64	2.21	17.21	11.51	1.27	72716.52
7	11.45	11.38	54.29	2.83	17.13	11.18	1.28	74953.20
8	9.88	11.54	60.47	1.74	18.68	11.12	1.28	73796.79
9	9.28	11.44	42.08	2.27	17.69	10.93	1.26	75376.09
10	9.26	12.02	57.01	1.12	19.67	11.28	1.27	71205.33
11	9.15	14.56	55.01	2.23	18.88	11.38	1.27	71116.50
12	9.31	13.76	51.22	3.21	17.07	11.73	1.27	68164.39
13	9.67	11.38	46.47	3.40	16.71	12.15	1.26	67355.05
14	9.62	10.94	53.93	3.20	16.12	12.18	1.26	67039.17
15	9.59	16.87	56.88	2.74	16.99	12.05	1.26	67383.50
16	9.20	14.29	52.88	2.51	16.86	11.65	1.25	69639.16
17	8.35	11.97	47.25	1.33	18.62	10.50	1.26	77833.39
18	8.73	12.32	49.61	2.10	17.46	11.13	1.27	73983.98
19	8.60	11.61	53.89	1.26	19.02	10.77	1.26	75505.82
20	11.09	12.19	48.09	2.59	18.26	11.04	1.25	76487.70
21	10.38	12.78	37.07	3.06	16.70	11.68	1.25	72447.21
22	10.68	11.75	51.68	1.93	18.68	11.09	1.25	74279.82
23	11.54	12.25	48.63	2.72	17.17	11.50	1.27	72425.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.34	12.41	50.80	2.46	17.60	11.39	1.27	72658.74
最大值	11.54	16.87	60.47	3.40	19.67	12.18	1.29	77913.89
發生時間	23	15	8	13	10	14		5
最小值	2.22	10.94	37.07	1.12	16.12	10.50	1.25	67039.17
發生時間	6	14	21	10	14	17		14
零點偏移(率)	-0.07 %	-0.01 %	-0.03 %	-0.01 %		-0.07	-0.01	0.20 %
全幅偏移(率)	1.39 %	-0.49 %	0.09 %	-0.07 %		-0.05	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.73	11.96	57.07	1.12	17.49	10.48	0.93	79769.65
1	8.28	11.74	44.50	1.54	17.16	10.29	0.92	77538.53
2	5.40	11.52	45.21	1.36	17.70	10.22	0.92	78578.00
3	6.46	11.77	52.19	1.05	18.02	10.20	0.92	82947.27
4	7.29	11.84	61.43	1.41	16.84	10.61	0.90	82896.72
5	7.61	12.28	63.29	1.03	17.59	10.71	0.90	82414.45
6	3.41	11.28	50.66	1.30	18.25	10.29	0.96	80692.17
7	6.93	11.51	63.39	1.68	17.03	11.19	1.01	76820.38
8	6.58	11.13	59.84	1.20	18.27	10.60	1.02	82054.42
9	7.15	10.83	59.91	1.14	18.33	10.50	1.01	83703.82
10	7.12	10.73	58.04	1.19	17.91	10.40	1.01	81841.67
11	7.69	11.02	43.80	1.75	17.03	10.64	1.02	79968.14
12	6.96	11.27	49.18	1.28	17.60	11.01	1.02	77664.18
13	6.41	11.50	47.25	1.58	16.93	10.99	1.02	78711.10
14	6.29	11.17	45.92	1.70	16.78	10.90	1.02	79399.88
15	6.20	11.15	50.09	2.17	16.68	10.99	1.02	79865.10
16	6.19	11.08	53.98	1.93	17.00	10.86	1.02	82846.18
17	7.52	12.28	54.72	2.81	15.25	11.05	1.02	83271.90
18	9.16	12.46	57.37	2.28	16.18	10.78	1.02	81754.97
19	9.17	11.79	55.67	1.10	18.11	10.34	1.01	82961.16
20	10.38	12.34	57.58	1.69	17.03	10.96	0.99	82735.32
21	8.51	12.78	51.97	1.36	17.71	10.81	0.99	82933.52
22	10.30	11.78	60.88	0.93	18.96	10.21	0.98	82611.92
23	10.06	11.64	49.71	1.04	19.51	9.98	0.98	82339.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.41	11.62	53.90	1.49	17.47	10.63	0.98	81096.67
最大值	10.38	12.78	63.39	2.81	19.51	11.19	1.04	83703.82
發生時間	20	21	7	17	23	7		9
最小值	3.41	10.73	43.80	0.93	15.25	9.98	0.90	76820.38
發生時間	6	10	11	22	17	23		7
零點偏移(率)	-0.11 %	-0.04 %	-0.04 %	-0.00 %		-0.08	-0.01	0.10 %
全幅偏移(率)	0.32 %	-0.55 %	0.64 %	-0.05 %		0.01	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.18	12.89	53.69	3.80	17.41	9.50	1.34	71125.44
1	6.50	11.37	53.41	3.29	17.50	9.70	1.34	71289.67
2	9.57	11.61	53.42	3.63	17.07	9.44	1.32	72656.35
3	8.21	11.31	59.01	3.80	17.76	9.71	1.31	72378.08
4	4.64	12.82	51.34	2.92	19.28	9.26	1.32	77997.86
5	9.22	11.18	54.66	2.30	17.97	9.90	1.35	76840.72
6	6.95	11.75	55.40	3.43	19.36	10.00	1.36	76412.30
7	7.09	10.13	55.78	3.84	18.64	9.55	1.36	75837.75
8	7.53	10.67	57.37	3.42	17.95	10.33	1.37	76960.81
9	8.52	12.67	41.50	3.36	20.33	8.86	1.36	79375.59
10	9.31	9.73	55.32	0.38	17.06	9.97	1.37	77751.45
11	8.71	10.28	60.74	0.33	18.10	9.89	1.35	77108.90
12	7.41	12.18	50.30	0.32	17.75	10.65	1.36	66023.25
13	9.24	10.33	48.28	0.31	18.00	9.69	1.36	72988.67
14	9.41	10.44	46.53	0.33	17.47	9.55	1.36	73644.55
15	8.25	11.88	43.43	0.33	16.32	9.42	1.36	72174.37
16	9.21	12.34	43.44	0.51	17.75	8.75	1.36	73842.93
17	9.11	11.62	38.64	1.70	18.67	8.36	1.35	73154.21
18	5.90	10.94	45.83	1.28	18.11	8.82	1.31	70822.58
19	8.78	12.01	49.53	1.34	19.47	8.46	1.35	72410.21
20	9.89	11.26	48.82	1.38	18.90	8.75	1.31	71083.46
21	5.90	11.05	45.89	1.34	17.72	8.80	1.32	70770.41
22	7.22	11.28	50.54	2.51	17.81	9.09	1.36	70386.97
23	8.64	11.49	46.58	2.94	18.75	9.30	1.36	72386.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.10	11.38	50.39	2.03	18.13	9.41	1.35	73559.30
最大值	9.89	12.89	60.74	3.84	20.33	10.65	1.41	79375.59
發生時間	20	0	11	7	9	12		9
最小值	4.64	9.73	38.64	0.31	16.32	8.36	1.30	66023.25
發生時間	4	10	17	13	15	17		12
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	0.00 %		-0.11	-0.01	-0.10 %
全幅偏移(率)	2.20 %	-0.52 %	-0.23 %	0.02 %		0.28	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								