

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.42	11.96	55.23	1.45	16.40	11.39	1.18	80919.63
1	9.26	11.64	53.08	1.58	16.82	11.33	1.18	81125.09
2	9.23	11.58	49.95	1.85	15.67	11.42	1.18	82234.22
3	11.08	11.60	55.41	1.91	15.25	11.56	1.18	81434.32
4	9.25	12.04	56.95	2.07	14.44	11.73	1.18	80610.34
5	11.43	12.36	53.10	2.67	14.26	11.65	1.18	78525.13
6	8.26	12.39	54.15	2.12	14.10	11.78	1.18	80669.38
7	7.94	12.00	54.30	1.60	15.05	11.73	1.18	79812.52
8	9.22	11.49	55.12	2.29	15.43	11.39	1.18	80751.78
9	10.09	11.05	57.43	2.30	16.35	11.00	1.18	82638.21
10	12.23	11.63	53.91	2.80	15.53	11.45	1.18	80007.93
11	7.43	11.97	56.35	2.63	14.10	11.99	無效	77230.83
12	10.43	11.86	52.46	2.63	14.73	11.62	1.20	79882.39
13	10.86	11.78	60.31	2.74	14.26	11.75	1.18	78975.64
14	10.06	11.54	61.90	3.01	14.82	11.56	1.20	80255.63
15	7.93	11.90	55.38	2.29	14.78	11.71	1.18	78472.36
16	14.94	11.83	47.89	2.38	16.08	11.37	1.18	79894.53
17	5.90	11.59	58.24	1.32	17.05	11.06	1.19	81468.54
18	9.23	11.47	54.39	1.78	16.13	11.14	1.19	81818.79
19	8.27	11.55	53.95	2.06	14.78	11.60	1.18	78949.84
20	13.88	12.53	52.54	2.51	14.58	11.60	1.18	79483.13
21	6.14	12.70	52.49	2.80	12.78	11.83	1.19	79062.72
22	13.11	13.03	49.23	2.94	13.61	11.72	1.18	78696.82
23	6.90	11.78	44.54	2.17	14.21	11.54	1.18	79423.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	23	24
平均值	9.69	11.89	54.10	2.25	15.05	11.54	1.18	80097.64
最大值	14.94	13.03	61.90	3.01	17.05	11.99	1.20	82638.21
發生時間	16	22	14	14	17	11		9
最小值	5.90	11.05	44.54	1.32	12.78	11.00	1.17	77230.83
發生時間	17	9	23	17	21	9		11
零點偏移(率)	-0.08 %	-0.00 %	-0.00 %	-0.00 %		-0.01	-0.01	0.00 %
全幅偏移(率)	-1.24 %	-0.62 %	1.81 %	-0.36 %		-0.06	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.22	11.94	50.93	0.74	19.04	10.15	0.98	83555.10
1	9.76	11.97	49.89	1.32	18.53	10.50	0.98	82239.39
2	8.89	12.81	44.05	1.37	18.21	10.35	0.97	82310.48
3	8.61	11.99	46.67	1.77	17.49	10.56	0.97	79451.14
4	9.73	11.74	48.10	2.20	17.71	10.23	0.96	81239.89
5	9.82	11.78	54.23	1.84	17.62	10.43	0.97	82939.06
6	13.48	11.90	53.11	2.63	17.16	10.67	0.99	81522.64
7	7.05	11.46	50.52	1.97	17.65	10.21	0.99	81596.62
8	11.27	11.61	56.37	1.61	17.95	10.34	1.00	81423.92
9	6.59	11.64	50.11	1.79	17.69	10.37	1.00	80725.56
10	14.04	11.69	52.82	1.77	16.68	10.55	1.00	78965.31
11	3.55	12.44	49.02	1.95	15.93	10.89	無效	76767.76
12	11.87	12.10	55.16	2.23	15.75	10.95	0.98	75649.67
13	7.50	11.78	59.32	1.97	16.28	10.68	0.99	78234.98
14	10.68	11.56	47.95	2.11	16.84	10.34	0.97	77264.02
15	7.69	11.76	56.88	1.58	16.92	10.52	0.96	78166.86
16	12.03	11.58	47.43	1.51	17.23	10.37	0.97	79069.86
17	4.95	12.11	45.72	1.60	17.96	10.21	0.98	79203.74
18	6.87	11.35	47.28	0.96	18.27	9.96	0.99	78533.79
19	9.73	12.36	43.16	2.04	16.70	10.29	0.96	76575.97
20	10.42	12.35	49.31	2.51	14.90	10.84	0.95	75787.84
21	8.17	12.64	50.06	2.55	15.35	10.68	0.96	75954.81
22	9.04	11.82	53.15	1.48	16.40	10.66	0.95	77493.40
23	9.48	11.98	54.12	1.94	15.62	10.49	0.96	79055.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	23	24
平均值	9.10	11.93	50.64	1.81	17.08	10.47	0.97	79321.97
最大值	14.04	12.81	59.32	2.63	19.04	10.95	1.02	83555.10
發生時間	10	2	13	6	0	12		0
最小值	3.55	11.35	43.16	0.74	14.90	9.96	0.94	75649.67
發生時間	11	18	19	0	20	18		12
零點偏移(率)	-0.04 %	0.00 %	-0.03 %	0.00 %		0.00	-0.01	-0.20 %
全幅偏移(率)	0.15 %	-1.45 %	1.36 %	-0.10 %		0.07	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.52	11.04	60.33	3.00	19.65	9.36	1.31	75982.69
1	4.94	11.52	59.15	2.98	19.26	9.98	1.28	74947.64
2	4.17	11.18	47.27	2.82	18.76	9.72	1.31	75016.86
3	3.78	11.25	51.41	2.64	17.26	9.75	1.31	74480.65
4	3.05	11.29	55.31	2.79	16.49	9.80	1.31	75007.21
5	2.57	11.81	55.33	2.83	16.07	10.03	1.31	74952.16
6	2.59	11.43	63.16	2.74	17.03	10.23	1.31	74606.32
7	2.96	11.20	56.07	2.95	17.62	9.94	1.33	75341.80
8	2.14	11.30	51.89	2.67	17.90	9.75	1.30	74980.47
9	2.87	11.05	46.77	2.56	18.30	9.49	1.32	74227.77
10	2.60	11.07	45.14	2.58	17.87	9.56	1.29	73617.74
11	2.75	11.39	41.17	2.57	17.64	9.41	無效	72623.73
12	2.30	11.29	55.01	2.83	19.22	9.32	1.31	72909.20
13	2.29	11.61	50.32	2.65	17.36	9.28	1.28	73707.85
14	3.70	11.60	39.61	2.53	17.84	9.13	1.27	73431.22
15	3.45	10.87	44.02	2.48	17.95	9.19	1.27	72514.98
16	2.97	10.94	46.63	2.61	18.55	9.09	1.28	72002.28
17	5.36	11.55	44.16	2.88	17.02	9.42	1.27	72975.04
18	3.26	12.63	39.82	2.47	19.10	9.06	1.27	74772.82
19	2.82	11.60	37.27	2.23	17.89	9.11	1.29	72261.79
20	4.25	12.78	36.02	1.80	17.13	9.03	1.27	71674.71
21	2.28	11.80	39.36	0.27	17.29	9.64	1.26	65142.39
22	6.31	11.95	32.90	0.26	16.58	9.05	1.28	69527.74
23	7.76	10.93	37.06	0.28	17.35	8.80	1.27	72018.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	23	24
平均值	3.65	11.46	47.30	2.35	17.80	9.46	1.29	73280.14
最大值	7.76	12.78	63.16	3.00	19.65	10.23	1.36	75982.69
發生時間	23	20	6	0	0	6		0
最小值	2.14	10.87	32.90	0.26	16.07	8.80	1.25	65142.39
發生時間	8	15	22	22	5	23		21
零點偏移(率)	-0.11 %	-0.08 %	-0.04 %	-0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	1.75 %	-0.17 %	1.66 %	0.11 %		0.15	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %	100.00 %
備註								