

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月05日

報表日期: 114年04月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.87	5.72	51.97	0.57	18.67	10.10	1.27	80948.22
1	1.69	8.98	48.53	1.23	21.42	9.26	1.27	84211.50
2	6.41	3.28	57.19	1.36	18.60	9.86	1.26	82861.87
3	10.23	2.95	51.63	1.72	17.73	10.13	1.27	83572.18
4	6.91	2.58	51.19	1.28	17.51	10.32	1.28	82560.74
5	8.82	3.97	48.66	2.80	15.91	10.69	1.27	83828.57
6	8.63	4.28	50.58	1.58	17.32	10.40	1.27	82022.84
7	6.82	2.91	47.64	1.95	16.05	10.63	1.29	79824.23
8	8.27	2.85	54.94	1.53	17.32	10.27	1.29	80389.14
9	6.76	4.18	46.11	1.47	17.63	10.00	1.28	80892.31
10	7.91	3.08	49.78	1.18	17.83	10.07	1.27	81736.22
11	2.47	3.06	49.70	0.67	18.09	10.07	1.25	80234.35
12	8.04	3.78	50.84	1.43	16.84	10.33	1.27	82403.93
13	11.07	3.39	47.95	2.14	15.99	10.68	1.29	81936.27
14	3.81	2.78	55.25	0.84	18.24	10.32	1.29	81274.66
15	6.95	3.33	50.57	1.31	17.52	10.14	1.29	84182.35
16	6.25	2.98	56.14	0.97	17.74	10.66	1.27	80059.43
17	5.60	2.16	49.60	1.19	17.68	10.19	1.26	82694.63
18	6.37	2.05	54.22	1.31	17.76	10.52	1.25	79897.16
19	7.60	2.52	57.23	0.83	19.03	10.02	1.25	82589.68
20	8.81	3.40	53.16	1.11	18.14	10.03	1.26	81555.70
21	8.20	3.45	48.07	1.38	17.60	10.02	1.29	80217.29
22	6.54	3.02	50.76	1.09	17.64	10.41	1.29	77177.05
23	2.61	3.27	59.22	1.00	17.71	11.15	1.29	71805.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.78	3.50	51.71	1.33	17.75	10.26	1.27	81203.15
最 大 值	11.07	8.98	59.22	2.80	21.42	11.15	1.30	84211.50
發生時間	13	1	23	5	1	23		1
最 小 值	1.69	2.05	46.11	0.57	15.91	9.26	1.23	71805.23
發生時間	1	18	9	0	5	1		23
零點偏移(率)	0.00 %	0.00 %	-0.18 %	-0.00 %		-0.01		0.30 %
全幅偏移(率)	0.00 %	0.12 %	-0.28 %	-0.05 %		0.05		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.41	6.76	48.68	1.49	18.21	9.86	1.10	86000.62
1	8.84	1.78	55.23	2.38	17.27	10.36	1.10	87291.46
2	9.08	2.07	54.17	2.14	16.74	10.36	1.10	84849.23
3	9.54	2.78	47.06	2.35	16.51	10.19	1.10	84566.11
4	9.49	2.49	52.90	2.65	15.79	10.46	1.10	86489.16
5	8.58	2.11	57.26	1.92	16.32	10.65	1.10	84726.37
6	6.34	5.43	60.23	2.05	14.84	10.86	1.14	86409.92
7	9.53	2.58	54.33	2.95	15.21	10.89	1.16	82570.07
8	8.97	2.28	60.97	2.13	15.76	10.82	1.15	84081.93
9	8.64	2.84	51.76	2.01	15.56	10.81	1.15	82501.80
10	8.42	3.25	58.26	2.60	14.24	10.92	1.17	81648.62
11	9.57	2.94	51.70	2.35	15.66	10.62	1.18	82989.91
12	9.07	3.02	50.18	2.06	15.80	10.67	1.16	82258.01
13	9.19	5.94	48.36	1.90	16.92	10.41	1.15	84165.69
14	9.13	6.47	51.00	2.42	15.70	10.53	1.15	84206.37
15	8.81	2.39	58.96	2.22	16.27	10.62	1.15	85051.39
16	8.80	3.16	48.03	1.87	16.53	10.54	1.16	82819.88
17	8.72	3.63	58.74	1.90	16.44	11.72	1.18	75455.74
18	9.73	3.12	53.94	2.65	17.37	10.33	1.17	86312.01
19	8.91	3.26	56.14	2.23	16.63	10.49	1.16	86936.45
20	9.26	3.47	47.88	2.46	16.80	10.25	1.14	86928.71
21	8.81	2.56	51.13	1.86	17.25	10.30	1.12	84364.16
22	8.96	4.40	52.84	1.37	17.20	10.66	1.13	80586.30
23	8.98	6.28	55.52	1.28	18.41	10.25	1.13	86006.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.95	3.54	53.55	2.13	16.39	10.57	1.14	84134.02
最 大 值	9.73	6.76	60.97	2.95	18.41	11.72	1.18	87291.46
發生時間	18	0	8	7	23	17		1
最 小 值	6.34	1.78	47.06	1.28	14.24	9.86	1.09	75455.74
發生時間	6	1	3	23	10	0		17
零點偏移(率)	-0.11 %	0.01 %	-0.03 %	-0.06 %		0.02		0.10 %
全幅偏移(率)	-0.20 %	0.53 %	-0.29 %	0.30 %		-0.06		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

