

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.46	12.51	54.50	1.26	17.38	11.77	1.03	72955.24
1	6.92	13.27	55.62	1.78	16.57	12.10	1.02	69833.91
2	6.34	10.87	60.32	1.25	17.34	11.95	1.02	71049.37
3	5.03	9.56	66.99	0.89	17.20	12.12	1.02	69895.40
4	8.11	10.84	46.89	1.57	17.53	11.22	1.01	75975.32
5	10.33	9.31	54.37	2.12	16.13	11.89	1.00	69773.60
6	8.14	8.73	67.80	1.39	17.07	11.88	0.99	70681.79
7	9.42	12.07	53.66	1.37	17.04	11.65	0.99	72207.98
8	6.85	12.97	65.20	1.60	16.38	12.08	1.04	69709.52
9	9.38	6.03	45.52	1.67	16.86	11.40	1.03	74391.93
10	9.81	5.82	56.08	1.98	15.44	11.88	1.01	71576.30
11	7.42	6.83	64.25	1.58	15.96	12.00	1.03	70356.89
12	7.98	6.48	70.18	1.34	16.85	11.80	1.02	70912.71
13	1.32	7.80	59.35	0.44	18.07	11.28	1.02	70832.46
14	3.33	6.05	47.41	1.25	16.97	11.71	1.02	70631.29
15	3.17	7.24	44.55	1.65	17.77	11.81	1.02	69504.79
16	3.74	6.60	53.14	1.43	17.72	11.67	1.00	71514.89
17	3.99	8.93	56.26	1.74	17.29	11.58	1.02	73345.19
18	6.94	14.72	52.92	2.73	15.97	11.87	1.00	71215.55
19	6.81	8.26	51.33	2.73	15.42	11.93	1.00	71289.73
20	2.88	8.97	65.22	1.45	17.19	11.76	1.02	71851.93
21	6.60	9.94	50.12	1.90	16.98	11.61	1.02	72891.86
22	6.13	12.53	56.45	1.96	16.79	11.75	1.02	71630.92
23	4.40	8.93	55.22	1.96	16.72	11.81	1.02	71159.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.31	9.39	56.39	1.63	16.86	11.77	1.01	71466.18
最大值	10.33	14.72	70.18	2.73	18.07	12.12	1.06	75975.32
發生時間	5	18	12	18	13	3		4
最小值	1.32	5.82	44.55	0.44	15.42	11.22	0.99	69504.79
發生時間	13	10	15	13	19	4		15
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.53 %	0.84 %	-0.10 %	0.23 %		-0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.14	8.16	46.92	1.84	18.81	10.39	0.99	83101.53
1	3.72	6.03	53.28	1.85	19.09	10.62	0.99	82061.75
2	3.68	5.79	50.50	1.53	18.46	10.68	0.99	82309.60
3	3.72	5.91	56.30	1.22	19.04	10.70	1.00	81685.29
4	3.60	4.92	47.11	1.25	18.65	10.24	1.00	85541.30
5	3.32	3.62	50.17	2.49	17.23	10.27	1.00	86180.43
6	5.94	2.47	57.52	2.23	17.18	10.80	1.01	74436.97
7	4.10	5.01	52.84	1.72	17.67	10.46	1.02	84200.30
8	4.64	7.11	51.71	2.41	16.59	10.37	1.01	86135.91
9	6.96	6.02	52.63	2.69	17.35	10.12	1.02	87293.37
10	4.46	6.88	51.48	2.68	16.49	10.40	1.04	86370.06
11	6.90	3.42	53.99	2.49	17.59	10.22	1.02	86355.89
12	7.39	4.54	45.78	2.51	16.77	10.34	1.01	86300.03
13	3.75	3.56	57.79	1.64	17.46	10.63	1.01	83198.74
14	3.07	3.82	53.44	1.52	18.03	10.55	1.02	83121.75
15	4.77	3.70	51.98	1.60	18.02	10.50	1.02	83100.64
16	5.85	11.16	51.12	2.27	17.25	10.11	1.01	87459.72
17	6.22	3.32	51.60	2.50	16.28	10.50	1.02	85507.31
18	6.51	3.38	58.54	1.25	17.46	10.45	1.02	84974.14
19	5.93	3.63	55.13	1.66	17.82	10.30	1.00	85802.87
20	8.49	5.15	44.48	2.38	17.32	10.30	1.01	85772.67
21	8.66	4.28	50.21	2.09	17.29	10.54	1.00	84139.67
22	9.75	3.75	56.93	2.66	16.68	10.55	0.99	84816.22
23	8.37	4.59	54.30	3.23	16.46	10.54	0.99	84909.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.54	5.01	52.32	2.07	17.54	10.44	1.01	84365.66
最大值	9.75	11.16	58.54	3.23	19.09	10.80	1.05	87459.72
發生時間	22	16	18	23	1	6		16
最小值	3.07	2.47	44.48	1.22	16.28	10.11	0.99	74436.97
發生時間	14	6	20	3	17	16		6
零點偏移(率)	-0.06 %	-0.00 %	-0.03 %	0.00 %		0.04		-0.20 %
全幅偏移(率)	-0.13 %	-0.02 %	-0.43 %	0.25 %		-0.11		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.81	9.72	54.87	1.41	15.71	11.19	1.02	77076.35
1	2.67	8.99	47.62	1.25	17.65	10.65	1.00	79116.15
2	5.39	7.61	50.42	1.94	16.02	10.79	0.99	79386.15
3	7.85	7.27	57.31	2.07	15.30	11.02	0.99	79797.12
4	5.51	15.04	53.43	2.50	13.84	11.26	0.97	76877.36
5	3.28	3.55	52.36	2.41	13.87	11.21	0.95	73476.97
6	3.68	5.22	44.85	5.13	13.27	10.85	0.94	72996.58
7	3.38	2.94	61.04	2.11	13.73	11.15	0.96	75643.59
8	2.75	5.77	56.01	2.77	13.32	11.20	0.98	71281.42
9	2.31	6.67	51.59	2.30	13.68	11.05	0.95	72202.63
10	2.40	7.41	49.33	2.20	13.82	11.17	0.99	71791.54
11	2.15	7.20	45.18	1.60	15.47	10.62	0.99	75620.09
12	4.23	8.63	48.16	2.02	14.65	10.72	0.95	76483.21
13	4.08	4.66	54.32	1.88	14.82	11.06	0.98	77243.91
14	3.99	5.21	43.36	1.75	15.00	10.52	1.01	78157.63
15	4.94	1.98	54.95	1.59	16.57	10.51	1.00	81383.20
16	5.01	5.16	44.30	1.79	16.17	10.26	0.96	82856.65
17	6.64	3.97	52.29	2.25	15.07	10.96	0.97	79658.54
18	6.57	3.80	48.84	1.83	15.68	10.87	0.97	81028.40
19	10.27	3.08	60.83	1.98	16.14	10.92	0.95	79323.21
20	6.85	3.40	58.50	1.81	15.72	11.05	0.99	79595.99
21	6.08	3.35	51.65	1.64	16.14	10.70	1.00	81911.77
22	5.22	4.65	52.19	1.50	16.30	10.63	0.99	82187.37
23	5.88	5.18	56.91	2.00	15.28	11.05	0.99	78260.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.79	5.85	52.10	2.07	15.13	10.89	0.98	77639.85
最大值	10.27	15.04	61.04	5.13	17.65	11.26	1.02	82856.65
發生時間	19	4	7	6	1	4		16
最小值	2.15	1.98	43.36	1.25	13.27	10.26	0.93	71281.42
發生時間	11	15	14	1	6	16		8
零點偏移(率)	-0.04 %	-0.00 %	-0.30 %	-0.07 %		0.02		0.00 %
全幅偏移(率)	0.18 %	-0.09 %	-0.76 %	0.20 %		0.34		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								