

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.43	5.11	60.90	3.48	19.16	11.91	1.39	71757.49
1	11.58	3.01	59.09	3.00	20.61	11.09	1.38	77085.92
2	10.95	5.81	54.02	3.53	18.40	11.55	1.38	74781.57
3	7.98	6.06	64.10	3.39	18.75	11.54	1.39	75870.05
4	9.53	4.12	53.33	3.18	19.22	11.11	1.40	78197.24
5	5.50	4.86	69.53	3.62	18.85	12.24	1.47	70181.22
6	8.11	4.14	57.04	3.42	20.09	11.37	1.46	76275.79
7	10.36	5.61	49.36	3.42	18.44	11.11	1.44	79135.07
8	8.79	1.77	59.04	2.17	18.19	11.35	1.43	77313.53
9	5.77	1.02	52.30	2.11	18.63	11.48	1.43	76284.31
10	6.65	1.05	61.08	1.92	19.76	11.07	1.42	78305.13
11	2.91	0.96	59.12	1.76	20.30	11.33	1.41	75956.48
12	5.34	3.30	51.44	1.80	19.12	11.13	1.42	78395.46
13	9.18	3.83	53.70	2.15	19.31	11.30	1.43	77083.74
14	9.54	4.72	54.29	1.85	20.00	10.83	1.42	79144.66
15	8.35	0.98	61.00	1.78	20.42	11.12	1.42	76962.10
16	9.72	1.33	51.34	2.06	19.43	11.23	1.41	76801.89
17	9.69	4.31	67.07	2.14	18.89	11.88	1.42	71919.15
18	10.97	3.43	65.40	2.31	18.77	11.68	1.40	74119.30
19	13.78	3.44	53.84	2.31	19.44	11.06	1.40	78683.10
20	12.68	4.98	56.72	2.16	18.82	11.22	1.42	77687.10
21	11.18	6.44	56.54	2.30	18.35	11.40	1.44	77157.65
22	10.69	7.11	59.44	2.30	18.07	11.52	1.45	76444.78
23	10.57	3.09	62.23	2.13	19.64	11.06	1.46	78315.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.09	3.77	58.00	2.51	19.19	11.36	1.42	76410.74
最大值	13.78	7.11	69.53	3.62	20.61	12.24	1.49	79144.66
發生時間	19	22	5	5	1	5		14
最小值	2.91	0.96	49.36	1.76	18.07	10.83	1.37	70181.22
發生時間	11	11	7	11	22	14		5
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	-0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	1.84 %	0.03 %	-0.24 %	0.03 %		0.34	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.02	4.04	65.51	1.70	17.24	10.91	1.40	65040.45
1	10.83	7.90	60.94	2.06	17.08	10.79	1.39	64672.69
2	8.10	7.32	63.54	2.13	16.52	10.87	1.38	63907.20
3	10.52	10.24	57.60	2.63	15.72	10.82	1.38	62928.39
4	11.27	9.60	63.06	2.43	15.37	10.71	1.37	63689.66
5	10.71	4.35	63.29	2.22	17.14	10.45	1.36	65532.91
6	8.47	8.79	57.00	2.69	15.20	10.50	1.33	66578.41
7	8.62	4.91	61.16	2.22	15.04	10.65	1.33	63245.90
8	8.51	1.94	62.50	2.16	15.50	10.81	1.35	64589.21
9	8.45	1.48	58.13	2.00	16.66	10.75	1.36	64930.12
10	8.78	2.19	58.90	1.50	18.84	10.13	1.37	68364.29
11	9.17	1.13	67.46	1.54	18.58	10.37	1.38	66996.10
12	4.69	1.93	65.63	1.48	18.67	10.94	1.38	62930.09
13	10.26	4.25	45.92	2.00	18.90	10.25	1.38	67329.12
14	8.18	2.79	58.69	1.79	17.18	10.86	1.38	65012.22
15	10.73	6.12	60.58	2.63	17.22	10.68	1.38	65772.13
16	10.75	1.90	66.14	2.11	16.07	11.33	1.38	63178.03
17	11.75	1.58	62.19	3.08	16.49	10.99	1.38	64934.04
18	9.80	1.13	65.66	2.38	17.01	11.03	1.38	64561.08
19	10.42	0.93	58.39	2.20	16.88	10.87	1.38	65584.72
20	10.27	8.86	64.78	2.24	15.69	11.15	1.36	64190.56
21	12.28	9.15	54.15	2.53	16.41	10.62	1.33	64804.72
22	11.23	2.49	63.84	2.37	16.56	10.72	1.33	65022.23
23	9.48	9.70	55.85	2.34	15.07	11.00	1.33	62113.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.68	4.78	60.87	2.18	16.71	10.76	1.37	64829.51
最大值	12.28	10.24	67.46	3.08	18.90	11.33	1.41	68364.29
發生時間	21	3	11	17	13	16		10
最小值	4.69	0.93	45.92	1.48	15.04	10.13	1.33	62113.91
發生時間	12	19	13	12	7	10		23
零點偏移(率)	-0.01 %	-0.00 %	-0.04 %	-0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	3.34 %	0.06 %	0.32 %	0.18 %		0.21	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.28	6.96	68.64	2.02	16.60	10.77	1.86	87903.91
1	8.75	7.21	60.01	1.94	17.48	10.64	1.88	87808.36
2	12.67	7.79	60.69	2.42	15.85	10.50	1.87	88450.43
3	12.63	6.78	60.45	3.08	15.36	10.63	1.85	88222.65
4	13.27	5.58	60.33	2.59	15.73	10.67	1.85	86407.52
5	5.87	5.45	68.94	2.30	15.18	10.92	1.83	89204.72
6	10.37	10.78	61.97	2.72	14.59	11.02	1.82	86944.33
7	7.65	4.15	65.42	2.64	14.97	11.03	1.81	73941.65
8	7.93	0.93	60.40	2.26	15.87	10.54	1.81	86700.10
9	7.77	4.57	66.54	2.19	16.06	10.86	1.82	83628.06
10	9.11	7.06	58.36	2.11	16.61	10.76	1.84	85169.70
11	6.59	9.96	63.17	2.35	15.29	10.90	1.85	83660.70
12	6.24	1.77	59.27	2.87	13.91	10.99	1.85	78926.42
13	9.66	1.95	58.85	2.39	16.09	10.56	1.85	83453.78
14	10.18	5.63	57.00	2.07	17.54	9.96	1.85	88326.97
15	7.10	2.86	61.97	2.10	15.76	10.55	1.85	82211.73
16	10.87	4.26	57.98	2.58	14.51	10.98	1.85	83667.86
17	12.66	5.22	63.55	2.54	15.11	10.78	1.85	83880.23
18	7.38	2.68	58.97	2.13	15.88	10.55	1.85	83684.76
19	7.75	6.08	63.92	2.61	14.47	11.08	1.83	82187.46
20	10.26	8.26	62.53	3.15	13.55	11.21	1.81	82270.18
21	10.31	5.75	54.74	2.45	15.57	10.41	1.79	82381.98
22	12.76	3.06	60.79	2.89	14.06	10.62	1.78	80234.54
23	10.01	3.16	59.81	2.94	13.83	11.14	1.80	81168.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.38	5.33	61.43	2.47	15.41	10.75	1.83	84184.85
最大值	13.27	10.78	68.94	3.15	17.54	11.21	1.88	89204.72
發生時間	4	6	5	20	14	20		5
最小值	5.87	0.93	54.74	1.94	13.55	9.96	1.77	73941.65
發生時間	5	8	21	1	20	14		7
零點偏移(率)	-0.02 %	0.00 %	-0.07 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.28 %	0.38 %	-0.23 %	0.22 %		0.41	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								