

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月01日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.10	8.97	56.92	2.74	17.59	11.22	0.94	77252.74
1	10.21	6.71	41.48	3.41	16.68	10.79	0.92	80236.20
2	9.37	4.04	49.46	3.31	17.57	10.44	0.92	82882.16
3	8.79	3.75	53.94	3.21	15.91	11.05	0.92	78530.34
4	6.70	5.54	65.56	2.23	17.30	10.75	0.92	78286.53
5	7.75	2.18	45.14	2.04	18.46	9.95	0.93	82132.88
6	6.17	4.16	38.35	1.32	17.20	10.29	0.92	77235.93
7	9.30	3.58	38.10	2.07	17.03	10.84	0.92	80560.42
8	9.89	1.68	49.64	2.43	17.54	11.11	0.94	78019.66
9	8.10	2.02	46.05	3.02	17.46	11.07	0.97	78200.40
10	12.59	4.91	44.39	1.99	16.72	11.18	0.96	79886.15
11	12.42	7.42	41.80	2.99	16.03	11.32	0.94	78728.76
12	7.57	8.12	46.43	4.01	16.20	11.23	0.97	78684.65
13	6.41	2.04	49.90	2.98	16.07	11.36	0.96	77961.42
14	4.61	4.61	59.95	2.52	15.56	11.64	0.94	79033.43
15	11.29	9.54	52.06	4.31	13.51	12.00	0.94	79632.58
16	5.56	7.72	44.57	2.39	14.08	11.49	0.94	75900.97
17	7.28	3.10	44.39	2.28	14.66	11.27	0.93	77047.09
18	6.24	4.34	52.15	1.76	16.39	11.25	0.93	81725.04
19	4.30	6.27	62.32	1.31	17.94	11.20	0.95	85299.54
20	1.84	6.10	63.05	1.23	17.12	11.76	0.96	81018.95
21	5.70	6.11	59.33	1.57	17.02	11.37	0.98	84936.46
22	8.26	6.16	68.20	1.34	16.99	11.39	0.98	84729.90
23	6.70	5.93	57.90	0.65	17.70	11.61	0.97	82338.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.76	5.21	51.30	2.38	16.61	11.15	0.94	80010.88
最 大 值	12.59	9.54	68.20	4.31	18.46	12.00	1.00	85299.54
發生時間	10	15	22	15	5	15		19
最 小 值	1.84	1.68	38.10	0.65	13.51	9.95	0.89	75900.97
發生時間	20	8	7	23	15	5		16
零點偏移(率)	-0.01 %	-0.00 %	-0.38 %	0.00 %		-0.11		0.30 %
全幅偏移(率)	0.00 %	0.24 %	-0.31 %	0.13 %		0.09		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 113年06月01日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.87	3.75	63.81	1.75	17.20	11.83	1.02	74126.05
1	6.54	4.50	53.96	2.03	17.13	11.69	1.02	75755.26
2	9.36	3.28	52.73	2.24	16.38	11.02	1.02	81369.08
3	9.58	3.57	49.02	2.34	17.18	10.61	1.02	83786.51
4	10.45	2.22	50.09	2.29	17.77	10.67	1.02	82832.41
5	10.42	2.05	53.88	1.96	17.28	10.77	1.03	82169.90
6	8.36	1.35	57.89	1.23	18.12	10.49	1.02	81575.23
7	11.76	3.31	48.64	2.41	16.98	10.51	1.01	83879.04
8	12.05	7.89	44.58	2.57	15.33	11.36	1.02	79246.89
9	10.34	2.00	56.30	2.00	16.68	10.97	1.01	82333.47
10	11.05	4.30	51.31	2.18	15.68	11.23	0.99	80648.76
11	10.13	1.98	55.07	2.66	16.17	11.11	0.99	81186.99
12	8.87	2.52	52.22	2.89	15.54	11.25	0.99	81455.77
13	9.23	4.23	57.53	2.68	16.12	11.16	0.97	81408.59
14	9.34	5.15	56.33	3.02	14.96	11.15	0.99	82385.03
15	8.50	6.48	53.44	3.36	14.29	11.47	0.99	80068.96
16	13.41	6.89	53.63	3.92	14.00	11.42	1.00	80686.46
17	5.96	2.01	61.91	2.79	15.83	11.37	1.01	79793.34
18	5.34	2.93	55.85	3.60	14.94	11.63	0.99	78202.34
19	3.89	2.99	63.77	0.74	18.48	10.67	1.01	82668.70
20	2.28	3.18	48.48	0.69	18.32	10.37	1.02	85263.38
21	2.97	3.27	51.26	0.85	19.48	9.92	0.99	87410.16
22	4.56	3.67	59.95	1.05	19.99	10.15	0.98	85583.13
23	4.89	4.33	58.00	1.42	18.72	11.18	0.96	78880.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.30	3.66	54.57	2.19	16.77	11.00	1.00	81363.15
最 大 值	13.41	7.89	63.81	3.92	19.99	11.83	1.04	87410.16
發生時間	16	8	0	16	22	0		21
最 小 值	2.28	1.35	44.58	0.69	14.00	9.92	0.94	74126.05
發生時間	20	6	8	20	16	21		0
零點偏移(率)	-0.02 %	-0.00 %	-0.08 %	-0.04 %		-0.06		0.00 %
全幅偏移(率)	-0.04 %	-0.68 %	0.23 %	0.08 %		0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月01日

報表日期: 113年06月01日

項目 單位	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.01	3.98	58.70	1.62	18.64	10.35	0.98	81001.50
1	5.69	1.98	57.46	1.52	18.33	10.63	0.96	78493.79
2	8.19	2.45	53.48	1.53	17.61	10.67	0.93	75719.37
3	4.67	2.57	48.79	1.54	18.70	10.12	0.92	78336.12
4	6.20	2.88	43.40	1.58	17.15	10.46	0.92	77328.90
5	11.11	4.39	45.37	1.80	17.94	10.05	0.91	79273.46
6	10.85	1.81	47.23	1.60	17.84	9.97	0.91	75247.03
7	6.12	4.00	49.08	1.86	17.99	9.69	1.01	82155.35
8	8.70	3.31	50.69	1.87	17.18	10.42	1.03	76817.32
9	5.96	3.13	53.32	2.67	17.86	10.44	1.00	74887.43
10	8.93	8.49	52.40	2.29	17.43	10.24	1.04	79523.66
11	9.70	6.79	41.92	3.15	15.22	10.41	1.04	75494.29
12	1.76	4.46	48.55	1.14	15.25	10.71	1.01	76070.21
13	9.46	1.79	53.45	1.11	15.86	10.90	1.01	75682.54
14	3.41	4.55	59.28	1.07	15.52	10.94	1.04	79187.86
15	9.32	8.92	58.44	1.90	13.35	11.35	1.07	76948.40
16	3.55	4.68	47.52	1.89	12.95	11.42	1.07	76187.84
17	5.10	3.72	53.57	1.86	13.72	11.32	1.04	79779.97
18	2.46	3.00	57.23	1.30	16.61	10.82	1.01	81085.88
19	2.12	6.53	52.93	1.61	16.54	10.88	1.01	80785.23
20	5.30	7.81	52.31	2.15	15.64	10.97	0.99	81062.04
21	3.32	5.07	50.05	2.09	15.35	11.09	1.00	78189.46
22	3.17	2.08	56.09	1.73	16.40	11.06	0.99	78717.20
23	1.78	4.98	60.09	1.59	18.01	10.60	0.99	81383.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.08	4.31	52.14	1.77	16.55	10.65	0.99	78306.59
最 大 值	11.11	8.92	60.09	3.15	18.70	11.42	1.11	82155.35
發生時間	5	15	23	11	3	16		7
最 小 值	1.76	1.79	41.92	1.07	12.95	9.69	0.90	74887.43
發生時間	12	13	11	14	16	7		9
零點偏移(率)	-0.02 %	-0.00 %	-0.10 %	-0.06 %		-0.08		0.20 %
全幅偏移(率)	0.02 %	0.16 %	-0.37 %	0.09 %		0.28		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								