

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月16日

報表日期: 115年08月16日

| 項目<br>單位<br>小時\限標 | #1-HCl_C<br>ppm | #1-CO_C<br>ppm | #1-NOx_C<br>ppm | #1-SO2_C<br>ppm | #1-H2O<br>% | #1-O2_C<br>% | #1-OPAC<br>% | #1-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 8.41            | 11.75          | 64.93           | 1.68            | 18.93       | 11.07        | 1.25         | 72272.30             |
| 1                 | 8.15            | 11.73          | 53.94           | 2.19            | 19.00       | 11.08        | 1.25         | 73431.51             |
| 2                 | 8.85            | 12.11          | 66.75           | 2.37            | 19.44       | 11.45        | 1.25         | 70821.64             |
| 3                 | 9.75            | 11.45          | 60.41           | 2.44            | 19.39       | 10.93        | 1.25         | 74561.53             |
| 4                 | 8.70            | 11.61          | 59.05           | 2.50            | 17.93       | 11.24        | 1.25         | 73347.01             |
| 5                 | 4.18            | 12.51          | 46.53           | 1.75            | 18.64       | 11.03        | 1.23         | 81776.11             |
| 6                 | 8.89            | 12.48          | 60.56           | 2.70            | 18.27       | 11.02        | 1.23         | 74206.12             |
| 7                 | 10.02           | 12.94          | 62.45           | 2.83            | 18.02       | 11.19        | 1.23         | 73561.48             |
| 8                 | 10.40           | 12.79          | 53.80           | 3.30            | 17.83       | 11.08        | 1.21         | 74101.38             |
| 9                 | 8.67            | 13.08          | 60.06           | 2.66            | 17.88       | 11.18        | 1.23         | 73359.36             |
| 10                | 9.01            | 13.63          | 64.43           | 2.78            | 18.56       | 10.92        | 1.23         | 74551.68             |
| 11                | 9.83            | 13.33          | 58.13           | 4.42            | 17.50       | 11.50        | 1.21         | 70889.59             |
| 12                | 10.08           | 13.84          | 63.31           | 4.76            | 16.80       | 12.01        | 1.19         | 69963.47             |
| 13                | 9.98            | 13.95          | 61.77           | 3.77            | 16.78       | 11.93        | 1.18         | 72754.57             |
| 14                | 9.05            | 16.12          | 50.34           | 4.37            | 16.17       | 12.83        | 1.18         | 66293.47             |
| 15                | 10.01           | 14.78          | 47.10           | 3.24            | 18.35       | 11.85        | 1.18         | 72393.65             |
| 16                | 13.53           | 13.38          | 47.60           | 4.15            | 17.57       | 11.43        | 1.19         | 74655.36             |
| 17                | 13.97           | 13.06          | 56.18           | 4.32            | 16.95       | 11.53        | 1.22         | 71947.16             |
| 18                | 7.57            | 12.42          | 54.68           | 2.44            | 17.04       | 11.38        | 1.21         | 72664.94             |
| 19                | 4.54            | 12.18          | 59.85           | 1.02            | 19.68       | 10.97        | 1.22         | 73531.28             |
| 20                | 3.94            | 11.84          | 59.76           | 1.07            | 17.96       | 11.23        | 1.23         | 72921.78             |
| 21                | 5.03            | 12.93          | 60.88           | 1.83            | 16.57       | 11.39        | 1.22         | 72475.56             |
| 22                | 4.08            | 11.64          | 63.59           | 1.33            | 16.54       | 11.57        | 1.23         | 70995.57             |
| 23                | 6.46            | 11.81          | 58.40           | 2.35            | 18.14       | 11.27        | 1.23         | 71891.12             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 8.46            | 12.81          | 58.10           | 2.76            | 17.91       | 11.38        | 1.22         | 72890.32             |
| 最 大 值             | 13.97           | 16.12          | 66.75           | 4.76            | 19.68       | 12.83        | 1.25         | 81776.11             |
| 發生時間              | 17              | 14             | 2               | 12              | 19          | 14           |              | 5                    |
| 最 小 值             | 3.94            | 11.45          | 46.53           | 1.02            | 16.17       | 10.92        | 1.18         | 66293.47             |
| 發生時間              | 20              | 3              | 5               | 19              | 14          | 10           |              | 14                   |
| 零點偏移(率)           | -0.02 %         | -0.01 %        | -0.03 %         | -0.01 %         |             | -0.01        | -0.01        | 0.20 %               |
| 全幅偏移(率)           | 2.09 %          | 0.09 %         | 0.74 %          | 0.93 %          |             | -0.15        | -0.06        | 0.10 %               |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月16日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 1.83     | 13.10    | 59.84    | 1.14     | 19.05    | 10.83    | 0.94     | 82197.67  |
| 1                 | 3.06     | 12.53    | 51.57    | 1.86     | 19.16    | 10.90    | 0.94     | 82294.07  |
| 2                 | 8.11     | 12.34    | 61.38    | 1.69     | 19.07    | 10.74    | 0.93     | 83663.08  |
| 3                 | 2.08     | 12.40    | 61.29    | 1.39     | 18.79    | 10.83    | 0.93     | 82817.33  |
| 4                 | 4.65     | 12.43    | 60.51    | 1.71     | 18.46    | 10.98    | 0.93     | 82477.97  |
| 5                 | 4.98     | 12.71    | 57.75    | 1.37     | 18.10    | 11.23    | 0.94     | 80335.59  |
| 6                 | 4.80     | 12.72    | 56.20    | 2.02     | 16.84    | 11.51    | 0.94     | 81525.25  |
| 7                 | 2.75     | 12.76    | 60.74    | 1.73     | 17.98    | 11.32    | 0.94     | 79640.10  |
| 8                 | 8.68     | 12.44    | 56.87    | 2.29     | 18.32    | 11.02    | 0.94     | 81402.42  |
| 9                 | 3.23     | 13.21    | 53.36    | 2.77     | 16.90    | 11.30    | 0.94     | 80474.03  |
| 10                | 5.14     | 12.81    | 50.79    | 2.57     | 18.46    | 10.92    | 0.94     | 81592.26  |
| 11                | 2.65     | 12.76    | 62.65    | 2.16     | 17.56    | 11.31    | 0.94     | 79635.29  |
| 12                | 6.63     | 12.43    | 53.57    | 2.14     | 18.39    | 11.02    | 0.92     | 81161.24  |
| 13                | 3.85     | 12.91    | 56.46    | 2.61     | 17.47    | 11.26    | 0.92     | 80330.98  |
| 14                | 7.58     | 14.56    | 48.73    | 2.37     | 17.22    | 12.45    | 0.93     | 70800.27  |
| 15                | 5.54     | 13.32    | 53.63    | 1.73     | 18.51    | 11.57    | 0.92     | 76771.01  |
| 16                | 5.47     | 12.28    | 46.81    | 2.35     | 18.28    | 10.88    | 0.93     | 82071.15  |
| 17                | 9.69     | 12.81    | 48.12    | 3.61     | 16.91    | 11.24    | 0.93     | 81378.90  |
| 18                | 5.05     | 12.78    | 56.47    | 1.41     | 17.23    | 11.41    | 0.92     | 79855.58  |
| 19                | 9.79     | 12.50    | 47.86    | 1.57     | 17.94    | 11.15    | 0.94     | 81167.40  |
| 20                | 6.04     | 12.52    | 55.78    | 1.25     | 18.10    | 11.15    | 0.94     | 80802.64  |
| 21                | 2.04     | 12.71    | 59.73    | 1.70     | 17.37    | 11.36    | 0.94     | 79663.14  |
| 22                | 6.44     | 12.92    | 56.05    | 2.05     | 16.61    | 11.59    | 0.94     | 78659.85  |
| 23                | 2.89     | 12.45    | 55.21    | 1.67     | 18.48    | 10.95    | 0.94     | 81558.15  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 5.12     | 12.77    | 55.47    | 1.96     | 17.97    | 11.20    | 0.93     | 80511.47  |
| 最 大 值             | 9.79     | 14.56    | 62.65    | 3.61     | 19.16    | 12.45    | 0.95     | 83663.08  |
| 發生時間              | 19       | 14       | 11       | 17       | 1        | 14       |          | 2         |
| 最 小 值             | 1.83     | 12.28    | 46.81    | 1.14     | 16.61    | 10.74    | 0.90     | 70800.27  |
| 發生時間              | 0        | 16       | 16       | 0        | 22       | 2        |          | 14        |
| 零點偏移(率)           | -0.15 %  | -0.08 %  | -0.05 %  | -0.01 %  |          | 0.00     | -0.01    | -0.10 %   |
| 全幅偏移(率)           | -1.63 %  | 0.93 %   | 0.07 %   | 0.39 %   |          | -0.14    | 0.00     | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月16日

報表日期: 115年08月16日

[illegible]