

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.23	3.81	51.58	2.41	18.63	12.08	1.41	69172.90
1	0.13	3.57	52.82	2.38	18.13	11.65	1.41	73487.18
2	1.53	3.65	71.41	2.63	17.70	12.23	1.42	70212.44
3	0.36	3.72	53.94	2.47	17.98	11.76	1.41	73112.03
4	0.44	4.56	56.34	2.53	17.78	11.98	1.41	71912.97
5	2.10	4.42	47.78	2.67	17.32	11.72	1.42	74914.69
6	2.90	5.63	45.64	3.08	16.36	12.11	1.42	71398.84
7	0.83	4.24	60.93	2.84	16.46	12.59	1.42	67871.53
8	1.20	4.27	53.75	2.81	16.98	12.20	1.42	70360.86
9	6.01	3.31	50.25	2.95	17.08	11.82	1.40	72570.86
10	3.50	3.24	60.27	2.42	17.88	11.87	1.38	71821.97
11	3.62	4.03	44.92	2.54	17.62	11.70	1.38	72548.18
12	4.72	3.18	62.54	2.30	17.98	11.57	1.41	73300.40
13	8.73	3.74	47.46	3.26	16.17	11.92	1.41	72086.32
14	7.05	3.81	50.78	3.17	16.14	12.04	1.41	70994.07
15	5.03	3.33	62.83	2.84	16.77	12.13	1.39	70664.60
16	8.12	3.40	54.47	3.20	17.25	11.86	1.37	71922.75
17	7.36	3.33	48.14	3.15	16.28	11.86	1.37	72277.02
18	3.24	3.63	65.51	3.14	15.78	12.84	1.40	65562.09
19	0.11	8.47	56.87	3.16	15.83	13.27	1.42	62208.53
20	0.66	4.36	51.74	2.68	16.49	12.23	1.41	69778.03
21	2.71	6.50	51.70	3.51	14.67	12.34	1.43	70784.90
22	2.76	4.13	67.92	3.19	15.87	12.47	1.44	69494.24
23	3.35	4.09	54.41	2.74	16.49	12.34	1.43	69223.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.20	4.18	55.17	2.84	16.90	12.11	1.41	70736.71
最大值	8.73	8.47	71.41	3.51	18.63	13.27	1.47	74914.69
發生時間	13	19	2	21	0	19		5
最小值	0.11	3.18	44.92	2.30	14.67	11.57	1.36	62208.53
發生時間	19	12	11	12	21	12		19
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	-0.46 %	-0.02 %	-0.17 %	-0.03 %		0.16	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.50	3.67	56.46	1.10	20.47	10.25	1.38	82530.77
1	4.57	3.56	50.33	1.44	19.86	10.02	1.38	84044.70
2	2.82	3.43	53.97	1.46	19.12	10.38	1.38	83102.63
3	2.26	4.00	65.48	1.06	20.26	10.28	1.38	82904.30
4	2.39	3.58	41.40	1.36	19.36	10.08	1.38	86769.73
5	4.64	4.49	51.81	1.87	18.03	10.31	1.38	84458.07
6	2.74	5.01	62.78	1.19	19.68	9.97	1.43	79994.67
7	7.79	5.23	47.40	2.00	19.11	10.10	1.44	86860.12
8	8.10	5.44	51.51	1.82	19.88	9.77	1.42	87735.36
9	9.70	3.60	48.00	2.32	18.50	9.95	1.41	86367.43
10	10.13	6.12	53.93	2.33	18.86	9.75	1.44	88261.57
11	9.61	7.28	51.09	2.60	17.64	9.92	1.45	83906.68
12	10.84	5.24	41.86	3.53	14.99	9.99	1.46	78714.55
13	10.80	7.32	40.33	2.62	16.12	9.55	1.46	82689.42
14	8.53	6.78	40.01	2.49	16.59	9.43	1.47	81022.09
15	10.53	2.95	45.03	2.62	18.73	9.23	1.48	84874.63
16	12.03	1.81	58.38	2.55	18.23	10.02	1.45	86885.69
17	8.58	2.86	57.17	1.68	19.15	9.98	1.45	86503.36
18	7.94	2.63	50.89	1.13	20.87	9.69	1.45	87354.54
19	10.76	6.46	59.54	2.18	20.19	9.47	1.43	88016.71
20	11.61	4.12	63.33	2.49	18.82	9.76	1.42	86161.59
21	9.61	4.14	52.36	2.71	19.03	9.91	1.42	85788.39
22	9.73	4.49	42.24	2.51	18.08	10.03	1.45	84069.46
23	9.77	3.57	60.03	1.91	19.04	10.20	1.45	81974.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.92	4.49	51.89	2.04	18.78	9.92	1.43	84624.63
最大值	12.03	7.32	65.48	3.53	20.87	10.38	1.50	88261.57
發生時間	16	13	3	12	18	2		10
最小值	2.26	1.81	40.01	1.06	14.99	9.23	1.38	78714.55
發生時間	3	16	14	3	12	15		12
零點偏移(率)	0.00 %	-0.02 %	-0.02 %	-0.01 %		-0.09	0.00	0.00 %
全幅偏移(率)	0.93 %	-0.00 %	-0.36 %	-0.02 %		-0.22	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.81	4.21	63.51	2.27	19.11	10.61	1.49	85687.36
1	3.05	4.60	51.78	2.11	18.31	10.56	1.49	85971.67
2	3.53	4.83	61.21	2.21	17.09	10.66	1.48	86000.99
3	3.19	10.45	54.23	2.49	16.26	10.71	1.49	83722.77
4	6.28	2.95	54.19	2.52	17.41	10.38	1.49	88954.22
5	4.96	2.31	62.40	2.57	16.33	10.90	1.49	84121.10
6	5.77	2.79	52.79	2.60	16.06	10.84	1.49	82966.00
7	7.27	5.03	60.07	2.24	18.17	10.12	1.48	86349.46
8	8.28	5.70	52.43	2.10	17.70	10.24	1.49	84907.57
9	7.44	5.05	48.71	2.13	17.56	9.93	1.49	86162.00
10	8.79	1.44	57.35	2.36	16.55	10.35	1.49	83966.38
11	8.06	1.71	54.20	2.43	15.42	10.68	1.49	82829.65
12	10.57	1.63	62.51	2.75	15.20	10.92	1.49	82730.37
13	9.12	8.00	51.69	3.07	14.46	10.72	1.48	78529.89
14	10.86	5.16	61.39	3.33	13.84	11.44	1.50	79381.58
15	9.17	2.17	56.25	3.84	14.04	11.68	1.49	80968.93
16	11.02	2.18	58.58	2.90	14.77	11.01	1.50	84178.22
17	7.43	1.38	62.93	2.02	16.27	11.22	1.51	83850.07
18	6.69	3.77	59.88	2.01	16.53	11.01	1.50	83955.80
19	9.63	6.46	57.77	2.23	15.70	10.98	1.51	84832.03
20	7.78	10.22	63.08	2.46	15.72	10.84	1.49	85162.60
21	6.95	4.33	48.63	2.36	15.01	10.90	1.47	80537.91
22	9.78	2.24	62.11	2.14	16.89	10.94	1.49	82017.32
23	8.28	3.30	55.54	1.87	17.35	10.77	1.49	85548.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.45	4.25	57.22	2.46	16.32	10.77	1.49	83888.83
最大值	11.02	10.45	63.51	3.84	19.11	11.68	1.52	88954.22
發生時間	16	3	0	15	0	15		4
最小值	3.05	1.38	48.63	1.87	13.84	9.93	1.46	78529.89
發生時間	1	17	21	23	14	9		13
零點偏移(率)	-0.02 %	0.00 %	-0.22 %	-0.08 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.28 %	0.28 %	-0.36 %	0.16 %		0.09	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								