

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月04日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.43	8.33	42.63	2.04	14.88	12.17	1.02	79320.14
1	10.18	7.73	47.56	1.19	17.30	11.71	1.02	80802.90
2	11.22	5.85	58.97	1.32	16.18	11.41	1.02	84584.86
3	12.98	10.93	43.44	2.53	14.05	12.28	1.02	78674.90
4	10.36	2.92	29.40	1.68	15.07	12.17	1.00	79072.26
5	9.93	7.43	63.48	1.61	14.79	12.81	1.02	77621.64
6	9.78	5.07	42.60	1.14	15.50	11.85	1.02	81313.07
7	10.26	6.21	46.97	1.83	15.58	11.83	1.02	81184.60
8	8.35	6.26	52.96	1.32	15.68	12.16	1.02	78493.52
9	8.24	8.57	50.80	0.79	16.28	11.93	1.02	79705.59
10	10.35	9.81	42.65	1.18	16.95	11.32	1.05	84293.58
11	9.27	9.92	49.35	0.72	17.00	11.57	1.04	82326.29
12	10.17	5.72	43.59	2.08	14.36	11.83	1.02	82016.59
13	9.98	6.86	43.64	2.41	14.01	12.03	1.02	80600.73
14	8.47	6.20	47.67	1.81	14.30	12.09	1.02	79486.37
15	8.07	6.94	48.79	1.73	14.50	12.34	1.02	77218.19
16	6.59	5.50	50.29	1.54	14.68	12.12	1.03	78613.65
17	2.06	5.44	50.29	0.48	17.08	11.82	1.06	79756.30
18	7.96	6.48	47.44	1.10	15.64	11.51	1.02	83731.23
19	7.02	6.76	49.71	0.97	15.61	11.72	1.05	81866.72
20	8.74	10.52	51.18	1.43	14.79	12.20	1.04	78577.07
21	8.25	11.21	52.15	1.63	14.82	12.44	1.01	76733.30
22	9.06	7.91	61.19	0.79	16.91	11.44	1.03	83326.84
23	10.42	7.62	39.62	1.49	16.02	11.51	1.04	83323.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.05	7.34	48.18	1.45	15.50	11.93	1.03	80526.82
最 大 值	12.98	11.21	63.48	2.53	17.30	12.81	1.11	84584.86
發生時間	3	21	5	3	1	5		2
最 小 值	2.06	2.92	29.40	0.48	14.01	11.32	0.98	76733.30
發生時間	17	4	4	17	13	10		21
零點偏移(率)	-0.06 %	0.00 %	-0.05 %	-0.00 %		-0.02		0.00 %
全幅偏移(率)	0.02 %	-0.02 %	0.44 %	0.59 %		-0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.51	4.01	40.36	2.51	14.25	11.48	1.06	79273.12
1	9.61	3.58	41.04	2.06	15.46	11.52	1.06	78150.84
2	10.11	3.45	41.49	2.64	14.20	11.60	1.04	78406.78
3	10.57	4.14	40.71	2.99	13.61	11.64	1.04	78453.50
4	9.82	3.27	42.54	2.69	13.91	11.68	1.03	78217.96
5	7.31	3.83	43.62	2.63	13.71	11.68	1.02	78679.83
6	10.12	5.39	44.57	2.01	13.45	11.67	1.02	78884.92
7	9.71	2.66	42.54	2.50	14.24	11.39	1.02	80248.30
8	8.13	2.68	49.63	1.88	15.51	11.45	1.02	78278.49
9	9.49	2.94	39.02	2.18	15.13	11.11	1.03	81231.34
10	7.83	3.53	50.67	1.77	15.18	11.49	1.06	78011.99
11	9.17	3.53	42.66	2.23	14.55	11.26	1.05	80099.20
12	5.60	3.91	44.44	2.89	12.49	11.73	1.02	77924.48
13	8.16	5.30	43.45	3.39	11.93	12.01	1.02	75626.42
14	8.00	5.01	41.61	3.52	12.30	11.92	1.02	75685.79
15	7.76	4.76	42.62	3.07	13.03	11.83	1.03	76631.16
16	2.92	3.22	58.52	1.47	15.14	11.61	1.05	76777.19
17	4.51	3.44	56.16	1.42	15.48	11.18	1.06	79889.30
18	7.18	5.17	47.04	2.62	12.79	11.96	1.03	75971.68
19	7.87	2.32	45.39	2.79	12.97	11.76	1.04	77865.18
20	8.38	2.65	44.41	2.66	12.83	11.84	1.02	76899.25
21	2.26	3.08	47.88	2.65	12.73	12.14	1.03	75487.15
22	0.97	2.83	57.54	1.56	14.51	12.04	1.02	74582.33
23	5.79	2.73	57.77	1.56	16.07	11.02	1.04	81773.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.49	3.64	46.07	2.40	13.98	11.63	1.03	78043.74
最 大 值	10.57	5.39	58.52	3.52	16.07	12.14	1.08	81773.52
發生時間	3	6	16	14	23	21		23
最 小 值	0.97	2.32	39.02	1.42	11.93	11.02	1.02	74582.33
發生時間	22	19	9	17	13	23		22
零點偏移(率)	-0.06 %	0.01 %	-0.11 %	-0.03 %		-0.01		-0.10 %
全幅偏移(率)	0.02 %	0.24 %	-0.26 %	0.12 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

