

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.83	15.69	41.67	1.81	20.06	10.36	1.12	74310.36
1	6.86	15.99	58.20	1.22	21.75	10.32	1.10	73176.45
2	9.69	14.81	39.44	2.12	18.20	10.68	1.10	73318.18
3	7.94	16.19	57.29	1.98	18.29	11.30	1.10	69986.99
4	4.56	14.68	47.11	1.71	19.49	10.61	1.08	73620.51
5	2.99	17.50	59.95	1.69	19.77	10.75	1.08	70282.94
6	4.96	16.73	48.81	1.72	19.39	10.52	1.08	75122.34
7	5.56	14.68	49.04	1.83	18.87	10.62	1.09	74237.27
8	9.11	15.19	46.50	2.12	17.88	11.06	1.10	71417.57
9	8.85	14.21	44.59	1.97	18.62	10.54	1.12	75011.46
10	8.27	15.18	46.31	2.06	18.23	10.90	1.11	71330.16
11	2.15	17.72	45.93	2.19	16.72	11.34	1.10	68420.93
12	6.16	無效	44.85	2.60	16.51	10.87	1.10	69436.58
13	6.47	15.97	45.65	2.03	18.70	10.27	1.11	71670.58
14	2.98	16.67	44.17	1.99	17.78	10.88	1.10	67316.25
15	2.44	16.45	48.07	1.78	19.05	10.52	1.10	68156.57
16	3.69	16.60	54.61	1.59	19.48	10.49	1.10	66496.08
17	7.44	17.49	46.02	1.78	20.38	9.94	1.10	69928.47
18	4.39	17.02	52.24	1.94	18.87	10.80	1.10	66658.40
19	0.81	17.85	46.53	1.70	18.37	10.81	1.09	65419.23
20	2.09	16.60	53.89	1.74	18.95	10.56	1.07	67044.48
21	4.44	無效	46.61	1.66	20.63	9.52	1.07	70186.52
22	7.35	18.28	48.95	2.28	17.96	11.23	1.10	66323.55
23	1.59	無效	64.67	1.99	18.97	11.25	1.11	64019.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	21	24	24	24	24	24	24
平均值	5.44	16.26	49.21	1.90	18.87	10.67	1.10	70120.46
最大值	9.83	18.28	64.67	2.60	21.75	11.34	1.12	75122.34
發生時間	0	22	23	12	1	11		6
最小值	0.81	14.21	39.44	1.22	16.51	9.52	1.07	64019.25
發生時間	19	9	2	1	12	21		23
零點偏移(率)	-0.01 %	0.00 %	-0.03 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.01 %	0.02 %	0.00 %	-0.15 %		-0.01		0.20 %
有效比率	100.00 %	87.50 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.60	15.80	63.34	1.19	17.13	9.52	1.18	80482.13
1	4.49	15.81	48.39	1.23	18.64	10.05	1.18	79874.48
2	4.10	12.84	64.92	1.04	18.93	9.74	1.18	80218.49
3	9.19	12.84	57.66	2.00	17.53	9.98	1.18	81232.07
4	4.62	13.03	62.26	1.05	18.39	9.99	1.17	79044.73
5	7.95	13.11	50.02	1.70	16.09	10.32	1.16	80706.05
6	7.18	17.43	70.51	0.81	18.76	10.22	1.15	81105.28
7	3.35	11.76	68.66	0.69	18.37	9.71	1.15	82512.09
8	8.04	11.98	54.57	1.55	16.45	10.24	1.15	80066.13
9	6.52	12.11	58.55	1.23	17.27	10.19	1.15	81587.09
10	5.61	13.68	59.79	1.39	16.81	10.45	1.18	79979.46
11	0.68	14.98	65.04	0.98	18.02	10.59	1.16	74497.74
12	2.16	無效	54.12	1.35	16.98	9.91	1.15	81863.91
13	4.60	無效	58.77	1.60	16.73	10.56	1.15	76429.21
14	0.53	18.83	53.21	1.18	17.43	10.55	1.15	72507.51
15	1.52	無效	57.52	1.80	15.54	10.38	1.16	73218.82
16	3.82	17.44	64.06	1.46	17.04	10.63	1.15	71686.84
17	3.89	16.86	50.26	1.16	17.81	9.91	1.15	77873.70
18	1.05	17.04	59.88	0.83	18.22	10.21	1.15	75379.73
19	0.10	18.29	49.18	0.83	17.96	10.08	1.15	76573.35
20	0.84	15.54	55.06	0.47	19.42	9.32	1.16	87062.11
21	2.29	無效	59.61	0.70	18.69	9.69	1.15	81679.46
22	0.26	11.94	50.05	0.33	19.82	9.22	1.14	77562.65
23	0.29	無效	60.53	0.29	20.33	9.51	1.13	79895.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	19	24	24	24	24	24	24
平均值	3.61	14.81	58.17	1.12	17.85	10.04	1.16	78876.59
最大值	9.19	18.83	70.51	2.00	20.33	10.63	1.18	87062.11
發生時間	3	14	6	3	23	16		20
最小值	0.10	11.76	48.39	0.29	15.54	9.22	1.13	71686.84
發生時間	19	7	1	23	15	22		16
零點偏移(率)	-0.02 %	-0.04 %	-0.01 %	-0.04 %		-0.11		-0.10 %
全幅偏移(率)	3.05 %	0.17 %	-0.41 %	0.71 %		-0.06		0.00 %
有效比率	100.00 %	79.17 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.57	14.87	69.14	2.75	16.02	11.34	1.05	82160.29
1	10.03	18.16	60.28	3.59	14.69	11.63	1.06	81057.66
2	9.47	14.03	68.69	3.75	14.59	11.93	1.09	82365.46
3	7.64	14.64	66.10	2.86	15.92	11.36	1.10	85798.08
4	7.83	15.64	68.61	2.96	15.65	11.79	1.10	81008.15
5	10.16	16.82	60.96	3.17	14.78	11.41	1.10	87843.88
6	7.83	15.62	69.87	2.98	15.36	11.63	1.10	84899.40
7	9.31	15.28	67.29	2.68	15.21	11.40	1.10	81747.42
8	8.07	14.04	62.27	2.43	16.00	11.10	1.07	81608.57
9	8.96	19.84	63.89	2.55	15.73	10.49	1.10	84919.43
10	8.61	無效	55.92	2.90	14.91	10.93	1.09	79967.84
11	1.96	13.06	59.18	1.62	17.45	11.01	1.05	76114.24
12	4.28	12.54	61.43	2.32	14.55	11.21	1.06	75461.23
13	1.19	無效	41.78	1.99	14.07	12.21	1.07	67063.03
14	1.15	12.02	50.48	1.44	14.69	11.97	1.10	65985.79
15	1.82	11.80	44.68	1.41	14.90	11.48	1.10	68327.12
16	3.19	無效	57.16	2.35	15.35	10.69	1.09	73876.88
17	4.57	17.95	51.86	2.21	16.39	10.44	1.07	75501.73
18	4.93	17.03	57.71	2.17	16.15	10.24	1.04	77057.94
19	5.84	17.91	59.54	2.26	16.37	10.46	1.04	75644.45
20	3.19	無效	62.67	2.06	16.20	10.48	1.08	80572.18
21	4.25	13.31	61.90	2.11	16.76	10.51	1.08	81480.15
22	1.65	15.35	64.88	1.91	17.68	10.88	1.07	76912.75
23	1.17	無效	52.51	1.76	17.65	10.09	1.05	79361.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	19	24	24	24	24	24	24
平均值	5.61	15.26	59.95	2.43	15.71	11.11	1.08	78613.96
最大值	10.16	19.84	69.87	3.75	17.68	12.21	1.10	87843.88
發生時間	5	9	6	2	22	13		5
最小值	1.15	11.80	41.78	1.41	14.07	10.09	1.04	65985.79
發生時間	14	15	13	15	13	23		14
零點偏移(率)	-0.16 %	0.00 %	-0.04 %	-0.04 %		-0.03		0.00 %
全幅偏移(率)	0.04 %	0.32 %	-0.71 %	0.46 %		0.31		0.20 %
有效比率	100.00 %	79.17 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								