

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.31	2.68	55.03	3.86	14.14	12.94	1.38	65598.49
1	6.19	2.86	67.57	3.39	14.45	13.35	1.41	61405.38
2	7.37	3.63	50.31	3.64	13.92	12.52	1.40	69494.57
3	8.40	5.99	41.54	3.88	13.66	12.52	1.40	68800.44
4	5.54	6.98	61.61	2.96	14.97	12.46	1.39	68467.79
5	3.89	7.94	48.72	4.06	12.93	12.81	1.37	66270.20
6	7.24	3.86	61.92	3.34	14.65	12.43	1.39	68440.37
7	6.93	4.93	62.72	3.85	13.54	12.69	1.38	66915.25
8	5.41	6.25	65.22	3.42	14.62	12.92	1.39	64624.19
9	8.73	3.41	60.61	3.48	14.39	12.40	1.36	68932.67
10	10.01	4.73	65.42	3.57	14.44	12.52	1.39	68405.47
11	9.57	3.93	57.27	3.70	13.92	12.66	1.37	67448.29
12	9.04	4.61	64.76	3.82	13.93	12.81	1.33	66475.06
13	7.21	5.31	57.58	3.67	14.11	12.69	1.33	67001.85
14	6.38	4.06	55.90	3.60	14.13	12.79	1.36	66223.95
15	6.51	4.30	51.78	4.22	13.34	13.00	1.36	65017.63
16	7.10	6.70	61.04	4.26	13.50	13.00	1.37	64971.97
17	11.04	4.98	50.77	3.67	14.03	12.22	1.34	70451.79
18	8.82	3.96	50.09	3.69	14.04	12.40	1.33	68860.16
19	1.83	5.36	60.44	3.11	14.70	12.83	1.36	65076.02
20	3.47	3.88	49.81	2.58	15.85	12.22	1.38	68805.82
21	7.08	4.97	61.16	2.78	15.57	12.16	1.36	69400.64
22	4.67	4.28	70.26	2.97	15.10	12.60	1.37	66520.31
23	3.85	3.82	49.74	2.42	15.74	12.01	1.33	70481.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.90	4.73	57.55	3.50	14.32	12.62	1.37	67253.76
最大值	11.04	7.94	70.26	4.26	15.85	13.35	1.45	70481.99
發生時間	17	5	22	16	20	1		23
最小值	1.83	2.68	41.54	2.42	12.93	12.01	1.33	61405.38
發生時間	19	0	3	23	5	23		1
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	2.27 %	0.49 %	-0.82 %	0.22 %		0.26	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.30	2.44	45.50	2.40	17.32	10.32	1.36	78882.18
1	8.65	3.18	30.08	2.35	18.75	9.64	1.36	79855.69
2	10.21	3.18	40.49	2.91	18.04	9.74	1.37	85505.76
3	10.10	4.45	35.78	3.33	16.92	9.72	1.37	79952.71
4	9.39	4.36	37.10	2.59	17.96	9.75	1.38	80501.51
5	8.58	8.77	36.43	2.53	18.08	9.37	1.38	81836.09
6	10.48	5.77	35.24	2.54	18.02	9.45	1.38	81866.42
7	10.25	5.04	47.66	2.61	17.28	10.00	1.39	84696.54
8	9.28	1.39	50.99	2.31	17.73	10.23	1.38	86941.75
9	10.80	2.11	43.41	2.55	17.73	10.27	1.41	86691.80
10	9.83	2.15	52.57	2.34	17.60	10.25	1.40	85600.43
11	10.26	1.68	53.12	2.84	16.71	10.34	1.38	83867.37
12	10.49	3.24	49.68	2.61	16.93	10.42	1.36	83632.92
13	8.80	3.40	52.03	2.29	16.84	10.55	1.37	83586.85
14	10.16	4.31	55.06	2.28	17.01	10.48	1.39	83987.21
15	9.16	3.71	52.82	2.11	17.45	10.45	1.40	86050.86
16	9.46	3.21	58.76	1.99	17.67	10.39	1.39	86764.93
17	9.76	4.50	51.86	2.21	16.69	10.51	1.38	84942.17
18	10.42	3.65	53.70	2.13	17.77	10.30	1.37	84738.62
19	9.05	3.50	51.98	1.78	18.39	10.09	1.37	85359.74
20	8.70	4.06	51.44	1.39	19.57	9.69	1.37	88394.85
21	9.05	7.78	57.34	1.53	19.70	9.79	1.40	86971.24
22	6.61	3.87	44.12	1.23	19.80	9.95	1.39	86375.47
23	5.11	3.79	55.63	0.82	21.14	9.82	1.38	87604.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.29	3.90	47.62	2.24	17.96	10.06	1.38	84358.65
最大值	10.80	8.77	58.76	3.33	21.14	10.55	1.43	88394.85
發生時間	9	5	16	3	23	13		20
最小值	5.11	1.39	30.08	0.82	16.69	9.37	1.35	78882.18
發生時間	23	8	1	23	17	5		0
零點偏移(率)	0.00 %	-0.02 %	-0.01 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	2.97 %	0.16 %	-0.63 %	0.25 %		0.16	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.70	4.72	47.71	3.21	12.49	11.38	1.38	76056.78
1	5.08	4.01	51.18	2.09	14.82	11.56	1.38	78181.57
2	9.13	4.51	53.41	2.58	14.39	11.77	1.38	76703.96
3	6.64	5.04	54.46	2.16	14.82	11.40	1.38	78870.31
4	8.34	6.84	53.69	2.61	14.49	11.33	1.40	80419.47
5	4.82	1.51	60.94	1.69	16.42	10.90	1.39	80666.22
6	7.99	3.81	55.70	2.28	16.17	10.77	1.37	79571.48
7	5.56	5.27	55.20	2.21	15.28	11.06	1.37	91239.74
8	8.63	3.59	49.35	2.44	15.14	11.14	1.38	80705.27
9	7.92	3.26	47.58	2.27	14.79	11.25	1.37	79295.06
10	8.99	2.16	50.98	2.88	14.12	11.31	1.37	79889.31
11	10.45	2.33	57.99	2.95	14.29	11.37	1.37	79114.68
12	9.44	3.46	53.60	2.78	14.65	10.99	1.35	79246.89
13	7.73	3.72	50.27	2.83	14.32	11.11	1.36	78536.94
14	5.61	3.88	55.90	2.24	15.05	10.94	1.34	79587.88
15	6.16	4.54	48.56	2.50	14.36	11.20	1.36	76585.20
16	9.18	4.71	54.80	2.76	14.96	10.93	1.36	79304.76
17	5.09	3.47	52.64	2.17	14.79	11.00	1.34	80337.75
18	4.90	3.96	62.09	1.89	15.81	11.15	1.36	77523.13
19	5.84	3.74	58.99	1.71	17.22	10.58	1.38	86206.95
20	8.14	4.78	54.43	2.35	15.06	11.15	1.38	84045.04
21	9.28	5.19	62.62	2.12	16.28	11.10	1.38	83735.19
22	8.95	5.55	53.70	2.23	15.49	11.07	1.37	85025.04
23	2.62	4.26	63.83	1.62	16.62	11.40	1.38	81034.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.34	4.10	54.57	2.36	15.08	11.16	1.37	80495.15
最大值	10.45	6.84	63.83	3.21	17.22	11.77	1.42	91239.74
發生時間	11	4	23	0	19	2		7
最小值	2.62	1.51	47.58	1.62	12.49	10.58	1.33	76056.78
發生時間	23	5	9	23	0	19		0
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	2.65 %	-0.03 %	-0.74 %	0.18 %		0.13	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								