

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.97	13.63	52.84	1.70	17.50	11.84	1.41	72782.79
1	6.30	4.87	56.83	1.17	19.43	11.39	1.41	73314.02
2	10.22	7.25	42.28	2.10	18.58	10.60	1.41	75808.87
3	8.80	6.38	45.44	1.73	17.67	11.30	1.39	72453.38
4	10.41	7.46	59.60	1.73	17.81	11.76	1.40	70279.25
5	10.15	3.90	60.51	1.66	17.70	11.97	1.41	70848.95
6	7.62	6.56	64.34	1.58	17.49	12.55	1.41	68302.58
7	3.91	4.47	60.55	1.45	17.68	12.35	1.41	70162.74
8	6.04	1.37	57.75	1.17	19.59	11.76	1.41	72913.28
9	3.97	1.66	67.46	1.22	18.44	12.08	1.39	71440.37
10	7.58	1.51	56.58	1.28	19.28	11.43	1.35	76443.42
11	8.88	1.68	66.91	1.17	19.30	11.10	1.34	77778.40
12	7.93	1.21	59.29	1.25	19.04	11.27	1.33	76715.00
13	9.88	7.63	54.20	1.88	17.46	11.66	1.33	74054.31
14	10.39	12.27	47.73	1.85	16.98	11.44	1.33	75496.73
15	3.86	1.51	69.33	1.29	17.83	11.79	1.35	73391.41
16	12.65	4.69	59.54	1.94	18.07	11.43	1.35	75645.37
17	8.26	4.08	67.41	1.36	18.96	11.36	1.37	75818.56
18	7.42	1.03	47.80	1.13	19.25	11.19	1.39	76883.83
19	6.93	1.15	52.54	1.15	18.85	11.31	1.39	76131.89
20	8.41	2.06	47.20	1.36	18.35	11.50	1.39	74854.25
21	8.98	3.13	55.33	1.36	18.31	11.30	1.41	76706.77
22	7.95	6.61	57.83	1.53	18.21	11.86	1.41	72891.39
23	4.07	2.04	62.61	1.07	19.65	11.88	1.40	72137.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.94	4.51	57.16	1.46	18.39	11.59	1.38	73885.64
最大值	12.65	13.63	69.33	2.10	19.65	12.55	1.42	77778.40
發生時間	16	0	15	2	23	6		11
最小值	3.86	1.03	42.28	1.07	16.98	10.60	1.33	68302.58
發生時間	15	18	2	23	14	2		6
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	2.71 %	0.41 %	-0.41 %	0.15 %		0.30	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.40	6.53	54.91	2.30	17.48	10.18	1.42	64764.43
1	9.74	1.96	56.34	3.09	17.56	10.03	1.42	64789.70
2	10.29	3.20	58.36	3.31	16.67	10.58	1.42	61609.98
3	10.01	8.45	60.96	3.04	17.04	10.60	1.42	64155.56
4	9.49	8.58	56.97	2.79	17.39	10.41	1.43	63399.59
5	12.30	11.12	61.27	3.68	16.86	10.34	1.43	65974.47
6	12.92	3.79	61.56	2.49	17.50	10.58	1.42	67612.04
7	7.99	7.11	66.67	2.09	17.58	10.43	1.42	65809.22
8	8.97	25.70	63.96	4.15	18.82	9.98	1.43	65162.46
9	11.77	2.40	64.68	3.46	19.04	8.89	1.44	71683.59
10	9.77	0.35	71.71	2.96	14.99	10.35	1.46	66095.13
11	10.70	4.34	52.40	2.79	15.42	11.79	1.47	60704.57
12	9.80	3.22	61.72	2.49	16.13	11.33	1.48	63290.17
13	10.34	7.68	66.45	2.65	16.04	11.40	1.47	62747.66
14	11.56	1.20	70.92	2.13	17.84	10.70	1.48	65889.60
15	17.95	2.42	66.51	2.71	17.07	10.59	1.47	66353.81
16	9.88	3.81	52.33	2.51	17.45	10.35	1.46	67567.25
17	9.24	1.27	58.00	1.87	18.79	10.16	1.45	67943.79
18	8.97	1.64	58.36	1.99	17.64	10.62	1.45	66934.46
19	8.31	0.88	61.46	1.73	18.13	10.39	1.45	67876.73
20	9.10	1.26	59.74	2.06	17.47	10.46	1.46	67287.29
21	8.58	1.40	59.19	1.80	18.21	10.48	1.43	67487.32
22	9.06	2.23	68.17	1.92	18.05	11.13	1.44	63336.05
23	8.63	1.54	57.47	1.47	19.20	10.25	1.44	68206.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.20	4.67	61.25	2.56	17.43	10.50	1.44	65695.05
最大值	17.95	25.70	71.71	4.15	19.20	11.79	1.49	71683.59
發生時間	15	8	10	8	23	11		9
最小值	7.99	0.35	52.33	1.47	14.99	8.89	1.40	60704.57
發生時間	7	10	16	23	10	9		11
零點偏移(率)	0.00 %	-0.00 %	-0.10 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	1.61 %	0.13 %	-0.44 %	0.06 %		0.20	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.96	1.51	59.94	3.34	14.35	10.21	1.29	79873.09
1	5.83	7.94	49.75	2.91	14.20	11.51	1.30	76129.33
2	8.36	2.76	58.61	3.09	14.20	11.29	1.30	80479.93
3	10.18	8.92	60.83	3.47	14.03	11.61	1.30	79196.28
4	10.54	7.33	55.00	2.88	15.45	10.89	1.30	81782.19
5	11.61	10.91	53.61	3.20	15.25	10.66	1.30	82487.48
6	10.09	8.20	49.93	2.56	15.78	10.33	1.30	84672.80
7	9.71	2.19	64.38	2.54	17.36	9.50	1.29	81895.08
8	8.29	3.37	59.84	2.23	16.82	10.30	1.28	84889.09
9	8.15	2.24	65.66	2.01	17.34	10.63	1.29	86813.74
10	9.81	11.30	48.08	2.80	14.13	10.77	1.29	81766.49
11	8.35	11.35	55.59	3.76	12.80	11.63	1.28	74867.54
12	8.42	2.60	59.14	2.01	16.47	10.69	1.30	85456.40
13	7.96	7.49	57.30	2.09	16.03	10.62	1.30	85085.47
14	4.47	6.41	56.32	1.89	17.47	9.70	1.29	85296.79
15	8.54	6.64	70.14	3.09	13.86	10.92	1.30	77114.65
16	10.26	3.21	44.81	2.78	15.46	11.00	1.30	86036.11
17	8.89	2.81	55.91	2.46	15.61	10.90	1.30	86120.51
18	9.48	1.97	58.54	2.34	17.14	10.34	1.30	88728.48
19	9.09	1.69	60.72	2.91	15.06	10.70	1.30	84550.27
20	10.04	12.67	57.52	4.69	14.70	10.99	1.29	82409.39
21	9.71	1.49	58.58	2.64	16.09	11.00	1.30	82561.60
22	8.49	7.04	55.14	2.20	16.95	10.44	1.30	86407.46
23	9.26	4.47	58.85	2.19	16.93	10.92	1.29	83677.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.94	5.69	57.26	2.75	15.56	10.73	1.30	82845.72
最大值	11.61	12.67	70.14	4.69	17.47	11.63	1.33	88728.48
發生時間	5	20	15	20	14	11		18
最小值	4.47	1.49	44.81	1.89	12.80	9.50	1.27	74867.54
發生時間	14	21	16	14	11	7		11
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-1.12 %	-0.25 %	0.22 %	0.75 %		0.26	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								