

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.27	5.58	65.62	2.25	15.58	12.18	1.48	71589.82
1	4.79	6.36	57.00	2.48	15.21	12.55	1.49	68661.81
2	3.26	5.91	65.85	2.59	14.58	12.40	1.50	70618.19
3	5.54	9.14	49.02	3.47	13.42	12.61	1.49	69336.36
4	3.08	6.97	57.86	2.81	13.99	12.28	1.49	71001.62
5	8.46	5.81	46.97	4.24	12.38	12.70	1.47	68466.12
6	6.92	3.18	57.89	3.38	13.81	12.40	1.46	70874.23
7	4.40	4.01	59.48	3.69	13.10	12.86	1.46	67542.42
8	3.90	4.78	64.53	3.18	14.09	12.74	1.47	68063.90
9	5.36	3.69	53.71	2.98	14.33	12.35	1.45	70185.91
10	5.76	3.81	57.04	3.07	14.17	12.40	1.42	70000.48
11	1.67	4.36	68.61	2.95	14.35	12.88	1.53	66232.52
12	0.21	3.89	57.58	2.28	15.38	12.24	1.50	70692.66
13	1.15	5.19	57.89	2.89	14.00	12.40	1.50	70672.43
14	8.64	11.89	61.44	3.71	13.20	12.53	1.47	70055.90
15	11.29	8.55	57.29	4.15	13.24	12.52	1.46	69487.27
16	8.99	5.24	56.53	3.44	13.94	12.38	1.45	70011.28
17	10.60	4.05	66.73	3.63	13.56	12.50	1.45	69770.68
18	10.12	6.27	55.15	3.70	13.62	12.50	1.41	69670.05
19	10.69	6.15	60.51	3.65	13.39	12.55	1.43	69530.77
20	8.98	5.16	59.49	3.95	12.93	12.77	1.46	68020.38
21	8.44	9.62	46.17	4.26	12.56	12.71	1.43	68313.52
22	10.86	10.63	56.56	4.14	12.99	12.61	1.42	69438.03
23	10.02	2.67	65.06	3.15	14.49	12.37	1.44	69990.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.64	5.95	58.50	3.34	13.85	12.52	1.46	69509.44
最大值	11.29	11.89	68.61	4.26	15.58	12.88	1.63	71589.82
發生時間	15	14	11	21	0	11		0
最小值	0.21	2.67	46.17	2.25	12.38	12.18	1.40	66232.52
發生時間	12	23	21	0	5	0		11
零點偏移(率)	-0.02 %	-0.03 %	-0.02 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.22 %	0.25 %	-0.73 %	0.08 %		0.32	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.99	7.30	49.83	1.25	18.78	10.02	1.43	83456.59
1	2.82	8.63	54.69	1.23	18.21	10.22	1.43	83351.15
2	4.63	7.01	52.05	2.18	15.63	10.27	1.42	81418.93
3	4.45	3.03	54.99	1.99	16.21	10.18	1.40	82556.06
4	6.77	3.02	45.20	2.25	16.24	9.91	1.40	81872.37
5	8.67	4.36	46.64	2.30	16.17	9.99	1.40	79721.43
6	4.56	4.02	56.09	2.00	16.22	10.41	1.42	75211.87
7	2.41	4.15	69.98	1.59	16.75	11.20	1.43	74145.72
8	0.13	4.31	59.39	1.73	15.62	11.70	1.43	72741.75
9	0.19	5.80	56.13	1.75	15.90	11.34	1.37	82326.90
10	1.96	5.09	54.33	2.02	15.99	11.05	1.38	86531.45
11	3.68	3.31	60.15	2.16	16.07	11.38	1.35	84128.44
12	5.75	4.02	57.50	2.47	15.58	11.61	1.33	82644.92
13	7.90	4.68	56.45	2.56	15.29	11.42	1.33	83034.02
14	7.50	6.11	61.73	3.57	15.17	11.42	1.36	82802.65
15	8.30	5.18	52.98	3.42	14.65	11.64	1.36	82232.74
16	9.09	3.23	54.14	3.00	15.17	11.39	1.38	83645.77
17	7.88	3.30	59.15	3.33	15.15	11.65	1.38	81421.64
18	8.82	4.60	57.34	2.85	15.50	11.33	1.38	84459.04
19	7.75	5.74	56.93	2.81	14.27	11.50	1.33	84467.33
20	9.83	8.58	51.82	2.63	15.05	10.42	1.35	81719.07
21	10.55	4.35	54.16	2.32	15.84	10.57	1.37	81131.69
22	9.38	3.43	66.18	1.90	16.62	10.82	1.38	79572.77
23	7.70	3.83	60.53	1.32	18.46	10.46	1.42	85330.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.11	4.88	56.18	2.28	16.02	10.91	1.38	81663.54
最大值	10.55	8.63	69.98	3.57	18.78	11.70	1.45	86531.45
發生時間	21	1	7	14	0	8		10
最小值	0.13	3.02	45.20	1.23	14.27	9.91	1.33	72741.75
發生時間	8	4	4	1	19	4		8
零點偏移(率)	0.00 %	-0.01 %	-0.04 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.86 %	0.45 %	-0.40 %	0.18 %		0.31	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.71	7.46	56.23	1.21	17.38	10.35	1.76	82476.75
1	2.26	9.93	54.84	1.46	15.57	10.95	1.74	80793.90
2	2.81	6.62	59.20	1.73	14.82	11.06	1.75	82212.70
3	2.38	8.54	57.95	1.50	15.94	10.74	1.73	84156.98
4	3.16	1.58	54.18	1.74	14.99	10.92	1.74	80969.06
5	3.35	1.78	61.39	1.39	16.38	11.14	1.73	80207.66
6	2.46	3.85	63.47	1.76	14.69	11.55	1.74	79979.60
7	3.45	5.26	63.18	1.50	16.00	10.93	1.73	81756.53
8	4.33	4.17	60.16	1.50	16.01	10.97	1.73	83790.39
9	3.38	4.81	62.01	1.68	15.54	11.22	1.75	80734.55
10	1.93	5.39	61.05	1.63	16.53	10.95	1.75	83090.38
11	1.23	3.53	60.23	1.32	17.87	10.58	1.79	85083.74
12	2.73	10.32	59.74	1.96	15.37	10.72	1.78	84424.21
13	2.16	3.39	57.05	2.44	14.29	11.29	1.77	79958.17
14	7.86	2.36	60.75	2.06	15.91	10.87	1.76	84108.65
15	12.44	3.92	61.58	3.19	15.18	11.15	1.76	82180.25
16	7.93	2.95	61.39	2.03	15.40	10.97	1.76	84752.73
17	7.30	4.02	61.98	2.30	14.73	11.24	1.76	83423.86
18	8.15	7.22	64.30	2.40	14.58	11.35	1.72	82721.09
19	9.56	15.22	60.27	3.23	13.19	11.39	1.72	82051.31
20	8.12	8.35	61.72	3.32	12.75	11.56	1.72	79813.91
21	10.22	8.42	60.90	3.18	13.91	11.55	1.72	80097.70
22	9.47	4.56	60.88	2.31	14.58	11.49	1.72	81447.37
23	7.77	4.60	58.02	1.78	15.79	10.96	1.72	83391.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.34	5.76	60.10	2.03	15.31	11.08	1.74	82234.31
最大值	12.44	15.22	64.30	3.32	17.87	11.56	1.80	85083.74
發生時間	15	19	18	20	11	20		11
最小值	1.23	1.58	54.18	1.21	12.75	10.35	1.71	79813.91
發生時間	11	4	4	0	20	0		20
零點偏移(率)	-0.11 %	0.00 %	-0.03 %	-0.03 %		0.03	0.00	0.00 %
全幅偏移(率)	1.38 %	0.57 %	-0.63 %	0.08 %		0.29	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								