

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.17	7.98	63.78	0.85	19.99	11.11	1.02	74927.38
1	7.65	9.13	54.05	0.98	19.99	10.79	1.02	76999.75
2	9.32	10.25	67.87	1.57	18.74	11.45	1.01	73465.79
3	9.23	7.80	54.86	1.92	17.54	11.38	0.99	75278.57
4	4.70	9.24	68.33	1.58	17.12	12.13	1.00	69854.41
5	3.54	9.82	59.47	0.87	19.02	11.66	1.04	71415.46
6	7.56	6.95	57.36	1.50	17.84	11.44	1.05	75132.73
7	6.41	7.19	65.03	1.77	17.39	11.81	1.05	71848.47
8	8.07	6.43	53.85	1.47	18.17	11.31	1.06	74973.29
9	7.49	6.37	57.63	1.54	17.13	11.45	1.07	72441.61
10	6.35	8.16	60.82	1.08	18.41	11.15	1.07	73984.49
11	4.69	6.08	49.01	1.30	16.68	11.16	1.08	74525.00
12	5.29	6.48	52.60	1.32	17.28	11.00	1.11	76470.64
13	3.29	7.05	57.85	1.36	17.35	11.36	1.11	73813.79
14	8.33	11.64	48.58	1.98	16.82	10.87	1.10	76279.03
15	9.61	3.27	55.35	1.80	16.97	11.29	1.10	74848.12
16	9.36	5.81	63.99	1.65	17.25	11.33	1.12	75405.42
17	7.63	5.05	54.99	1.51	17.23	11.37	1.13	75312.54
18	6.74	5.18	54.13	1.25	17.94	11.46	1.11	74454.16
19	7.99	4.86	52.32	1.19	19.08	10.64	1.09	79818.74
20	5.90	5.61	62.76	1.02	18.40	11.40	1.08	74428.54
21	4.86	5.69	34.87	0.81	19.90	10.42	1.07	79482.49
22	8.63	5.70	36.52	1.20	19.22	10.54	1.06	79213.42
23	4.31	5.70	53.14	0.98	18.82	11.23	1.07	74465.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.84	6.98	55.80	1.35	18.10	11.24	1.07	74951.63
最大值	9.61	11.64	68.33	1.98	19.99	12.13	1.14	79818.74
發生時間	15	14	4	14	0	4		19
最小值	3.29	3.27	34.87	0.81	16.68	10.42	0.99	69854.41
發生時間	13	15	21	21	11	21		4
零點偏移(率)	-0.04 %	-0.03 %	-0.00 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	0.49 %	0.36 %	-0.03 %	0.04 %		0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.82	3.70	63.09	1.60	18.87	10.20	1.07	84378.73
1	6.13	9.36	49.24	2.00	20.04	9.57	1.07	88390.37
2	8.13	6.34	48.25	2.40	18.59	9.83	1.07	87464.76
3	7.74	1.96	52.23	1.76	19.31	9.80	1.05	87371.50
4	7.67	5.08	48.65	1.86	19.55	9.57	1.05	88434.36
5	8.68	3.59	46.17	2.24	18.77	9.74	1.05	87997.13
6	8.42	6.59	45.89	1.73	18.97	9.69	1.07	90829.90
7	8.78	9.15	51.00	1.72	18.83	9.59	1.07	89591.41
8	9.42	1.69	53.71	2.03	17.82	10.15	1.09	87446.76
9	9.12	6.13	52.34	1.39	18.71	10.29	1.08	87774.40
10	7.66	2.79	43.58	1.63	18.55	10.39	1.07	87277.88
11	7.71	4.83	39.58	2.64	17.06	10.82	1.07	85650.16
12	7.91	3.62	41.50	1.83	17.93	10.68	1.05	86064.56
13	3.45	7.80	48.82	1.98	17.86	10.72	1.05	85347.87
14	5.19	1.69	40.49	1.68	18.20	10.57	1.05	87061.56
15	7.16	2.65	44.77	1.46	18.59	10.45	1.05	87231.61
16	8.03	7.17	41.65	1.89	18.92	10.20	1.05	88806.16
17	4.34	4.20	48.57	1.81	18.47	10.50	1.05	87056.22
18	5.58	3.04	41.41	2.38	17.77	10.50	1.06	87599.86
19	8.30	6.48	56.29	2.31	18.10	10.46	1.07	87692.90
20	8.32	3.79	43.58	2.41	17.72	10.62	1.07	86828.67
21	7.85	6.45	44.18	1.96	18.71	10.40	1.07	86839.02
22	8.36	4.51	43.29	2.31	18.38	10.59	1.07	85504.57
23	6.59	3.36	51.25	1.40	19.78	9.97	1.07	87052.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.35	4.83	47.48	1.93	18.56	10.22	1.06	87320.54
最大值	9.42	9.36	63.09	2.64	20.04	10.82	1.10	90829.90
發生時間	8	1	0	11	1	11		6
最小值	3.45	1.69	39.58	1.39	17.06	9.57	1.04	84378.73
發生時間	13	8	11	9	11	1		0
零點偏移(率)	-0.16 %	-0.03 %	-0.04 %	-0.01 %		0.02		-0.20 %
全幅偏移(率)	0.49 %	0.01 %	-0.13 %	0.26 %		0.23		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.92	7.62	45.03	1.44	17.21	10.24	0.94	82254.53
1	7.81	8.57	49.33	1.24	18.62	10.29	0.94	83745.10
2	7.76	10.57	54.13	1.77	17.13	10.36	0.95	83173.11
3	9.50	9.49	46.21	2.24	14.89	10.91	0.97	78378.19
4	7.52	3.71	53.41	1.77	15.95	10.75	0.97	80643.50
5	7.71	5.83	53.20	2.32	14.32	10.99	0.94	77385.09
6	8.91	6.90	51.18	1.90	15.91	10.67	0.95	80855.06
7	9.50	4.04	42.78	1.38	16.48	10.14	0.97	80219.37
8	8.86	8.69	43.80	1.56	14.99	10.55	0.95	79129.81
9	9.26	4.53	56.13	1.58	16.71	9.76	0.95	84733.90
10	5.13	3.57	50.42	1.44	14.23	10.84	0.94	75598.04
11	4.28	2.64	50.71	1.62	14.26	10.74	0.95	76566.66
12	5.32	4.81	46.25	1.47	14.85	10.81	0.96	77119.73
13	6.51	6.60	55.84	1.08	16.86	9.86	0.97	80365.32
14	9.44	6.14	49.42	1.71	15.74	10.08	0.97	83602.23
15	8.36	6.80	45.85	1.63	14.61	11.05	0.97	75479.29
16	6.78	4.58	55.63	1.15	15.87	10.79	0.96	75175.64
17	1.43	4.31	57.54	0.60	16.93	10.78	0.95	72957.67
18	2.09	5.66	47.57	0.75	17.71	9.60	0.95	82042.21
19	2.40	21.91	39.06	0.99	15.77	10.42	0.95	76682.47
20	3.40	10.12	39.49	0.79	17.22	10.15	0.95	77023.02
21	7.47	5.83	46.60	1.20	17.38	10.09	0.96	78959.72
22	7.66	6.72	47.55	1.41	15.60	10.61	0.97	77086.45
23	3.80	4.72	51.22	0.87	16.97	10.30	0.97	78454.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.66	6.85	49.10	1.41	16.09	10.45	0.96	79067.96
最大值	9.50	21.91	57.54	2.32	18.62	11.05	0.98	84733.90
發生時間	3	19	17	5	1	15		9
最小值	1.43	2.64	39.06	0.60	14.23	9.60	0.94	72957.67
發生時間	17	11	19	17	10	18		17
零點偏移(率)	-0.06 %	0.00 %	-0.05 %	-0.06 %		0.02		0.00 %
全幅偏移(率)	0.04 %	0.05 %	-0.32 %	0.03 %		0.50		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								