

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.54	12.39	55.85	0.55	18.00	11.38	0.99	80093.00
1	6.05	11.96	60.50	0.82	18.76	11.19	1.00	81003.47
2	8.90	9.75	42.34	1.37	15.76	11.05	0.99	81670.18
3	10.08	12.04	47.52	0.94	16.56	11.37	0.97	79269.37
4	8.03	11.87	51.90	0.68	16.69	11.28	0.97	79517.78
5	9.44	10.55	48.69	0.35	17.82	10.90	0.97	82793.99
6	8.08	10.45	54.41	0.26	18.12	11.26	0.99	78867.81
7	8.78	9.72	48.70	0.26	18.32	10.94	1.02	81545.94
8	9.67	4.55	52.10	0.38	18.07	11.35	1.00	80664.43
9	9.81	4.23	51.59	2.04	17.73	11.68	0.97	83332.99
10	5.86	4.38	50.20	0.35	18.41	11.31	0.99	86750.58
11	3.56	4.33	54.05	0.42	16.74	12.17	0.99	81171.15
12	7.80	4.13	50.16	0.35	17.28	11.77	0.99	82813.43
13	3.24	5.74	56.85	0.32	17.56	11.71	0.98	83162.94
14	5.55	6.46	48.43	0.53	16.84	12.09	0.98	80172.00
15	5.42	6.00	57.62	0.53	17.93	11.73	0.98	82420.63
16	6.54	6.25	43.18	0.65	16.15	12.08	0.98	77599.55
17	8.60	6.36	49.91	0.70	17.03	11.71	0.97	83394.33
18	7.00	6.05	60.39	0.49	18.12	11.86	0.94	82033.66
19	9.85	6.70	55.42	0.41	18.44	11.27	0.96	84080.61
20	6.99	13.33	56.57	0.19	19.15	11.22	0.97	83338.14
21	4.29	11.15	48.97	0.23	18.01	11.19	0.97	83594.20
22	2.77	11.40	52.26	0.29	18.05	11.34	0.97	81259.08
23	1.94	12.04	63.78	0.24	18.55	11.42	0.97	80640.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.82	8.41	52.56	0.56	17.67	11.47	0.98	81716.25
最大值	10.08	13.33	63.78	2.04	19.15	12.17	1.02	86750.58
發生時間	3	20	23	9	20	11		10
最小值	1.94	4.13	42.34	0.19	15.76	10.90	0.94	77599.55
發生時間	23	12	2	20	2	5		16
零點偏移(率)	-0.05 %	-0.00 %	-0.00 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.07 %	-0.27 %	-0.35 %	0.46 %		-0.09		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.33	11.90	47.03	0.72	19.02	9.56	1.10	82341.80
1	8.91	9.40	41.91	1.20	17.87	9.86	1.10	80116.73
2	5.79	13.56	38.69	1.51	15.26	9.70	1.07	71142.14
3	6.58	6.02	51.61	0.52	18.48	9.20	1.07	81643.00
4	5.29	7.75	50.36	0.35	18.72	9.42	1.07	78287.78
5	9.73	5.80	51.34	0.53	18.29	9.21	1.07	83829.18
6	0.42	7.16	64.73	0.21	17.54	9.66	1.11	78228.04
7	0.50	10.17	49.51	0.37	18.56	9.31	1.12	75594.71
8	4.97	14.00	52.68	0.71	18.89	9.07	1.12	74597.94
9	2.74	34.72	51.01	1.20	18.03	9.87	1.14	66496.87
10	8.42	8.17	33.17	0.53	18.03	8.46	1.14	81838.89
11	7.34	9.59	47.10	0.54	18.13	9.08	1.11	76038.39
12	7.05	3.07	52.91	0.38	18.13	9.24	1.13	82567.97
13	2.42	4.31	54.43	0.31	19.24	9.73	1.15	79441.23
14	11.77	13.70	40.79	0.89	18.24	9.49	1.15	79953.63
15	25.50	14.45	53.91	1.40	16.17	10.18	1.14	77026.54
16	11.59	6.13	59.99	1.22	16.62	10.76	1.11	76566.78
17	9.25	9.85	49.76	0.93	16.59	9.80	1.10	73427.53
18	8.02	9.15	49.10	1.03	14.82	10.47	1.10	78478.61
19	1.43	5.82	63.47	0.53	16.60	11.28	1.11	69649.57
20	0.10	6.68	49.29	0.46	18.18	10.56	1.12	74710.25
21	0.09	7.94	46.20	0.48	17.97	10.33	1.12	74564.52
22	0.10	9.85	35.66	0.27	19.39	9.23	1.12	82747.47
23	0.77	10.58	48.97	0.37	19.40	9.63	1.12	79074.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.05	9.99	49.32	0.69	17.84	9.71	1.11	77431.85
最大值	25.50	34.72	64.73	1.51	19.40	11.28	1.15	83829.18
發生時間	15	9	6	2	23	19		5
最小值	0.09	3.07	33.17	0.21	14.82	8.46	1.07	66496.87
發生時間	21	12	10	6	18	10		9
零點偏移(率)	-0.09 %	0.00 %	-0.02 %	-0.03 %		-0.35		0.00 %
全幅偏移(率)	0.04 %	-0.24 %	-0.54 %	0.45 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.76	7.09	47.55	2.26	16.41	10.67	0.97	80018.10
1	4.90	6.51	46.56	1.86	16.28	10.75	0.99	78179.58
2	9.67	12.58	45.96	3.22	13.24	10.65	0.99	77250.82
3	5.78	8.49	51.43	2.17	14.74	11.56	0.99	76836.21
4	5.19	17.42	50.02	1.65	15.48	11.27	0.99	77982.65
5	1.84	9.58	53.83	0.95	17.16	10.70	0.97	77449.31
6	2.08	14.60	47.76	1.17	17.13	10.39	0.98	80284.30
7	2.11	10.64	43.64	1.80	14.47	10.80	0.95	72382.11
8	3.25	11.18	48.18	1.67	15.12	10.94	0.98	76380.49
9	6.77	4.45	52.41	1.95	15.30	10.99	0.94	77703.24
10	5.63	3.58	49.54	1.63	16.34	10.50	0.93	76351.46
11	5.29	3.20	40.81	1.59	15.56	10.62	0.93	73916.03
12	0.75	4.22	43.96	1.21	15.42	10.89	0.91	71459.47
13	0.07	5.97	42.67	1.25	15.11	10.67	0.96	73363.68
14	1.27	10.44	52.85	1.29	15.93	10.25	0.96	77991.93
15	12.44	11.42	49.34	2.43	14.62	10.76	0.94	70973.71
16	11.74	2.66	53.78	2.37	14.45	10.85	0.92	71034.41
17	6.09	2.74	58.09	1.47	15.79	11.13	0.97	75361.10
18	2.72	1.33	53.08	1.09	17.03	10.80	0.98	78180.98
19	5.80	1.87	51.21	1.09	17.46	10.38	0.99	82283.78
20	5.06	9.88	54.24	1.17	17.49	10.51	0.98	82036.53
21	0.22	11.47	53.61	0.98	17.05	10.88	0.95	80798.35
22	0.73	10.82	53.63	0.94	17.73	10.52	0.94	82528.22
23	1.01	9.19	52.79	0.90	18.32	10.46	0.94	80270.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.51	7.97	49.87	1.59	15.98	10.75	0.96	77125.69
最大值	12.44	17.42	58.09	3.22	18.32	11.56	1.00	82528.22
發生時間	15	4	17	2	23	3		22
最小值	0.07	1.33	40.81	0.90	13.24	10.25	0.91	70973.71
發生時間	13	18	11	23	2	14		15
零點偏移(率)	-0.06 %	0.00 %	-0.08 %	0.00 %		0.01		0.00 %
全幅偏移(率)	-0.83 %	-0.06 %	-1.19 %	0.25 %		0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								