

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.00	12.29	60.52	0.82	19.40	11.56	1.31	77210.08
1	10.39	12.27	45.59	2.00	19.46	10.32	1.30	86653.85
2	11.44	12.25	54.69	2.89	17.31	10.95	1.31	81410.71
3	9.26	11.77	58.75	3.10	15.86	11.56	1.31	76999.64
4	12.41	12.00	50.31	2.68	17.60	11.00	1.31	82068.09
5	9.68	11.58	52.27	1.80	17.43	11.11	1.34	78260.88
6	9.96	12.12	53.26	2.05	17.95	11.01	1.34	82631.70
7	7.75	12.34	54.85	1.63	17.84	11.52	1.34	78963.82
8	9.14	11.57	50.91	1.63	19.01	10.73	1.34	84580.95
9	9.18	12.38	63.40	1.39	18.27	11.51	1.33	78893.14
10	9.56	11.88	49.45	2.12	17.17	11.21	1.33	81077.61
11	9.39	12.05	61.07	2.23	15.91	11.65	1.30	77456.98
12	9.86	12.06	61.36	1.91	16.32	11.62	1.32	77131.05
13	9.29	12.02	64.91	2.13	15.82	11.61	1.29	77556.24
14	10.76	13.14	61.60	1.22	19.26	10.75	1.29	82845.66
15	8.70	12.91	52.72	1.83	17.03	10.97	1.29	79138.95
16	9.40	13.43	66.65	1.20	17.89	10.99	1.29	79145.87
17	10.22	11.31	47.95	1.70	18.36	10.47	1.29	85939.21
18	8.54	12.19	34.12	1.57	16.92	11.26	1.31	80313.20
19	10.19	12.18	48.12	1.29	18.16	11.18	1.31	79949.94
20	9.10	12.10	49.49	1.48	17.50	10.89	1.29	82862.59
21	10.02	11.92	48.76	1.49	17.64	11.15	1.30	81015.50
22	9.04	11.95	59.00	1.72	16.95	11.38	1.32	79781.29
23	9.02	12.50	57.76	1.18	17.88	11.71	1.33	76708.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.60	12.18	54.48	1.79	17.62	11.17	1.31	80358.14
最大值	12.41	13.43	66.65	3.10	19.46	11.71	1.34	86653.85
發生時間	4	16	16	3	1	23		1
最小值	7.75	11.31	34.12	0.82	15.82	10.32	1.29	76708.33
發生時間	7	17	18	0	13	1		23
零點偏移(率)	-0.08 %	-0.05 %	-0.04 %	-0.01 %		-0.05	-0.01	0.40 %
全幅偏移(率)	1.09 %	-0.63 %	-1.16 %	-1.67 %		0.09	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.90	12.01	49.31	1.07	18.09	10.34	1.03	82050.08
1	10.83	11.99	57.01	2.30	16.17	10.62	1.03	80882.15
2	10.10	11.74	58.79	1.69	17.35	10.34	1.04	81984.83
3	10.88	11.83	60.62	1.42	17.15	10.45	1.04	80544.67
4	8.93	11.43	56.73	1.60	17.28	10.07	1.04	81501.05
5	11.18	11.65	62.64	1.71	17.64	10.28	1.04	79185.23
6	7.54	11.48	49.47	1.17	17.82	10.11	1.04	80017.06
7	10.73	11.96	54.18	0.76	18.82	9.85	1.04	81620.48
8	12.77	11.40	56.42	0.63	18.80	9.95	1.04	81191.10
9	7.68	12.26	60.49	0.57	20.10	9.21	1.02	79034.23
10	8.35	11.19	60.83	1.07	17.10	9.51	1.03	76714.46
11	9.85	12.82	58.72	0.83	20.23	9.12	1.04	79098.65
12	8.25	11.40	67.74	1.19	16.92	10.18	1.04	77456.14
13	9.77	11.51	57.49	0.85	18.68	9.84	1.05	77901.84
14	12.12	11.27	59.14	0.55	19.68	9.38	1.03	79264.50
15	7.42	11.37	60.27	0.78	18.26	9.96	1.04	79048.94
16	10.21	11.40	38.36	0.92	18.09	9.72	1.02	77922.92
17	8.46	12.19	50.80	1.30	17.24	10.21	1.03	79435.22
18	10.32	11.51	52.40	1.22	17.14	10.22	1.02	76947.96
19	9.45	7.13	50.85	1.82	17.37	9.87	1.03	81266.53
20	11.11	10.30	51.69	1.85	17.57	10.01	1.05	80679.44
21	7.15	11.75	54.64	1.21	17.03	10.30	1.02	78616.16
22	10.10	13.23	60.21	1.01	18.79	10.42	1.02	74349.74
23	10.12	15.00	52.49	0.95	21.61	8.80	1.02	87484.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.76	11.66	55.89	1.19	18.12	9.95	1.03	79758.25
最大值	12.77	15.00	67.74	2.30	21.61	10.62	1.06	87484.68
發生時間	8	23	12	1	23	1		23
最小值	7.15	7.13	38.36	0.55	16.17	8.80	1.02	74349.74
發生時間	21	19	16	14	1	23		22
零點偏移(率)	-0.15 %	0.01 %	-0.03 %	-0.01 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-0.41 %	-0.17 %	0.39 %	-0.29 %		-0.11	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.17	12.15	52.25	2.16	18.06	10.44	1.41	70230.19
1	6.42	12.52	57.55	2.06	20.10	9.85	1.40	74606.13
2	10.13	11.93	46.14	2.06	20.34	9.55	1.41	76981.16
3	8.19	12.02	51.35	1.76	18.61	9.92	1.39	73379.31
4	9.58	11.66	55.70	1.90	17.84	9.93	1.39	71795.72
5	10.53	11.60	57.43	1.86	17.89	9.97	1.39	71413.32
6	8.97	11.47	56.74	1.99	18.59	9.76	1.39	72692.46
7	5.83	11.44	44.29	1.75	18.19	9.95	1.40	72837.55
8	9.18	11.70	49.97	1.94	17.16	10.44	1.43	73133.40
9	8.84	11.82	53.41	2.07	17.84	10.28	1.41	73753.61
10	10.34	11.65	63.30	2.07	18.06	10.14	1.42	74050.38
11	9.67	13.63	63.58	2.44	15.60	10.73	1.37	70530.01
12	7.90	12.17	63.23	1.77	17.76	10.41	1.42	71532.97
13	9.90	11.54	57.42	1.79	18.25	9.87	1.38	73178.48
14	9.01	11.89	60.62	1.66	17.23	10.38	1.43	70291.71
15	9.27	11.74	56.02	1.66	17.60	10.11	1.38	72842.51
16	11.97	13.11	39.98	2.45	17.80	9.56	1.40	72708.99
17	7.17	13.82	41.64	2.36	18.42	8.79	1.36	72742.35
18	10.51	12.42	49.16	2.89	19.22	9.05	1.40	75827.87
19	8.52	6.86	52.40	0.41	18.28	9.37	1.41	73905.64
20	11.91	12.13	44.30	1.01	18.81	9.47	1.37	73543.21
21	7.82	11.86	38.89	0.93	18.01	9.35	1.36	75335.48
22	9.42	11.63	57.13	0.92	18.67	9.80	1.39	72322.40
23	10.40	13.44	42.12	2.20	20.07	9.56	1.38	74305.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.19	11.92	52.28	1.84	18.27	9.86	1.39	73080.86
最大值	11.97	13.82	63.58	2.89	20.34	10.73	1.45	76981.16
發生時間	16	17	11	18	2	11		2
最小值	5.83	6.86	38.89	0.41	15.60	8.79	1.34	70230.19
發生時間	7	19	21	19	11	17		0
零點偏移(率)	-0.05 %	-0.08 %	-0.03 %	-0.01 %		-0.18	-0.01	-0.10 %
全幅偏移(率)	-0.95 %	-0.49 %	1.02 %	0.51 %		0.07	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								